

Appendix M

Air Emissions Reports

Appendix M-1

Stantec Consulting Ltd., 2015

**Source Emissions Testing 2015 –
CertainTeed Gypsum Wallboard Plant,
McAdam,
New Brunswick**



Prepared for:

CertainTeed Gypsum Canada Inc.
57 Quality Way
McAdam, NB E6J 1B1

Prepared by:

Stantec Consulting Ltd.
845 Prospect Street
Fredericton, NB E3B 2T7

Project No. 121811606
December 16, 2015

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

December 16, 2015

TABLE OF CONTENTS

EXECUTIVE SUMMARY	E-1
1.0 INTRODUCTION	1
1.1 GENERAL SYNOPSIS	1
2.0 STUDY METHODOLOGY	2
2.1 SCOPE OF WORK AND OVERVIEW OF METHODOLOGY.....	2
2.2 TASK 1 – INITIAL PREPARATION.....	3
2.3 TASK 2 – ON-SITE SOURCE EMISSIONS TESTING	3
2.3.1 Preliminary Testing	3
2.3.2 Total Particulate Matter	4
2.3.3 Combustion Gases	4
2.4 TASK 3 – LABORATORY ANALYSIS OF COLLECTED SAMPLES.....	7
2.5 TASK 4 – DATA ANALYSIS AND EMISSION CALCULATIONS	7
2.6 TASK 5 – REPORTING	7
2.7 QUALITY ASSURANCE AND QUALITY CONTROL	7
3.0 RESULTS AND DISCUSSION.....	9
3.1 CALCINE MILL	9
3.2 ROCK DRYER.....	11
3.3 ZONE 1 AND ZONE 2 DRYERS	12
4.0 CLOSING REMARKS.....	16

LIST OF TABLES

Table 3.1	Source Emissions Testing Results – Calcine Mill, McAdam Gypsum Wallboard Plant	9
Table 3.2	Source Emissions Testing Results – Rock Dryer, McAdam Gypsum Wallboard Plant	11
Table 3.3	Source Emissions Testing Results – Zone 1 Dryer, McAdam Gypsum Wallboard Plant	13
Table 3.4	Source Emissions Testing Results – Zone 2 Dryer, McAdam Gypsum Wallboard Plant	14

LIST OF FIGURES

Figure 1	US EPA Method 5 Sampling Train.....	5
----------	-------------------------------------	---

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

December 16, 2015

LIST OF APPENDICES

- Appendix A Approval to Operate
- Appendix B PTP and Approval Email
- Appendix C Calibration Data
- Appendix D Sampling Locations
- Appendix E Field Sheets
- Appendix F Calculated Data - Sample Calculations and Velocity Profiles

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

December 16, 2015

EXECUTIVE SUMMARY

CertainTeed Gypsum Canada Inc. (CertainTeed) retained Stantec Consulting Ltd. (Stantec) to conduct source emissions testing on the exhaust stacks at its Wallboard Plant in McAdam, New Brunswick. The objective of the source emissions testing was to quantify the emissions from select stacks, in partial fulfillment of the regulatory requirements set out in the Certificate of Approval to Operate (Approval #I-8150, presented in Appendix A) issued by the New Brunswick Department of Environment and Local Government (NBDELG).

The source emissions testing was conducted over the period of October 20-29, 2015, and was completed under normal operating conditions in order to determine the emission rates and concentrations of specified contaminants outlined in Table I.

Table I Source Emissions Testing Matrix – Gypsum Wallboard Plant, McAdam, NB

Sampling Location	No. of Tests	Sample Type / Pollutant	Sampling Method
Calcine Mill, Rock Dryer, Zone 1 and Zone 2 Dryers (4 sources)	3	Velocity Traverse	EPS 1/RM/8, Method B
	3	Molecular Weight	EPS 1/RM/8, Method C
	3	Moisture Content	EPS 1/RM/8, Method D
	3	Total Suspended Particulate Matter (PM)	EPS 1/RM/8, Method E
	3	Oxygen (O ₂)	EPS 1/RM/15
	3	Carbon Dioxide (CO ₂)	EPS 1/RM/15
	3	Sulphur Dioxide (SO ₂)	EPS 1/RM/15
	3	Nitrogen Oxides (NO _x as NO ₂)	EPS 1/RM/15
	3	Carbon Monoxide (CO)	EPS 1/RM/15

No stack specific limits are specified in the Approval to Operate.

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

INTRODUCTION

December 16, 2015

1.0 INTRODUCTION

1.1 GENERAL SYNOPSIS

CertainTeed Gypsum Canada Inc. (CertainTeed) retained Stantec Consulting Ltd. (Stantec) to conduct source emissions testing on selected exhaust stacks at its Gypsum Wallboard Plant located in McAdam, New Brunswick. The objective of the source emissions testing was to quantify the emission rates and/or concentrations of contaminants being released from the selected sources, in partial compliance with CertainTeed's Certificate of Approval to Operate (No. I-8150) issued by the New Brunswick Department of Environment and Local Government (NBDELG). The source emissions testing was conducted during the period of October 20-29, 2015.

The report is organized into four sections. A brief introduction to the report, including the scope and objectives of the project, is presented in Section 1.0. The source emissions testing methodology is presented in Section 2.0. The results of the source emissions testing program are presented in Section 3.0, and closing remarks are provided in Section 4.0. Supporting information, field sheets, raw data, calculations, and laboratory data are provided in the Appendices.

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

STUDY METHODOLOGY
December 16, 2015

2.0 STUDY METHODOLOGY

2.1 SCOPE OF WORK AND OVERVIEW OF METHODOLOGY

The source emissions testing requirements are outlined in the Approval to Operate (I-8150), issued to CertainTeed by the New Brunswick Department of Environment and Local Government (NBDELG). The Approval to Operate is provided for reference in Appendix A.

Stantec conducted the source emissions testing campaign at the Gypsum Wallboard Plant from October 20-29, 2015. Source emissions testing was completed under normal operating conditions in order to determine the emission rates and concentrations of specified contaminants, as outlined in Table 2.1.

Table 2.1 Source Emissions Testing Matrix – Gypsum Wallboard Plant, McAdam, NB

Sampling Location	No. of Tests	Sample Type / Pollutant	Sampling Method
Calcine Mill, Rock Dryer, Zone 1 and Zone 2 Dryers (4 sources)	3	Velocity Traverse	EPS 1/RM/8, Method B
	3	Molecular Weight	EPS 1/RM/8, Method C
	3	Moisture Content	EPS 1/RM/8, Method D
	3	Total Suspended Particulate Matter (PM)	EPS 1/RM/8, Method E
	3	Oxygen (O ₂)	EPS 1/RM/15
	3	Carbon Dioxide (CO ₂)	EPS 1/RM/15
	3	Sulphur Dioxide (SO ₂)	EPS 1/RM/15
	3	Nitrogen Oxides (NO _x as NO ₂)	EPS 1/RM/15
	3	Carbon Monoxide (CO)	EPS 1/RM/15

All testing was conducted in accordance with the conditions of the Approval to Operate (I-8150), the NB Air Quality Regulation, and the applicable source emissions testing methods of Environment Canada and the United States Environmental Protection Agency (US EPA). In accordance with the regulatory requirements for source emissions testing, three replicate tests were conducted for each contaminant from each stack. The specific source emissions testing reference methods used to complete the source emissions testing campaign are presented in Table 2.1.

The testing methodology and specific work-task breakdown is described in the following subsections.

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

STUDY METHODOLOGY
December 16, 2015

2.2 TASK 1 – INITIAL PREPARATION

Following award of the contract, Stantec made initial preparations to conduct the source testing work, including equipment calibrations and ensuring the preparation of the sampling locations. The Pre-test Plan describing the source emissions testing program was prepared and submitted to Ms. Sheryl Johnstone of the NBDELG via email for approval on September 30, 2015. Approval of the methods outlined in the Pre-test Plan was obtained on October 1, 2015. The Pre-test Plan and approval are provided in Appendix B of this report.

2.3 TASK 2 – ON-SITE SOURCE EMISSIONS TESTING

Stantec conducted source emissions testing while the process was under normal operation and in accordance with the applicable source testing reference methods. Three repetitions of each test method were completed for each contaminant from each stack, in accordance with the regulatory requirements for compliance testing.

Emission concentrations are reported in milligrams per reference cubic meter (mg/Rm^3) and corrected to reference conditions (25°C and 101.3 kPa), as well as the corresponding mass emission rates in kilograms per hour (kg/hr). Stantec completed the testing in accordance with the applicable source emissions testing reference methods, the conditions of the Approval to Operate, and the NBDELG Guidance Document for Source Emissions Testing.

A brief description of the source emissions testing reference methods followed for the testing campaign is in the following subsections.

2.3.1 Preliminary Testing

Upon arrival at each sampling location, the source emissions testing equipment was set up and a preliminary survey was conducted to measure the average flue gas velocity, moisture content, and flue gas composition in the stack, in accordance with the Environment Canada Reference Method EPS 1/RM/8 Methods B, C, and D, respectively, entitled *Reference Method for Source Testing: Measurement of Releases of Particulate from Stationary Sources*.

The data from the preliminary survey was used to determine the appropriate nozzle size to conduct isokinetic sampling (where the velocity of the gas entering the nozzle is equal to the gas velocity in the stack) during the particulate matter testing, and in calculations for reporting emission rates and concentrations of the sampled contaminants. Verification for cyclonic or reverse flow was also conducted during the preliminary survey, according to procedures outlined in EPS 1/RM/8. Where applicable, flow verification data from previous testing campaigns was used.



Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

STUDY METHODOLOGY
December 16, 2015

2.3.2 Total Particulate Matter

Particulate matter emissions were measured in accordance with the United States Environmental Protection Agency (US EPA) Method 5, entitled *Determination of Particulate Matter Emissions from Stationary Sources*. The sampling train consists of several different components which include: a heated sampling probe (a nozzle, stainless steel liner, thermocouple, and pitot tube assembly), a heated sample case containing a filter, an ice box containing impinger glassware, and an umbilical cord leading to the pump and control console.

The operation of the Method 5 sampling train can be generally described as follows.

Exhaust gases are drawn through the probe nozzle at or near isokinetic conditions (i.e., where the gas velocity in the nozzle is at the same velocity as the gas in the stack). The gases are then drawn through the inner stainless steel liner of the electrically heated sampling probe to the other components of the sampling train.

A pitot tube assembly is attached to the probe next to the nozzle to measure the exhaust gas velocity in the area of the probe nozzle. Using the differential pressure reading on the control console, the desired nozzle flow rate is determined from the differential pressure across a calibrated orifice.

The exhaust gases are drawn from the probe liner through a pre-weighed glass fiber filter, in the hot side of the sampling unit, and then through pre-weighed impingers in an ice bath to cool the gases and condense the moisture in the gas, before the gas enters the umbilical cord.

The umbilical cord carries the filtered, cooled exhaust gases from the sampling site to the control console. The control console contains a fiber vane vacuum pump, which is used to draw the exhaust gases through the sampling train. A calibrated dry gas meter records the volume of gas sampled.


A diagram of the Method 5 particulate matter sampling train is provided in Figure 1.

2.3.3 Combustion Gases

Emissions of combustion gases including oxygen, carbon dioxide, sulphur dioxide, nitrogen oxides and carbon monoxide were determined in accordance with the Environment Canada Reference Method EPS 1/RM/15, entitled *Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Boilers*.

The combustion gases were analyzed using a Testo 350 XL Flue Gas Analyzer manufactured by Testo GmbH and Co. This unit is equipped with electrochemical cells that are used to measure the concentrations of oxygen, carbon dioxide, sulphur dioxide, nitrogen oxides, carbon monoxide, and total hydrocarbons, in accordance with EPS 1/RM/15. The system is equipped with a flue gas probe that has an integrated filter trap and condensate trap and a housing unit that contains the pump and the electrochemical cells.





**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

STUDY METHODOLOGY
December 16, 2015

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

STUDY METHODOLOGY

December 16, 2015

The calibration data for the gas analyzer is in Appendix C.

2.4 TASK 3 – LABORATORY ANALYSIS OF COLLECTED SAMPLES

Total particulate matter is determined gravimetrically at Stantec's laboratory in Fredericton, New Brunswick. The total reported mass of particulate matter is the sum of the solid portions of the probe rinse and the mass captured on the filter. The mass of particulate collected in the impingers is reported separately and not included in the calculation of exhaust gas particulate matter concentration.

2.5 TASK 4 – DATA ANALYSIS AND EMISSION CALCULATIONS

After the source emissions testing work, and the laboratory analysis were completed, Stantec reviewed and analyzed the data and calculated the concentrations and emission rates for combustion gasses and the contaminants described above. Data and calculations were subjected to quality assurance and quality control protocols as per Stantec's quality management process to confirm their accuracy.

2.6 TASK 5 – REPORTING

Finally, the results of the source emissions testing program described above were summarized and described in this report. Emission concentrations are reported in mg/Rm³ corrected to reference conditions (25°C and 101.3 kPa), as well as the corresponding mass emission rates in kg/hr.

2.7 QUALITY ASSURANCE AND QUALITY CONTROL

As a company offering a professional source emissions testing service, Stantec's measuring equipment used in the stack testing procedure are calibrated and traceable to applicable international standards of measurement. Calibrations were conducted to address instrument drift and further confirm measurement accuracy was maintained for all tests. Stantec QA/QC checks are summarized below.

Calibrations include, but are not limited to the following:

Pitot tubes: calibrated in a wind tunnel with probe and nozzles attached.

Gas meters: calibrated using a certified critical orifice calibration set.

Thermocouples: calibrated using a potentiometric technique.

Nozzle: four diameter measurements made using a micrometer across the sharpened edges.

Gas Analyzer: : The analyzer was calibrated against reference gas using standard calibration gases meeting the United States Environmental Protection Agency "Protocol 1" method specifications and within the expected range of concentrations from the source.



Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

STUDY METHODOLOGY

December 16, 2015

Appendix C provides the calibration data for equipment.

Quality control checks were performed at several stages during the testing program to confirm the collection of representative samples and the generation of valid results. These checks were performed by test personnel throughout the program under the guidance of the source testing crew chief. The Quality Control (QC) checks included, but are not limited to the following:

- use of standardized checklists to confirm completeness, traceability, and comparability of the process information and samples collected;
- field review of standardized forms by a second person to confirm accuracy and completeness;
- adherence to sample chain-of-custody procedures;
- use of appropriate field blanks (e.g., filter and solution samples);
- testing for cyclonic or reverse flow, as well as stratified flow conditions; and
- leak checks of sample trains.

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION
December 16, 2015

3.0 RESULTS AND DISCUSSION

A brief description of the stacks tested, and the results of the source emissions testing campaign are provided in the following subsections.

The detailed calculations and source testing raw data are provided in Appendices E and F, respectively. The velocity profiles across the stacks, as shown in Appendix E, were consistent between tests and did not indicate the presence of cyclonic or reverse flow.

3.1 CALCINE MILL

The calcine mill is where dried gypsum from the Rock Dryer is fed for further size reduction, and then calcined into stucco. The mill can be operated on natural gas or No. 2 Fuel oil and is equipped with an exhaust stack that is 0.6 m in diameter. Sampling location details for the Calcine Mill are provided in Appendix D.

The testing was completed while the calcine mill was operating on No. 2 Fuel oil, and the results of the source emissions testing for the Calcine Mill exhaust stack are presented in Table 3.1.

Table 3.1 Source Emissions Testing Results – Calcine Mill, McAdam Gypsum Wallboard Plant

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Test Date	October 22, 2015	October 27, 2015	October 27, 2015	-	-
Test Period	13:20-15:00	10:40-12:35	14:03-15:45	-	-
Test Duration (min)	96	96	96	96	-
Barometric Pressure (kPa)	101.6	103.3	102.9	102.6	-
Stack Gas Static Pressure (kPa)	0.02	0.02	0.02	0.02	-
Volume of Gas Sampled (Rm ³)	3.08	3.07	3.19	3.11	-
Average Isokineticity (%)	95.9	100.6	99.3	98.6	90 ≤ % ≤ 110
Total mass of particulate in Impingers (mg)	5.91	5.79	5.81	5.83	-
Total Mass of Particulate Collected (excluding impinger catch) (mg)	10.1	15.9	18.1	14.7	-

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION

December 16, 2015

**Table 3.1 Source Emissions Testing Results – Calcine Mill,
McAdam Gypsum Wallboard Plant**

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Exhaust Gas Parameter					CoA Limits
Stack Gas Temperature (°C)	145	149	152	149	-
Moisture Content of Stack Gases (%)	17.3	21.0	20.3	19.5	-
Stack Gas Velocity (m/s)	19.99	19.74	20.86	20.20	-
Stack Gas Flow Rate (Rm ³ /s)	7.77	7.37	7.78	7.64	-
Oxygen - O ₂ (%)	17.4	17.5	17.4	17.5	-
Carbon Dioxide - CO ₂ (%)	2.45	2.58	2.66	2.56	-
<u>Sulphur Dioxide - SO₂</u>					
SO ₂ Measured Concentration (ppm)	3.29	2.71	2.57	2.86	-
Concentration (mg/Rm ³)	8.61	7.11	6.74	7.49	-
Emission Rate (kg/hr)	0.24	0.19	0.19	0.21	-
<u>Nitrogen Oxides – NO_x</u>					
NO _x Measured Concentration (ppm)	86.9	81.4	102.3	90.2	-
Concentration (mg/Rm ³)	163	153	193	170	-
Emission Rate (kg/hr)	4.57	4.07	5.39	4.68	-
<u>Carbon Monoxide – CO</u>					
CO Measured Concentration (ppm)	9.71	8.14	9.29	9.05	-
Concentration (mg/Rm ³)	11.1	9.32	10.6	10.4	-
Emission Rate (kg/hr)	0.31	0.25	0.30	0.29	-
<u>Particulate Matter – PM</u>					
Particulate Concentration (mg/Rm ³)	3.29	5.17	5.68	4.72	-
Particulate Emission Rate (kg/hr)	0.09	0.14	0.16	0.13	-
Legend:					
°C	degrees Celsius			kPa	kilopascals
m/s	metres per second			kg/hr	kilograms per hour
ND	not detected				
Rm ³ /s	Reference cubic metres per second (25°C and 101.3 kPa)				
mg/Rm ³	milligrams per reference cubic metre (25°C and 101.3 kPa)				
ppm	parts per million				

The measured particulate matter concentration was 4.72 mg/Rm³. There are no stack specific limits specified in the Approval to Operate for this facility.

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION

December 16, 2015

3.2 ROCK DRYER

The Rock Dryer is a rotary kiln dryer unit used to evaporate excess free moisture from the rock. The Rock Dryer burns No. 2 Fuel oil and is equipped with an exhaust stack that is 0.9 m in diameter.

Sampling location details for the Rock Dryer stack are provided in Appendix D.

The results of the source emissions testing for the Rock Dryer stack are presented in Table 3.2.

Table 3.2 Source Emissions Testing Results – Rock Dryer, McAdam Gypsum Wallboard Plant

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Test Date	October 20, 2015	October 20, 2015	October 21, 2015	-	-
Test Period	10:30-12:15	12:45-14:45	10:30-12:10	-	-
Test Duration (min)	96	96	96	96	-
Barometric Pressure (kPa)	101.2	100.9	102.3	101.5	-
Stack Gas Static Pressure (kPa)	0.05	0.05	0.05	0.05	-
Volume of Gas Sampled (Rm ³)	1.58	1.41	1.54	1.51	-
Average Isokineticity (%)	101	100	98.5	99.9	90 ≤ %I ≤ 110
Total mass of particulate in Impingers (mg)	0.11	1.02	1.47	0.87	-
Total Mass of Particulate Collected (excluding impinger catch) (mg)	1.85	ND	1.20	<1.02	-
Exhaust Gas Parameter					CoA Limits
Stack Gas Temperature (°C)	61.3	61.7	53.8	58.9	-
Moisture Content of Stack Gases (%)	9.7	10.4	7.4	9.2	-
Stack Gas Velocity (m/s)	12.1	11.1	11.5	11.6	-
Stack Gas Flow Rate (Rm ³ /s)	6.42	5.79	6.43	6.21	-
Oxygen - O ₂ (%)	19.7	19.6	19.7	19.7	-
Carbon Dioxide - CO ₂ (%)	0.68	0.86	0.67	0.74	-

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION

December 16, 2015

Table 3.2 Source Emissions Testing Results – Rock Dryer, McAdam Gypsum Wallboard Plant

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
<u>Sulphur Dioxide - SO₂</u>					
SO ₂ Measured Concentration (ppm)	0.71	ND	ND	<0.24	-
Concentration (mg/Rm ³)	1.87	ND	ND	<0.62	-
Emission Rate (kg/hr)	0.04	ND	ND	<0.01	-
<u>Nitrogen Oxides – NO_x</u>					
NO _x Measured Concentration (ppm)	10.0	3.14	7.57	6.90	-
Concentration (mg/Rm ³)	18.8	5.91	14.2	13.0	-
Emission Rate (kg/hr)	0.44	0.12	0.33	0.30	-
<u>Carbon Monoxide – CO</u>					
CO Measured Concentration (ppm)	9.71	13.9	10.3	11.3	-
Concentration (mg/Rm ³)	11.1	15.9	11.8	12.9	-
Emission Rate (kg/hr)	0.26	0.33	0.27	0.29	-
<u>Particulate Matter – PM</u>					
Particulate Concentration (mg/Rm ³)	1.17	ND	0.78	<0.65	-
Particulate Emission Rate (kg/hr)	0.03	ND	0.02	<0.02	-
Legend:					
°C	degrees Celsius			kPa	kilopascals
m/s	metres per second			kg/hr	kilograms per hour
ND	not detected				
Rm ³ /s	Reference cubic metres per second (25°C and 101.3 kPa)				
mg/Rm ³	milligrams per reference cubic metre (25°C and 101.3 kPa)				
ppm	parts per million				

The measured particulate matter concentration was <0.65 mg/Rm³. There are no stack specific limits specified in the Approval to Operate for this facility.

3.3 ZONE 1 AND ZONE 2 DRYERS

The Zone 1 and Zone 2 Dryers operate on natural gas or No. 2 Fuel oil and are equipped with exhaust stacks that are 0.9 m in diameter.

Appendix D provides sampling location details and requirements for the Zone 1 and Zone 2 dryer stacks.

The testing was completed while the Zone 1 Dryer was operating on No. 2 Fuel oil, and the results of the source emissions testing for the Zone 1 Dryer stack are presented in Table 3.3.



**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

RESULTS AND DISCUSSION

December 16, 2015

**Table 3.3 Source Emissions Testing Results – Zone 1 Dryer,
McAdam Gypsum Wallboard Plant**

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Test Date	October 28, 2015	October 29, 2015	October 29, 2015	-	-
Test Period	13:52-15:30	9:55-11:45	13:20-15:00	-	-
Test Duration (min)	96	96	96	96	-
Barometric Pressure (kPa)	101.6	101.5	101.2	101.5	-
Stack Gas Static Pressure (kPa)	0.05	0.05	0.05	0.05	-
Volume of Gas Sampled (Rm ³)	2.00	1.43	1.23	1.55	-
Average Isokineticity (%)	119	104	101	107	90 ≤ %I ≤ 110
Total mass of particulate in Impingers (mg)	44.5	49.6	42.7	45.6	-
Total Mass of Particulate Collected (excluding impinger catch) (mg)	19.7	21.1	12.3	17.7	-
Exhaust Gas Parameter					CoA Limits
Stack Gas Temperature (°C)	144	147	143	144	-
Moisture Content of Stack Gases (%)	31.7	40.8	42.0	38.2	-
Stack Gas Velocity (m/s)	12.6	12.1	10.8	11.8	-
Stack Gas Flow Rate (Rm ³ /s)	7.23	5.94	5.24	6.14	-
Oxygen - O ₂ (%)	14.5	14.7	14.6	14.6	-
Carbon Dioxide - CO ₂ (%)	4.81	4.71	4.74	4.76	-
<u>Sulphur Dioxide - SO₂</u>					
SO ₂ Measured Concentration (ppm)	ND	ND	ND	ND	-
Concentration (mg/Rm ³)	ND	ND	ND	ND	-
Emission Rate (kg/hr)	ND	ND	ND	ND	-
<u>Nitrogen Oxides – NOx</u>					
NOx Measured Concentration (ppm)	140	133	144	139	-
Concentration (mg/Rm ³)	264	250	271	262	-
Emission Rate (kg/hr)	6.86	5.35	5.11	5.77	-
<u>Carbon Monoxide – CO</u>					
CO Measured Concentration (ppm)	14.4	13.9	14.3	14.2	-
Concentration (mg/Rm ³)	16.5	15.9	16.4	16.2	-
Emission Rate (kg/hr)	0.43	0.34	0.31	0.36	-

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION

December 16, 2015

**Table 3.3 Source Emissions Testing Results – Zone 1 Dryer,
McAdam Gypsum Wallboard Plant**

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Particulate Matter – PM					
Particulate Concentration (mg/Rm ³)	9.85	14.7	10.0	11.5	-
Particulate Emission Rate (kg/hr)	0.26	0.31	0.19	0.25	-
Legend:					
°C	degrees Celsius			kPa	kilopascals
m/s	metres per second			kg/hr	kilograms per hour
ND	not detected				
Rm ³ /s	Reference cubic metres per second (25°C and 101.3 kPa)				
mg/Rm ³	milligrams per reference cubic metre (25°C and 101.3 kPa)				
ppm	parts per million				

The measured particulate matter concentration was 11.5 mg/Rm³. There are no stack specific limits specified in the Approval to Operate for this facility. It should be noted that the average isokinetics for test 1 were 119%, which is outside the allowable range (90-110%). This was due to the moisture content being underestimated for the first test, but was corrected for the subsequent testing. Higher isokinetics can potentially result in the measurement being biased low for concentration. However, the three tests are consistent (within 10% of average) therefore the tests are considered representative of the source emissions.

The testing was completed while the Zone 2 Dryer was operating on No. 2 Fuel oil, and the results of the source emissions testing for the Zone 2 Dryer stack are presented in Table 3.4.

**Table 3.4 Source Emissions Testing Results – Zone 2 Dryer,
McAdam Gypsum Wallboard Plant**

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Test Date	October 28, 2015	October 29, 2015	October 29, 2015	-	-
Test Period	14:45-14:30	11:05-12:45	14:15-16:00	-	-
Test Duration (min)	96	96	96	96	-
Barometric Pressure (kPa)	101.6	101.5	101.2	101.5	-
Stack Gas Static Pressure (kPa)	0.05	0.05	0.05	0.05	-
Volume of Gas Sampled (Rm ³)	1.92	1.91	1.88	1.9	-
Average Isokineticity (%)	104	104	98.5	102	90 ≤ %I ≤ 110
Total mass of particulate in Impingers (mg)	72.4	46.9	38.1	52.5	-
Total Mass of Particulate Collected (excluding impinger catch) (mg)	18.7	36.0	17.8	24.2	-

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

RESULTS AND DISCUSSION

December 16, 2015

**Table 3.4 Source Emissions Testing Results – Zone 2 Dryer,
McAdam Gypsum Wallboard Plant**

Parameter	Test 1	Test 2	Test 3	Average	Quality Criteria
Exhaust Gas Parameter					CoA Limits
Stack Gas Temperature (°C)	116	117	117	117	-
Moisture Content of Stack Gases (%)	39.0	39.3	39.3	39.2	-
Stack Gas Velocity (m/s)	14.4	14.4	15.1	14.6	-
Stack Gas Flow Rate (Rm ³ /s)	7.90	7.83	8.16	7.96	-
Oxygen - O ₂ (%)	16.8	16.7	16.8	16.8	-
Carbon Dioxide - CO ₂ (%)	16.8	16.7	16.8	16.8	-
<u>Sulphur Dioxide - SO₂</u>					
SO ₂ Measured Concentration (ppm)	0.71	0.86	0.30	0.62	-
Concentration (mg/Rm ³)	1.87	2.25	0.79	1.63	-
Emission Rate (kg/hr)	0.05	0.06	0.02	0.05	-
<u>Nitrogen Oxides – NOx</u>					
NOx Measured Concentration (ppm)	83.1	72.4	78.7	78.1	-
Concentration (mg/Rm ³)	156	136	148	147	-
Emission Rate (kg/hr)	4.45	3.84	4.35	4.22	-
<u>Carbon Monoxide – CO</u>					
CO Measured Concentration (ppm)	11.7	10.3	10.4	10.8	-
Concentration (mg/Rm ³)	13.4	11.8	11.9	12.4	-
Emission Rate (kg/hr)	0.38	0.33	0.35	0.35	-
<u>Particulate Matter – PM</u>					
Particulate Concentration (mg/Rm ³)	9.76	18.9	9.46	12.7	-
Particulate Emission Rate (kg/hr)	0.28	0.53	0.28	0.36	-
Legend:					
°C	degrees Celsius			kPa	kilopascals
m/s	metres per second			kg/hr	kilograms per hour
ND	not detected				
Rm ³ /s	Reference cubic metres per second (25°C and 101.3 kPa)				
mg/Rm ³	milligrams per reference cubic metre (25°C and 101.3 kPa)				
ppm	parts per million				

The measured particulate matter concentration was 12.7 mg/Rm³. There are no stack specific limits specified in the Approval to Operate for this facility.

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

CLOSING REMARKS
December 16, 2015

4.0 CLOSING REMARKS

This report has been prepared by Stantec Consulting Ltd. (Stantec) for the sole benefit of CertainTeed Gypsum Canada Inc. The report may not be relied upon by any other person or entity, other than for its intended purposes, without the express written consent of Stantec and CertainTeed Gypsum Canada Inc.. This report was undertaken exclusively for the purpose outlined herein and was limited to the scope and purpose specifically expressed in this report. This report cannot be used or applied under any circumstances to another location or situation or for any other purpose without further evaluation of the data and related limitations. Any use of this report by a third party, or any reliance on decisions made based upon it, are the responsibility of such third parties. Stantec accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions taken based on this report.

Stantec makes no representation or warranty with respect to this report, other than the work was undertaken by trained professional and technical staff in accordance with generally accepted engineering and scientific practices current at the time the work was performed. Any information or facts provided by others and used in the preparation of this report were assumed by Stantec to be accurate. Conclusions presented in this report should not be construed as legal advice.

The source testing measurements for each stack were taken over short periods of time and the emissions results are considered representative for the conditions present at the time of testing. The information provided in this report was compiled from such on-site measurements and by applying currently accepted industry standard mitigation and prevention principles. This report represents the best professional judgment of Stantec personnel at the time of its preparation. Stantec reserves the right to modify the contents of this report, in whole or in part, to reflect the any new information that becomes available. If any conditions become apparent that differ significantly from our understanding of conditions as presented in this report, we request that we be notified immediately to reassess the conclusions provided herein.

This report has been prepared by Tristan Blair-Hicks, EIT, and reviewed by Vicki Corning, P.Eng. on behalf of CertainTeed Gypsum Canada Inc. If you have any questions or concerns about this report, please do not hesitate to contact the undersigned.

STANTEC CONSULTING LTD.


Tristan Blair-Hicks, EIT
Air Quality Engineer-in-Training
Environmental Services
(506) 452-7000




Vicki Corning, P.Eng.
Senior Associate
Environmental Services
(506) 452-7000

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX A

Approval to Operate

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015



APPROVAL TO OPERATE

I-8150

Pursuant to paragraph 5 (3) (a) of the *Air Quality Regulation - Clean Air Act*, this Approval to Operate is hereby issued to:

CERTAINTEED GYPSUM CANADA, INC.

for the operation of the

McAdam Gypsum Wallboard Plant

Description of Source:

Gypsum Rock Stockpile, Primary Crusher, Rock Dryer, Calcine Mill, Wallboard Fabrication Line

Source Classification:

Air Quality Regulation

Class 1B

Parcel Identifier:

01534668

Mailing Address:

57 Quality Way

McAdam, NB E6J 1B1

Conditions of Approval:

See attached Schedule "A" of this Approval

Supersedes Approval:

I-6085

Valid From:

April 01, 2013

Valid To:

March 31, 2018

Recommended by: _____

Community Planning & Environmental Protection Division

Issued by: _____

Minister of Environment and Local Government

Date

SCHEDULE "A"

A. DESCRIPTION AND LOCATION OF SOURCE

CertainTeed Gypsum Canada, Inc. operates a Gypsum Wallboard Plant that has an annual production capacity of 23 million square metres of Gypsum Wallboard. The plant is located in the Village of McAdam, New Brunswick.

There exists *potential* environmental impacts to the atmospheric environment from: i) upset operating conditions; ii) the release of particulate matter from fuel oil combustion, crushing and drying processes; iii) the release of sulphur dioxide, nitrogen oxides, and carbon monoxide from fuel oil combustion processes; iv) the release of fugitive particulate matter emissions from the on-site stock piles, materials handling, crushing and site access roads; and v) the release of noise from the general operation of the facility.

The operation of the CertainTeed Gypsum Wallboard Plant in the Village of McAdam, County of York, and Province of New Brunswick, and identified by Parcel Identifier (PID) 01534668 is hereby approved subject to the following:

B. DEFINITIONS

1. **"Approval Holder"** means CertainTeed Gypsum Canada, Inc.

2. **"Minister"** means the Minister of the Department of Environment & Local Government and includes any person designated to act on the Minister's behalf.

3. **"Department"** means the New Brunswick Department of Environment & Local Government.
4. **"Director"** means the Director of the Impact Management Branch of the Department of Environment & Local Government and includes any person designated to act on the Director's behalf.
5. **"Inspector"** means an Inspector designated under the *Clean Air Act*, the *Clean Environment Act*, or the *Clean Water Act*.
6. **"environmental emergency"** means a situation where there has been or will be a release, discharge, or deposit of a contaminant or contaminants to the atmosphere, soil, surface water, and/or groundwater environments of such a magnitude or duration that it could cause significant harm to the environment or put the health of the public at risk.
7. **"normal business hours"** means the hours when the Department's offices are open. These include the period between 8:15 a.m. and 4:30 p.m. from Monday to Friday excluding statutory holidays.
8. **"after hours"** means the hours when the Department's offices are closed. These include statutory holidays, weekends, and the hours before 8:15 a.m. and after 4:30 p.m. from Monday to Friday.
9. **"statutory holiday"**, for the purpose of this approval, means the following days: New Year's Day, Good Friday, Easter Monday, Victoria Day, Canada Day, New Brunswick Day, Labour Day, Thanksgiving Day, Remembrance Day, Christmas Day and Boxing Day. If the statutory holiday falls on a Sunday, then the following day shall be considered to be the statutory holiday.
10. **"Facility"** means the property, buildings, equipment, and all contiguous property in the title of the Approval Holder at that location, including but not limited to:

- A. GYPSUM STOCKPILE - is the area where the Gypsum Rock, which is the plant feed rock, is stored prior to transportation to the Primary Crusher. In 2012 two tarpaulin fabric covered, steel spanned dome buildings were constructed to improve storage conditions. Each dome building currently has two walls, with the other two open to the environment. The stockpile is considered a potential source of fugitive particulate matter.
- B. PRIMARY CRUSHER - is used to crush the feed rock to a reduced size less than 3.8 cm (4.5 in) in diameter. The primary crusher is considered a potential source of fugitive particulate matter.
- C. ROCK DRYER - is a rotary kiln dryer unit used to evaporate excess free moisture from the rock. The kiln utilises No. 6 Fuel Oil as the fuel source and is equipped with an exhaust stack that is 0.9 m (3.95 ft) in diameter and 7 m (22.9 ft) above adjacent ground level. The dryer exhaust stack is considered a release point for process gas and a point source of particulate matter (PM), sulphur dioxide (SO_2), nitrogen oxides (NO_x), and carbon monoxide (CO) emissions to the atmospheric environment.
- D. CALCINE MILL - is where dried gypsum from the Rock Dryer is fed for further size reduction to 94.2% passing 100-mesh screens, and then calcined to stucco in the Calcine Mill . The mill utilises No. 6 Fuel Oil and is equipped with an exhaust stack that is 0.6 m (1.97 ft) in diameter and 6.5 m (21.3 ft) above adjacent ground level. The mill exhaust stack is considered a release point for process gas and a point source of particulate matter (PM), sulphur dioxide (SO_2), nitrogen oxides (NO_x), and carbon monoxide (CO) emissions to the atmospheric environment.

- E. WALLBOARD FABRICATION LINE - is situated after the stucco production in the Calcine Mill. All the dry and liquid ingredients are added, mixed, and placed between sheets of paper; the wallboard is extruded to the desired form and set before it is fed into a drying oven. The drying oven has ten levels and two zones. The initial zone operates at 245 to 288°C (473 to 550°F), while the second zone operates at 191°C (375°F). The initial zone drives off most of the moisture while the second zone permits continued drying. The board emerges from the ovens at about 0.5 % free moisture. The dryer utilises No. 2 Fuel Oil as the fuel source and is equipped with two exhaust stacks, one for each zone, that are 0.9 m (3.95 ft) in diameter and 6.7 m (21.9 ft) above adjacent ground level. The dryer exhaust stacks are considered a release point for process gas and are point sources of particulate matter (PM), sulphur dioxide (SO₂), nitrogen oxides (NO_x), and carbon monoxide (CO) emissions to the atmospheric environment.
- F. WASTE WALLBOARD STOCKPILE AREA - is located at the west end of the property and serves as storage for the waste wallboard generated from the operation. The current process allows 35% recycled material. The waste stockpile has decreased in size significantly and future plans include managing the recycle wallboard by the rock shelter. This area is currently considered a potential source of fugitive particulate matter.

C. EMERGENCY REPORTING

11. Initial Notification

Immediately following the discovery of an environmental emergency a designate representing the Approval Holder shall notify the Department in the following manner:

During normal business hours, telephone the Department's Fredericton Regional Office **until personal contact is made** (i.e. no voice mail messages will be accepted) and provide as much information that is known about the environmental emergency. The telephone number for the Fredericton Regional Office is provided below:

Fredericton Regional Office (506) 444-5149

After hours, telephone the Canadian Coast Guard **until personal contact is made** and provide as much information that is known about the environmental emergency. The telephone number for the **Canadian Coast Guard** is **1-800-565-1633**.

12. Follow-Up

Within 24-hours of the time of initial notification, a faxed copy of a **Preliminary Emergency Report** shall be filed by a designate representing the Approval Holder to the Department's Fredericton Regional Office and to the Department's Central Office using the fax numbers provided below. The Preliminary Emergency Report shall clearly communicate as much information that is available at the time about the environmental emergency.

Within five (5) days of the time of initial notification, a faxed copy of a **Detailed Emergency Report** shall be filed by a designate representing the Approval Holder to the Department's Fredericton Regional Office and to the Department's Central Office using the fax numbers provided below:

Fredericton Regional Office (fax): (506) 453-2893

Central Office (fax): (506) 457-7805

The **Detailed Emergency Report** shall include, as minimum, the following:

- i) a description of the problem that occurred;
- ii) a description of the impact that occurred;
- iii) a description of what was done to minimize the impact; and
- iv) a description of what was done to prevent recurrence of the problem.

D. TERMS AND CONDITIONS

GENERAL CONDITIONS

13. The Approval Holder shall operate the Facility in compliance with the *Air Quality Regulation 97-133* filed under the *Clean Air Act* of the Province of New Brunswick. Violation of any term and condition herein stated constitutes a violation of the *Clean Air Act*.
14. This Facility has been classified as a **Class 1B** source, pursuant to the *Air Quality Regulation 97-133* filed under the *Clean Air Act*. The Approval Holder shall pay the appropriate annual fee within 30 days of receiving an invoice.
15. The terms and conditions of this Approval are severable. If any term or condition of this Approval is held invalid, is revoked or is modified, the remainder of the Approval shall not be affected.
16. **Prior to June 30, 2017**, The Approval Holder shall make application in writing on a form provided by the Minister for a renewal of this Approval.
17. The Approval Holder shall notify the Minister in writing of any plans to modify the operation of the Facility that would result in a significant change in the characteristics or increased rate of discharge or concentration of any pollutants to the environment **at least two hundred and seventy (270) days prior** to the modification.
18. In the event of facility closure, the Approval Holder shall notify the Minister in writing **at least two hundred and seventy (270) days prior** to the anticipated closure date.

19. If, in the opinion of the Minister, the environmental impact of the work described in this Approval is unacceptable, the Minister reserves the right to cancel this Approval and issue a new Approval with terms and conditions as deemed necessary.
20. The issuance of this Approval does not relieve the Approval Holder from compliance with other by-laws, federal or provincial acts or regulations, or any guidelines issued pursuant to regulations.
21. The Approval Holder shall ensure that a copy of this Approval to Operate is posted in a prominent location in the main office or working area of the Facility.

FUGITIVE PARTICULATE MATTER CONTROL

22. The Approval Holder shall ensure that fugitive particulate matter emissions being emitted from the Facility do not cause adverse impacts to any off-site receptor. In the event fugitive particulate matter emission impacts are suspected by the Department to be adversely impacting any off-site receptor, the Approval Holder will be required to develop, submit, and implement a Fugitive Particulate Matter Prevention and Control Plan in accordance with a timetable established by the Department. The plan shall be submitted in writing to the Department for review and approval prior to implementation.

NOISE CONTROL

23. The Approval Holder shall ensure that noise being emitted from the Facility does not adversely impact any off-site receptors. In the event noise impacts are suspected by the Department to adversely impact the environment, the Approval Holder will be required to develop, submit, and implement a Noise Prevention and Control Plan in accordance with a timetable established by the Department. The plan shall be submitted in writing to the Department for review and approval prior to implementation.

EMISSION LIMITS

24. The Approval Holder shall ensure that the total combined release of Sulphur Dioxide (SO₂) from all sources at the Facility does not exceed 200 tonnes per calendar year.
25. The Approval Holder shall ensure that the total combined release of Particulate Matter (PM) from all sources at the Facility does not exceed 200 tonnes per calendar year.

TESTING AND MONITORING

26. The Approval Holder shall conduct performance tests on emissions or ambient air quality at such times and in such manner as the Minister may specify in writing.
27. **Prior to December 01, 2015**, the Approval Holder shall conduct source testing to determine the concentration in milligrams per cubic metre (mg/m³) and the emission rate in kilograms per hour (kg/hr) of Sulphur Dioxide (SO₂), Carbon Monoxide (CO), Nitrogen Oxides (NO_x), and Particulate Matter (PM) being released from the exhaust stacks of the Rock Dryer, Calcine Mill, and the two Dryer Ovens representing normal operating conditions.
28. The Approval Holder shall ensure that source testing is carried out in accordance with Section 18 of the New Brunswick *Air Quality Regulation 97-133*, and with the requirements embodied in the Department's *Code of Practice for Source Testing* or latest revision, as well as using normal accepted practice as published by the Canadian Environmental Protection Service (EPS) or the United States Environmental Protection Agency (US EPA). A detailed description of the methods to be used shall be submitted to the Director for review at least four (4) weeks prior to commencement of source testing.

REPORTING

29. In the event of a small spill or leak of liquid materials, the Approval Holder shall act first to contain, and then to clean up the spilled or leaked material and mitigate any resulting impacts as soon as the spill or leak is detected. If the spill or leak results in an "environmental emergency" as defined in this Approval, the Approval Holder shall report the event in accordance with the Emergency Reporting section of this Approval. If the spill or leak is not an "environmental emergency", the Approval Holder shall follow the approved Accidental Spill Procedure for recording and reporting a small spill.
30. In the event the Approval Holder violates any Term and Condition of this Approval, the *Air Quality Regulation* or the *Water Quality Regulation*, the Approval Holder is to immediately report this violation by facsimile to the Department's applicable Regional Office and the Central Office in Fredericton at **(506) 457-7805**. In the event the violation may cause the health or safety of the general public to be at risk and/or significant harm to the environment could or has resulted, the Approval Holder shall follow the Emergency Reporting procedures contained in this Approval.
31. In the event the Approval Holder receives a complaint from the public regarding unfavourable environmental impacts associated with the Facility, the Approval Holder is to report this complaint by facsimile to the Department's applicable Regional Office within one business day of receiving the complaint.
32. **By January 31 of each year**, the Approval Holder shall submit to the Department an **Annual Environmental Report** which includes as a minimum the following:
 - a) the annual amount and type of fuel oil used at the Facility in litres for the previous year;
 - b) the sulphur content of the fuels used in a);
 - c) a calculation of the total sulphur dioxide being emitted from the Facility in tonnes per year, based on the fuel consumption and sulphur content provided in a) and b);

- d) a summary of any reportable upset conditions and/or spills that occurred during the previous year.
33. **Prior to February 10, 2016**, the Approval Holder shall submit a report pertaining on source testing activities in accordance with Condition 27. Reporting shall be in accordance with the Department's *Code of Practice for Source Testing*, or latest revision.

Prepared by: _____

Sheryl Johnstone, P.Eng.

Industrial Approvals Engineer, Industrial Processes

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX B

PTP and Approval Email



**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015



Stantec Consulting Ltd.
845 Prospect Street, Fredericton NB E3B 2T7

File No.: 121811606
September 30, 2015

Attention: Ms. Sheryl Johnstone, P.Eng.

New Brunswick Department of the Environment & Local Government
PO Box 6000, 20 McGloin Street, Marysville Place
Fredericton, NB E3B 5H1

**RE: PRE-TEST PLAN FOR CERTAINTeed GYPSUM CANADA INC. MCADAM GYPSUM WALLBOARD PLANT
MCADAM, NB (COA NO. I-8150)**

Dear Ms. Johnstone:

Please accept this Pre-Test Plan submitted on behalf of CertainTeed Gypsum Canada Inc. for the source testing of emissions from the exhaust stacks of their gypsum wallboard plant located in McAdam, New Brunswick.

INTRODUCTION

Stantec Limited has been retained by CertainTeed Gypsum Canada Inc. (CertainTeed) to conduct source emissions testing at the exhaust stacks of its gypsum wallboard plant in McAdam, New Brunswick, as required under the Certificate of Approval to Operate (# I-8150) issued to CertainTeed by the New Brunswick Department of the Environment and Local Government (NBDELG) under the Air Quality Regulation. The source emissions testing campaign will be performed according to conditions stipulated in the Certificate of Approval to Operate, Part III of the Air Quality Regulation 97-133 and the NBDELG Guidance Document for Source Testing.

The testing will be performed to determine the concentrations and emissions rates of the following parameters from the calcine mill stack, the rock mill stack, and the Zone 1 and Zone 2 dryer stacks:

- particulate matter (PM);
- carbon monoxide (CO);
- nitrogen oxides (NO_x);
- sulphur dioxide (SO₂);
- oxygen (O₂); and
- carbon dioxide (CO₂).

TEST PROGRAM ORGANIZATION

The source emissions testing program will be performed for:

Company Name:	CertainTeed Gypsum Canada Inc.
Company Address:	57 Quality Way, McAdam, NB, E6J 1B1
Plant Location:	McAdam, NB
Contact Name:	Ms. Agata Sulkiewicz
Position:	Quality and Environmental Manager
Telephone Number:	(506) 784-1224
Fax Number:	(506) 784-3204



September 30, 2015

Ms. Sheryl Johnstone, P.Eng.

Page 2 of 9

**RE: PRE-TEST PLAN FOR CERTAINTEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

The source emissions testing program will be performed by:

Sampling Company: Stantec Consulting Ltd.
Project Co-ordinator: Tristan Blair-Hicks, EIT.
Telephone No.: (506) 457-3217
Fax No.: (506) 452-0112
Email: tblairhicks@stantec.com
Sampling Team: See "qualifications of source testing team"

Source Description

The source emissions testing will be conducted on the exhaust stacks of the calcine mill, the rock dryer, and the Zone 1 and Zone 2 Dryers. The following is a brief description of the plant and the sources.

- **Gypsum Plant:** The facility is a gypsum wallboard plant with a production capacity of 23 million square metres of gypsum wallboard. The plant transforms gypsum rock to wallboard in a process of grinding and drying the rock, calcination, extruding and forming into boards and then drying.
- **Calcine Mill Stack:** The calcine mill burner burns natural gas or No. 2 fuel oil and hot combustion gases from the process are exhausted through a circular, vertical stack that measured 0.9 metres in diameter and is equipped with 2 sample ports.
- **Rock Dryer Stack:** The rock dryer burns No. 2 Fuel oil and hot combustion gases from the process are exhausted through a circular, vertical stack that measures 0.9 metres in diameter and is equipped with 2 sample ports.
- **Zone 1 and Zone 2 Dryer Stacks:** The Zone 1 and Zone 2 dryers burn natural gas or No. 2 fuel oil and hot combustion gases from the process are exhausted through circular, vertical stacks that measure 1.22 metres in diameter and are equipped with 2 sample ports.

Source Emissions Testing Program

Source emissions testing will be completed for CertainTeed to determine the concentrations and emission rates of particulate matter and combustion gases from the exhaust stack of the calcine mill stack, the rock mill stack, and the Zone 1 and Zone 2 dryer stacks. Emissions testing will be conducted while the facility is operated under normal conditions.

A brief description of each of the source emissions testing reference methods is provided below. Three (3) tests will be conducted for each contaminant in accordance with the applicable source emissions testing reference methods, Part III of the New Brunswick Air Quality Regulation 97-133 under the Clean Air Act, and the NBDELG Guidance Document for Source Testing.



September 30, 2015
Ms. Sheryl Johnstone, P.Eng.
Page 3 of 9

**RE: PRE-TEST PLAN FOR CERTAINEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

Table 1 Source Emissions Testing Matrix – Certainteed Gypsum

Source	Contaminant	No. of Tests	Sampling Protocol
Calcine mill stack, rock mill stack, zone 1 and zone 2 dryer stacks (4 Sources)	Velocity Traverse/Flowrate	3	EPS 1/RM/8, Method B
	Molecular Weight	3	EPS 1/RM/8, Method C
	Moisture Content	3	EPS 1/RM/8, Method D
	Total Particulate Matter (PM)	3	EPS 1/RM/8, Methods B to E
	Oxygen (O ₂)	3	EPS 1/RM/15
	Carbon Dioxide (CO ₂)	3	EPS 1/RM/15
	Sulphur Dioxide (SO ₂)	3	EPS 1/RM/15
	Nitrogen Oxides (NO _x)	3	EPS 1/RM/15
	Carbon Monoxide (CO)	3	EPS 1/RM/15

Preliminary Survey and Sample Location Details

Upon arrival at the stack sampling location, Stantec will set up the source testing equipment and conduct a preliminary survey to measure the average velocity, moisture content, and flue gas composition in the stack. The data from this survey will be used to determine the appropriate nozzle size to conduct isokinetic sampling (where the velocity of the gas entering the nozzle is equal to the gas velocity in the stack) for particulate matter during the testing.

Verification for cyclonic or reverse flow will also be conducted during the preliminary survey, according to procedures outlined in the Environment Canada reference method EPS 1/RM/8. In the event that cyclonic, reverse flow, or the fluctuations in the velocity pressure at any traverse point exceed 20% of the average pressure for that point, the NBDELG will be consulted on whether deviations from the standard methods are warranted to complete the testing campaign. If reverse flow conditions are present as determined during the preliminary survey, Stantec proposes that sampling be conducted only at points having positive flow conditions, with sampling time per point adjusted accordingly.

The number and location of sample points along each traverse will be determined according to EPS 1/RM/8, Method A, using the exhaust stack dimensions. The sample location details are summarized in Table 2. These sampling locations will be confirmed upon arrival at the site, and included in the final report.

Table 2 Sample Location Details - Certainteed Gypsum

Parameter	Calcine Mill	Rock Mill	Zone 1 Dryer	Zone 2 Dryer
Stack Height - Above Grade (m)	21	21	6.7	6.7
Stack/Duct Description	circular, vertical	circular, vertical	circular, vertical	circular, vertical
Diameter (m)	0.9	0.9	1.22	1.22
Number of Ports	2	2	2	2
Sample Port Configuration	2 @ 90°	2 @ 90°	2 @ 90°	2 @ 90°
Sample Port Diameters (m)	0.1	0.1	0.1	0.1



September 30, 2015
Ms. Sheryl Johnstone, P.Eng.
Page 4 of 9

**RE: PRE-TEST PLAN FOR CERTAINTEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

Table 2 Sample Location Details - Certainteed Gypsum

Parameter	Calcine Mill	Rock Mill	Zone 1 Dryer	Zone 2 Dryer
Location Upstream from any Disturbance, Dimension A from Figure 2 (Number of Stack Diameters)	<2	<2	<2	<2
Location Downstream from any Disturbance, Dimension B from Figure 2 (Number of Stack Diameters)	<8	<8	<8	<8
Ideal or Non Ideal ¹	non-ideal ¹	non-ideal ¹	non-ideal ¹	non-ideal ¹
Total Number of Sample Points	24	24	24	24
Number of Sample Points per Traverse for PM	12	12	12	12
Sample Time per Point for PM (min)	4	4	4	4
Total Sample Time per Test for PM (min)	96 min	96 min	96 min	96 min
Total Sample Time for Combustion Gases	30 min	30 min	30 min	30 min
Notes:	¹ The exhaust gas flow characteristics at the sampling location are referred to as being "Ideal" if the sample ports are located in a straight section of stack at least 8 stack diameters downstream and two stack diameters upstream of any flow disturbance.			


Source Emissions Testing


Source emissions testing on the plant exhaust stack will be conducted with the plant operating at a consistent load in accordance with the source testing reference method EPS 1/RM/8 for particulate matter. Combustion gas emissions will be measured in accordance with the Environment Canada reference method EPS 1/RM/15. Three repetitions of each test method will be completed for each of the sources to be tested, in accordance with the regulatory requirements for compliance source emissions testing.

Particulate Matter Testing

The source emissions testing for total suspended particulate matter will be conducted in accordance with the Environment Canada reference method EPS 1/RM/8, entitled "Measurement of Releases of Particulate from Stationary Sources".

The particulate sampling train, used specifically for isokinetic sampling, is described in detail in EPS 1/RM/8, and is generally referred to as the "Method 5" sampling train for particulate matter (after the US EPA protocol). The sampling train has several different components which include: a heated sampling probe (a nozzle, stainless steel liner, thermocouple, and pitot tube assembly), a heated sample case containing a filter, an ice box containing impinger glassware, and an umbilical cord leading to the pump, and control console. The operation and accuracy of the dry gas meter will be checked before and after the testing is completed. A schematic of the sampling system is shown Figure 1. Figure 2 shows the sampling point locations for isokinetic sampling.







September 30, 2015
Ms. Sheryl Johnstone, P.Eng.
Page 7 of 9

**RE: PRE-TEST PLAN FOR CERTAINTEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

Theoretically, particulate matter greater than 0.3 µm in diameter will be captured in the front half of the sampling train and on the filter. Any particulate matter or vapour mist less than 0.3 µm in diameter will pass through the filter and be deposited in the impingers (i.e., the back half of the train). The amount of material caught in the impingers will be determined gravimetrically and reported separately from the calculated total particulate matter emissions. All particulate matter samples will be recovered and analyzed at our laboratory in Fredericton, New Brunswick.

Three replicate tests will be conducted for each source for particulate matter, in accordance with the requirements of the Air Quality Regulation.

Combustion Gases (oxygen, carbon dioxide, sulphur dioxide, nitrogen oxides, and carbon monoxide)

The combustion gases will be sampled according to the Environment Canada reference method EPS 1/RM/15, entitled "Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Boilers". In this method, samples of flue gas are drawn through a probe, non-isokinetically, from a single point near the centre of the stack. A Testo 350 XL Flue Gas Analyzer, manufactured by Testo GmbH and Co., will be used to conduct the sampling. The Testo 350 XL Flue Gas Analyzer is manufactured and calibrated to ensure high accuracy. Calibration data will be included with the final report.

REPORTING

Actual emissions will be reported in mg/m³ and kg/hr at reference conditions of 25 °C and 101.3 kPa. The concentrations will be corrected to appropriate conditions for comparison with the limits documented in the Approval to Operate No. I-8150.

Results of the source emissions testing will be documented in the final report for submission to NBDELG for review and approval.

QUALITY ASSURANCE AND QUALITY CONTROL

Throughout the stack testing program, quality assurance and quality control procedures will be applied to ensure the collection of reliable, representative, and reproducible emissions data. All equipment will be calibrated according to the protocols and schedule as prescribed by the New Brunswick Department of Environment (NBDELG), Environment Canada, and the US EPA. These calibrations include, but are not limited to the following:

- **Pitots:** calibrated in a wind tunnel with probe and nozzles attached.
- **Gas Meters:** calibrated using a standard set of critical orifices.
- **Thermocouples:** calibrated using a potentiometric technique.
- **Nozzle:** four diameter measurements made using a micrometer across sharpened edges.
- **Gas Analyzers:** The analyzers are calibrated using standard calibration gases meeting the USEPA "Protocol 1" method specifications.

Calibration data for all equipment will be provided in the final report.

Quality control checks will be performed at several stages during the testing program to ensure the collection of representative samples and the generation of valid results. These checks are performed



September 30, 2015

Ms. Sheryl Johnstone, P.Eng.

Page 8 of 9

**RE: PRE-TEST PLAN FOR CERTAINTEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

by test personnel throughout the program under the guidance of the source testing crew chief. The Quality Control (QC) checks include, but are not limited to the following:

- use of standardized checklists and field notebooks to confirm completeness, traceability, and comparability of the process information and samples collected;
- field checking of standardized forms by a second person to confirm accuracy and completeness;
- adherence to sample chain-of-custody procedures;
- use of appropriate field blanks (e.g., filter and solution samples); and
- leak checks of sample trains.

QUALIFICATIONS OF SOURCE TESTING TEAM

The successful completion of the project requires the skills of competent and experienced professionals who have a strong commitment to finish the project quickly and efficiently. The source testing team we have assembled to meet the challenges of this assignment consists of highly trained professionals who bring a broad range of expertise and experience to the project. The following paragraphs provide brief descriptions of the qualifications of the source emissions testing team.

Project Management

Mr. Tristan Blair-Hicks, EIT, has a degree in mechanical engineering and joined the Stantec air quality team in the summer of 2011. He has led a number of emissions testing campaigns including for particulate matter, particle size distribution, volatile organics and combustion gases. Tristan has experience testing boilers, asphalt plants and refinery process units. Tristan will coordinate the project, and will also aid in conducting on-site testing work, data analysis and reporting, as required.

Senior Review

Ms. Vicki Corning, P.Eng., will be the quality reviewer for the emissions testing campaign. Ms. Corning has a degree in chemical engineering and 10 years of technical and management expertise in many environmental services including: source emissions testing (particulate matter, gases, volatile organic compounds, chlorine compounds, reduced sulphur compounds, metals, dioxins and furans, relative accuracy test audits) regulatory activities (environmental impact assessments, responses to technical review committees, environmental protection plans, environmental monitoring plans, Alberta Greenhouse Gas Baseline and Compliance Application Verifications, Alberta NO_x and SO₂ Credit Application Verifications); ambient air quality monitoring; emissions inventories; pollutant dispersion modelling (AERMOD, ISC); ambient sound quality assessments; noise attenuation modelling; landfill gas testing and utilization; and National Pollutant Reporting Inventory preparation. Ms. Corning has experience in public and stakeholder relations, having participated in several open houses as an air and sound quality specialist on projects undergoing environmental assessment.

Ms. Corning has worked with clients in a variety of different industries in Canada and the US including: gas processing plants, oil refineries, pipeline operations, electrical generating stations (coal, gas, co-generation), manufacturing plants, construction projects, and pulp mills.



September 30, 2015
Ms. Sheryl Johnstone, P.Eng.
Page 9 of 9

**RE: PRE-TEST PLAN FOR CERTAINTEED GYPSUM CANADA INC.
MCADAM GYPSUM WALLBOARD PLANT, MCADAM, NB (COA NO. I-8150)**

Source Testing Team

Mr. Nick MacDonald, P.Tech. - graduated from NBCC Moncton, since graduation Mr. MacDonald has worked in environmental engineering, specializing in source emissions testing since 2007. Mr. MacDonald has been involved with over 100 source testing projects including testing for total particulate matter, combustion gases (including RATAs), metals, PAHs, dioxins and furans and particle size distribution (PM₁₀, PM_{2.5}). Mr. MacDonald is Stantec's field team leader and is responsible for maintenance and calibration of the Stantec source testing equipment. He will act as the source testing crew chief onsite.

Mr. Josh Babin, P.Tech. - graduated from NBCC Moncton in 2013 in Civil Engineering Technology: Building System Services. He joined Stantec's engineering department in Fredericton after graduation and supported design & drafting for various industrial clients from the Forestry/Pulp & Paper, Food & Beverage, and Power Generation sectors. He is a recent addition to the emissions testing team, bringing with him his experience with mechanical systems design and drafting. He has assisted on several testing campaigns under the guidance of our experienced technicians and engineers, for a variety of compounds including those covered by this pre-test plan. Josh would assist in completion of the onsite testing, data entry, and reporting.

Other Stantec staff may be used to support the team in completion of the work as required.

SCHEDULE

Testing is tentatively scheduled to be conducted the weeks of October 19 and October 26, to be confirmed based on plant operation and weather permitting. It is anticipated that the on-site source emissions testing will require two weeks on-site for a two person team.

CLOSURE

Stantec would appreciate your timely review and written approval of the Pre-Test Plan at your convenience. If you have any questions, please do not hesitate to contact me directly.

Sincerely,

STANTEC CONSULTING LTD.

Tristan Blair-Hicks, EIT
Project Manager
Tel: (506) 452-7000
Fax: (506) 452-0112
Tristan.Blair-Hicks@Stantec.com

Vicki Corning, P.Eng.
Technical Quality Reviewer
Tel: (506) 452-7000
Fax: (506) 452-0112
Vicki.Corning@Stantec.com

cc' Agata Sulkiewicz, CertainTeed Gypsum Canada Inc.

\\\cd1214-f02\workgroup\1218\active\121811606\1_environmental\8_report\1_pre-test_plan_and_approval\rpt_tbh_20150812_ptp_certaineed_mcadam_drft_jas.doc

Blair-Hicks, Tristan

From: Johnstone, Sheryl (ELG/EGL) <Sheryl.Johnstone@gnb.ca>
Sent: Thursday, October 01, 2015 2:58 PM
To: Blair-Hicks, Tristan
Cc: Corning, Vicki
Subject: RE: Pre-test plan for source testing at Certainteed Gypsum in MacAdam, NB

Follow Up Flag: Follow up
Flag Status: Flagged

Categories: Blue Category

Tristan,

The pre-test plan is approved, thanks.

Sheryl Johnstone, P.Eng
Industrial Approvals Engineer
Impact Management
Department of Environment & Local Government

Tel (506) 453-3824
Fax (506) 457-7805
sheryl.johnstone@gnb.ca

From: Blair-Hicks, Tristan [<mailto:Tristan.Blair-Hicks@stantec.com>]
Sent: Wednesday, September 30, 2015 4:55 PM
To: Johnstone, Sheryl (ELG/EGL)
Cc: Corning, Vicki
Subject: Pre-test plan for source testing at Certainteed Gypsum in MacAdam, NB

Hi Sheryl,

Here is the pre-test plan for the gypsum plant run by Certainteed located in MacAdam, NB and operated under the CoA No. I-8150. The testing is scheduled for the weeks of October 19 and October 26. I apologize for the delay in submitted the pre-test plan, I hope this will not be an issue as it states in their approval that it needs to be submitted 4 weeks in advance. Please feel free to contact me if you have any questions.

Tristan Blair-Hicks

Air Quality Engineer In Training
Stantec
845 Prospect Street Fredericton NB E3B 2T7
Phone: (506) 452-7000
Cell: (506) 461-6586
Fax: (506) 452-0112
Tristan.Blair-Hicks@stantec.com



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX C
Calibration Data



**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
PROBE ID - 3FT M5
NOZZLE - #8- 0.250"
DATE - Februaury 24, 2015

FAN SPEED	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
m/s		
0.00	0.00	0.00
12.1	8.70	13.80
13.7	11.00	17.70
15.2	13.60	21.80
16.7	16.40	26.20
18.1	19.30	30.80

PITOT FACTOR Cp = 0.791

PITOT - 3FT M5 NOZZLE - #8- 0.250"
Februaury 24, 2015



Technician: T. Ryan

Signature 

VALLEY ENVIRONMENTAL SERVICES
160 Pony Drive #1
Newmarket, Ontario L3Y 7B6
PH: (905) 830 0136
FAX: (905) 830 0137

Tunnel	VES
Std. Pitot Cp	0.999
Static	-0.25
Barometric	28.7
Temperature	65
Abs Static	28.68


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
PROBE ID - 3FT M5
NOZZLE - #10- 0.3125"
DATE - Februaury 24, 2015

FAN SPEED	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
m/s		
0.00	0.00	0.00
12.1	8.60	14.10
13.7	11.00	17.80
15.1	13.50	22.20
16.7	16.50	26.90
18.2	19.60	32.00

PITOT FACTOR Cp = 0.783

PITOT - 3FT M5 NOZZLE - #10- 0.3125"
Februaury 24, 2015



Technician: T. Ryan
Signature 

VALLEY ENVIRONMENTAL SERVICES
160 Pony Drive #1
Newmarket, Ontario L3Y 7B6
PH: (905) 830 0136
FAX: (905) 830 0137

Tunnel	VES
Std. Pitot Cp	0.999
Static	-0.25
Barometric	28.7
Temperature	65
Abs Static	28.68


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
PROBE ID - 4FT M5
NOZZLE - #10- 0.3125"
DATE - February 23, 2015

FAN SPEED	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
m/s		
0.00	0.00	0.00
12.1	8.70	15.30
13.6	11.10	19.40
15.1	13.70	24.00
16.6	16.60	28.90
18.0	19.50	34.30

PITOT FACTOR Cp = 0.756

PITOT - 4FT M5 NOZZLE - #10- 0.3125"
February 23, 2015



Technician: T. Ryan

Signature 

VALLEY ENVIRONMENTAL SERVICES
160 Pony Drive #1
Newmarket, Ontario L3Y 7B6
PH: (905) 830 0136
FAX: (905) 830 0137

Tunnel	VES
Std. Pitot Cp	0.999
Static	-0.25
Barometric	29.15
Temperature	65
Abs Static	29.13


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
PROBE ID - 6FT M5
NOZZLE - #10- 0.3125"
DATE - February 25, 2015

FAN SPEED	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
m/s		
0.00	0.00	0.00
12.1	8.70	14.00
13.7	11.00	17.70
15.2	13.60	22.00
16.7	16.40	26.50
18.2	19.50	31.20

PITOT FACTOR Cp = 0.788

PITOT - 6FT M5 NOZZLE - #10- 0.3125"
February 25, 2015



Technician: T. Ryan

Signature 

VALLEY ENVIRONMENTAL SERVICES
160 Pony Drive #1
Newmarket, Ontario L3Y 7B6
PH: (905) 830 0136
FAX: (905) 830 0137

Tunnel	VES
Std. Pitot Cp	0.999
Static	-0.25
Barometric	28.7
Temperature	65
Abs Static	28.68

Pre-Test Dry Gas Meter - Control Unit Calibration

Date : 10/20/2015

Barometric Pressure, Pb : 30

Model Number : 1848

Calibrated By : TBH

Job #: 121899000

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Meter Volume, Vm (cu.ft)			Temperatures (F)			Time, theta (min)	
					Dry Gas Meter			
			Total		Outlet, to	Average, tm		
0.8				5.552		71	71	10
1.2				5.432		70	70	8
2.0				5.872		70	71	7

Calculations

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Correction Factor, gamma (Tolerance = 0.95 - 1.05, +/-1.5% of avg)	Orifice Pressure Differential (delta H@) yielding 0.75 cfm of air at 68F and 29.92 in.Hg as in. H2O (Tolerance = +/- 0.15 in.)	Orifice Coefficient Ko
0.8	0.976	1.516	0.779
1.2	0.971	1.553	0.773
2.0	0.973	1.687	0.740
Average	0.974	1.585	0.764

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE:		10/10/2015		METER SERIAL #:		14108776		BAROMETRIC PRESSURE (in Hg):				INITIAL	FINAL	AVG (P _{bar})	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED				
METER PART #:		1848		CRITICAL ORIFICE SET SERIAL #:		1463s													
ORIFICE #	RUN #	K'	TESTED VACUUM	DGM READINGS (FT ³)			TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	(1) V _m (STD)	(2) V _{cr} (STD)	(3) Y	Y VARIATION (%)	ΔH@		
		FACTOR (AVG)	(in Hg)	INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG									
15	1	0.4164	18	19.64	25.28	5.640	70	71	70	72	71	71	10.00	0.79	5.6238	5.4169	0.963	1.51	
	2	0.4164	18	25.28	30.79	5.505	72	70	70	71	71	70.5	10.00	0.79	5.4944	5.4067	0.984	1.52	
	3	0.4164	18	30.79	36.30	5.510	73	70	70	71	70	70.25	10.00	0.79	5.5020	5.4016	0.982	1.52	
18	1	0.5085	18	56.76	62.21	5.450	74	70	71	70	70	70.25	8.00	1.20	5.4475	5.2722	0.968	1.55	
	2	0.5085	18	62.21	67.65	5.440	73	71	71	70	70	70.5	8.00	1.20	5.4350	5.2771	0.971	1.55	
	3	0.5085	18	67.65	73.06	5.405	75	71	71	70	70	70.5	8.00	1.20	5.40	5.2672	0.975	1.56	
23	1	0.6307	16.5	73.06	78.91	5.855	75	71	71	70	70	70.5	7.00	2.00	5.8610	5.7164	0.975	1.69	
	2	0.6307	16.5	78.91	84.81	5.90	75	71	71	70	70	70.5	7.00	2.00	5.9061	5.7164	0.968	1.69	
	3	0.6307	16.5	87.11	92.97	5.860	73	71	71	70	70	70.5	7.00	2.00	5.8660	5.7271	0.976	1.68	
																		Avg = 0.973 -0.05	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.974**

$$(1) \quad V_{m(\text{std})} = K_1 * V_m * \frac{P_{\text{bar}} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)

T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

$$(2) \quad V_{cr(\text{std})} = K' * \frac{P_{\text{bar}} * \Theta}{\sqrt{T_{\text{amb}}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

$$(3) \quad Y = \frac{V_{cr(\text{std})}}{V_{m(\text{std})}}$$

= DGM calibration factor

AVERAGE ΔH@ = **1.59**

$$\Delta H@ = \left(\frac{0.75 \Theta}{V_{cr(\text{std})}} \right)^2 \Delta H \left(\frac{V_{m(\text{std})}}{V_m} \right)$$

Pre-Test Dry Gas Meter - Control Unit Calibration

Date : 6/29/2015

Barometric Pressure, Pb : 29.7

Model Number : 1646

Calibrated By : JJB

Job #:

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Meter Volume, Vm (cu.ft)					Temperatures (F)			Time, theta (min)	
						Dry Gas Meter				
				Total		Outlet, to	Average, tm			
0.9					5.430		64	65	10	
1.5					5.353		66	66	8	
2.3					5.803		67	67	7	

Calculations

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Correction Factor, gamma (Tolerance = 0.95 - 1.05, +/- 1.5% of avg)	Orifice Pressure Differential (delta H@) yielding 0.75 cfm of air at 68F and 29.92 in.Hg as in. H2O (Tolerance = +/- 0.15 in.)	Orifice Coefficient Ko
0.9	1.039	1.590	0.758
1.5	1.030	1.776	0.723
2.3	1.032	1.770	0.723
Average	1.033	1.712	0.734

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

DATE:		METER SERIAL #:		BAROMETRIC PRESSURE (in Hg):		INITIAL	FINAL	AVG (P _{bar})	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED									
METER PART #:		CRITICAL ORIFICE SET SERIAL #:				29.7	29.7	29.7										
ORIFICE #	RUN #	K'	TESTED VACUUM (in Hg)	TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H ₂ O)	(1) V _m (STD)	(2) V _{cr} (STD)	(3) Y	Y VARIATION (%)	ΔH _@				
		FACTOR (AVG)	DGM READINGS (FT ³)	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG											
15	1	0.4164	18	983.61	989.03	5.420	20.2	63	66	63	64	64	10.00	0.90	5.4343	5.6454	1.039	1.59
	2	0.4164	18	989.03	994.47	5.440	20.4	66	66	64	65	65.25	10.00	0.90	5.4414	5.6442	1.037	1.59
	3	0.4164	18	994.47	999.90	5.430	20.5	66	66	65	65	65.5	10.00	0.90	5.4288	5.6437	1.040	1.59
18	1	0.5085	17	999.90	1,005.25	5.350	20.5	66	67	65	65	65.75	8.00	1.50	5.3542	5.5135	1.030	1.78
	2	0.5085	17	1,005.25	1,010.61	5.360	20.5	67	67	65	66	66.25	8.00	1.50	5.3591	5.5135	1.029	1.78
	3	0.5085	17	1,010.61	1,015.96	5.350	20.5	67	67	66	66	66.5	8.00	1.50	5.3466	5.5135	1.031	1.78
23	1	0.6307	16	1,015.96	1,021.77	5.810	20.5	67	68	66	67	67	7.00	2.30	5.8122	5.9837	1.030	1.77
	2	0.6307	16	1,021.77	1,027.56	5.790	20.5	68	69	67	66	67.5	7.00	2.30	5.7867	5.9837	1.034	1.77
	3	0.6307	16	1,027.56	1,033.37	5.810	20.5	69	69	66	67	67.75	7.00	2.30	5.8040	5.9837	1.031	1.77

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **1.033**

$$(1) \quad V_{m_{(std)}} = K_1 * V_m * \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)

T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

$$(2) \quad V_{cr_{(std)}} = K' * \frac{P_{bar} * \Theta}{\sqrt{T_{amb}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

$$(3) \quad Y = \frac{V_{cr_{(std)}}}{V_{m_{(std)}}}$$

= DGM calibration factor

AVERAGE ΔH_@ = **1.71**

$$\Delta H_{@} = \left(\frac{0.75 \Theta}{V_{cr_{(std)}}} \right)^2 \Delta H \left(\frac{V_{m_{(std)}}}{V_m} \right)$$

Probe Stack Thermocouple Calibration

Calibration Date: 19-Mar-15

Calibrated By: NGM, JJB

Reference ID Fisher Scientific catalog #150414E



Ice Bath

Thermocouple #	Reference Temp (F)	Observed Temp (F)
#1 -2' probe	32	32.3
#1 -3' probe	32	32.1
#1 -4' probe	32	33.7
#1 -5' probe	32	33.1
#1 - 6' probe	32	32.5
#1 - 8'-1 probe	32	32.7
#1 - 8'-2 probe	32	32.6
#1 - 10'-1 probe	32	33
#1 - 10'-2 probe	32	33
#6 -1848	32	
#7 -1848	32	
#6 -1646	32	
#7 -1646	32	


Percent Difference (Absolute Temp)
-0.06%
-0.02%
-0.34%
-0.22%
-0.10%
-0.14%
-0.12%
-0.20%
-0.20%

Boiling Water

Thermocouple #	Reference Temp (F)	Observed Temp (F)
#1 -2' probe	202	206.7
#1 -3' probe	201	208.7
#1 -4' probe	203	201.6
#1 -5' probe	203	206.3
#1 - 6' probe	202	203.3
#1 - 8'-1 probe	203	204.5
#1 - 8'-2 probe	202	202.3
#1 - 10'-1 probe	200	212.1
#1 - 10'-2 probe	202	210.3
#6 -1848	202	
#7 -1848	203	
#6 -1646	203	
#7 -1646	201	

Percent Difference (Absolute Temp)
-0.70%
-1.15%
0.21%
-0.50%
-0.20%
-0.23%
-0.05%
-1.80%
-1.24%

Error should be < 1.5%



CAL-CHEK CANADA

250 GOVERNOR'S ROAD - DUNDAS, ONTARIO L9H 3K3
TELEPHONE: (905) 628-4636 FAX: (905) 627-5903
email calchek@cogeco.ca

Scale / Balance Certification

Date: February 9, 2015

Certificate Number: S150165

Customer: Stantec Consulting Ltd.
845 Prospect Street
Fredericton, New Brunswick E3B 2T7

Room Temperature: 20.1°C

Calibration Location: 10 Timothy Road North Kingsclear Lab

Resolution: 0.0001g

Scale / Balance Manufacturer: Radwag

Model Number: XA220-2X

Serial Number: 336271

Capacity: 220 g

Capacity Calibrated To: 220 g

<u>ACTUAL WEIGHT</u>	<u>SCALE</u>	<u>ACTUAL WEIGHT</u>	<u>SCALE</u>
<u>APPLIED</u>	<u>READINGS</u>	<u>APPLIED</u>	<u>READINGS</u>
<u>GRAMS</u>	<u>AS FOUND</u>	<u>GRAMS</u>	<u>AS LEFT</u>
0.0020	0.0020	0.0020	0.0020
0.0050	0.0050	0.0050	0.0050
0.0100	0.0100	0.0100	0.0100
0.0500	0.0500	0.0500	0.0500
0.1000	0.1000	0.1000	0.1000
0.5000	0.5001	0.5000	0.5000
1.0000	0.9998	1.0000	0.9999
5.0000	4.9999	5.0000	4.9990
10.0000	10.0001	10.0000	10.0000
20.0000	20.0016	20.0000	20.0009
50.0000	50.0030	50.0000	50.0020
100.0000	99.9982	100.0000	99.9992
200.0000	200.0134	200.0000	200.0027
220.0000	220.0170	220.0000	220.0110

The above mentioned Scale / Balance has been checked for accuracy using the following N.I.S.T. calibrated dead weights as per the CSA method.

<u>STANDARD</u>	<u>CAL DATE</u>	<u>NIST LAB #</u>
22XE	03/10/13	681/280058-10

Obtained results are within the manufacturer's stated accuracy and/or are within +/-0.01% or 1 division whichever is greater at any point of the calibrated range.

Pass/Fail statements are based on data from measurements made, procedures utilized, professional experience and the uncertainty associated with this calibration. It is the responsibility of the user of this equipment to determine if the results identified meet specific requirements for its intended application.

Calibration Technician: Dave Newitt

Authorized Signatory: Roni Newitt

Suggested Calibration Due Date: February 2016

Due dates appearing on the certificate of calibration and label are determined by client for administrative purposes and do not imply continued conformance to specifications.

All calibrations performed at customer location unless otherwise noted.

This certificate shall not be reproduced except in full, without the written approval of Cal-Chek Canada

Stantec Consulting Ltd.						
Steel Nozzle Calibration Data Sheet						
NozzleID	Nozzle Diameter (inches)					
Set - 1	<1>	<2>	<3>	<4>	Hi-Lo	Avg.
1-4	0.125	0.124	0.125	0.125	0.001	0.125
1-6	0.175	0.173	0.165	0.175	0.010	0.172
1-8	0.236	0.232	0.234	0.232	0.004	0.234
1-10	0.307	0.305	0.308	0.305	0.003	0.306
1-12	0.367	0.372	0.367	0.371	0.005	0.369
1-14	0.434	0.434	0.433	0.434	0.001	0.434
1-16	0.500	0.497	0.503	0.501	0.006	0.500
QA/QC	Check					
	Each Diameter Measured To Within = 0.001 Inches					
	High - Low </= 0.004					
Prepared By: JJB				Date: Feb 05, 2015		

Stantec Consulting Ltd.						
Steel Nozzle Calibration Data Sheet						
NozzleID	Nozzle Diameter (inches)					
Set - 2	<1>	<2>	<3>	<4>	Hi-Lo	Avg.
2-4	0.124	0.126	0.125	0.127		0.126
2-6	0.177	0.174	0.176	0.173		0.175
2-8	0.245	0.249	0.231	0.244		0.242
2-10	0.306	0.306	0.304	0.302		0.305
2-12	0.359	0.363	0.365	0.361		0.362
2-14	0.432	0.430	0.432	0.433		0.432
2-16	0.493	0.500	0.497	0.492		0.496
QA/QC	Check					
	Each Diameter Measured To Within = 0.001 Inches					
	High - Low </= 0.004					
Prepared By: JB				Date: Feb 05, 2015		



QRM
ELECTRONICS



QRM Electronics Inc. calibration laboratory certifies that the described instrument has been presented for inspection and the tests as shown indicate that the work performed has been completed and that the standard used in obtaining data are calibrated regularly traceable to the **National Institute of Standards and Technology**

Date:	6/24/2015	Customer:	STANTEC
Control Number:	8309	Address:	845 PROSPECT ST. FREDERICTON, NEW BRUNSWICK E3B 2T7
Description:	350M/XL		
Serial Number:	00968835/404 - 00959384/404		

SUGGESTED RECALIBRATION DATE: 6/24/2016

Parameter: Combustion

Accuracy Statement: +/- 20 ppm or 5% of m.v.

STANDARD	AS RECEIVED				AFTER CALIBRATION			
	PPM	°F	PASS/FAIL	NOTE	PPM	°F	PASS/FAIL	NOTE
O2 3.06 %	3.00 %	76.2	PASS		3.05 %	76.2	PASS	SR
CO 497 PPM	482 PPM	76.2	PASS		496 PPM	76.2	PASS	
NO 824 PPM	795 PPM	76.2	PASS		832 PPM	76.2	PASS	
NO2 96 PPM	94.1 PPM	76.2	PASS		97.0 PPM	76.2	PASS	
SO2 994.7 PPM	985 PPM	76.2	PASS		995 PPM	76.2	PASS	
HC 4980 PPM	4160 PPM	76.2	PASS		4990 PPM	76.2	PASS	

*NOTE: SR = Sensor Replaced, RNS = Response Not Stable

Test Equipment Transfer standards from:				
Cylinder #	Gas	Concentration	Certification Date	Expiration Date
RA56616	CO / O2	996.9 PPM / 3.10 %	03/27/2014	03/27/2017
XF000167B	SO2	994.7 PPM	03/31/2014	03/31/2016
SV14124	NO2	96 PPM	04/09/2014	04/09/2016
SX34840	NO / CO2	824 PPM / 17 %	05/01/2014	05/01/2017
S970111A	CO / H2	497 PPM / 296 PPM	06/10/2014	06/10/2017
CC107025	NO	81.3 PPM	03/06/2015	03/06/2017
SX21602	CO / O2	99.2 PPM / 3.06 %	03/11/2015	03/11/2018

Calibrated at:

QRM Electronics Inc.
250 West Beaver Creek Rd.
Unit 15, Richmond Hill, ON
L4B 1C7

Phone: (905) 771 5009
Fax : (905) 771 6041

KYLE ANDERSON
Calibrated By

Authorized Signature



**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX D

Sampling Locations

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam, New Brunswick

December 16, 2015

Sample Location Details - CertainTeed Gypsum

Parameter	Calcine Mill	Rock Mill	Zone 1 Dryer	Zone 2 Dryer
Stack Height - Above Grade (m)	21	21	6.7	6.7
Stack/Duct Description	circular, vertical	circular, vertical	circular, vertical	circular, vertical
Diameter (m)	0.9	0.9	1.22	1.22
Number of Ports	2	2	2	2
Sample Port Configuration	2 @ 90°	2 @ 90°	2 @ 90°	2 @ 90°
Sample Port Diameters (m)	0.1	0.1	0.1	0.1
Location Upstream from any Disturbance (Number of Stack Diameters)	<2	<2	<2	<2
Location Downstream from any Disturbance, (Number of Stack Diameters)	<8	<8	<8	<8
Ideal or Non Ideal ¹	non-ideal ¹	non-ideal ¹	non-ideal ¹	non-ideal ¹
Total Number of Sample Points	24	24	24	24
Number of Sample Points per Traverse for PM	12	12	12	12
Sample Time per Point for PM (min)	4	4	4	4
Total Sample Time per Test for PM (min)	96 min	96 min	96 min	96 min
Total Sample Time for Combustion Gases	30 min	30 min	30 min	30 min
Notes:				
1 The exhaust gas flow characteristics at the sampling location are referred to as being "Ideal" if the sample ports are located in a straight section of stack at least 8 stack diameters downstream and two stack diameters upstream of any flow disturbance.				

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX E

Calculated Data – Sample Calculations and Velocity Profiles

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

MOISTURE FIELD DATA SHEET

6922-04

Project No.: 121811606
 Client: Certainteed
 Plant: Rock Dryer
 Location: McAdam, NB
 Test: PM-1
 Date: Oct 20, 2015
 Analyst: JJB/NGM



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	789.2	704.4	84.8
2	100 mL H ₂ O	726.5	702.1	24.4
3	Blank	667.0	660.9	6.1
4	200g Silica Gel	995.5	986.1	9.4
		Total Weight Gain (g)		124.7
		Moisture Volume (mL)		124.7

$$\text{Volume H}_2\text{O Collected: } 124.7 \text{ ml}$$

$$X 0.048 = \underline{\quad 5.99 \quad} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{\quad 77.87 \quad} \text{ ft}^3$$

$$\text{DGM Initial } \underline{\quad 76.03 \quad} \text{ ft}^3$$

$$\text{Final - Initial } = \underline{\quad 51.84 \quad} \text{ ft}^3 (\text{Vmc})$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \frac{5.99}{(5.99 + 51.84)}$$

$$\text{Moisture} = \underline{\quad 0.104 = 10.4\% \quad}$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: Certainteed
 Plant: Rock Dryer
 Location: M. Adam, NB
 Test: PM-1
 Date: Oct. 20, 2015
 Operators: JJB/NGM
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.791
 Start: 10:30
 Finish: 12:15

Static Pressure (in.H2O): 0.20
 Port Length (in): 4"
 Stack Dia. (in.): 36"
 Probe Length (ft): 3'
 Nozzle ID (in.): 1-8 (0.234)
 Console S/N: 1646

Pre-Test Leak Check: -18
 Vacuum Pressure: 0
 Post-Test Leak Check: -18
 Vacuum Pressure: 0

K': 2.24

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				26.03						
1-1	4	151	0.47	0.89	28.13	249	227	41	56	56	-1
2	8	151	0.53	1.00	30.37	245	235	42	56	55	-1
3	12	153	0.45	0.85	32.58	254	249	42	57	55	-1
4	16	155	0.44	0.83	34.64	255	250	42	57	55	-1
5	20	152	0.46	0.87	36.67	259	258	42	58	55	-1
6	24	148	0.46	0.87	38.80	255	259	42	58	55	-1
7	28	146	0.48	0.91	40.92	257	262	42	59	56	-1
8	32	146	0.49	0.93	43.09	255	264	42	58	56	-1
9	36	144	0.48	0.91	45.25	257	265	42	60	57	-1
10	40	134	0.50	0.97	47.45	262	269	42	60	57	-1
11	44	130	0.48	0.94	49.65	256	268	42	60	57	-1
12	48	130	0.48	0.94	51.80	251	266	42	59	56	-1
2-1	52	130	0.49	0.94	53.99	248	259	42	59	56	-1
2	56	131	0.50	0.98	56.19	243	262	42	60	57	-1
3	60	133	0.50	0.98	58.40	247	265	42	59	56	-1
4	64	134	0.48	0.94	60.57	249	264	42	59	56	-1
5	68	138	0.51	0.99	62.78	245	264	42	59	56	-1
6	72	141	0.49	0.95	64.98	243	259	42	59	56	-1
7	76	143	0.49	0.95	67.14	243	262	42	58	56	-1
8	80	143	0.49	0.95	69.31	248	261	42	60	56	-1
9	84	141	0.46	0.89	71.41	244	259	42	60	57	-1
10	88	143	0.50	0.97	73.61	249	261	42	60	57	-1
11	92	148	0.50	0.95	75.76	244	263	43	60	57	-1
12	96	151	0.46	0.88	77.87	244	263	43	60	57	-1

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811606

Client: Certainteed

Plant: Rock Dryer

Location: McAdam, NB

Test No.: 1

Date: 04/20/2015

Fuel Type: Natural Gas

Time Start: 10:15

Time Finish: 10:45

Personnel: JJB

MOISTURE FIELD DATA SHEET

Project No.: 121811606
 Client: CertainTeed
 Plant: Rock Dyer
 Location: McAdam, NB
 Test: PM-2
 Date: Oct 20, 2015
 Analyst: JJS/NAM



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	784.6	692.2	92.4
2	100 mL H ₂ O	716.8	701.5	15.3
3	Blank	663.4	662.1	1.3
4	200g Silica Gel	1005.7	995.5	10.2
		Total Weight Gain (g)		121.2
		Moisture Volume (mL)		121.2

$$\text{Volume H}_2\text{O Collected: } \underline{121.2} \text{ ml}$$

$$X 0.048 = \underline{5.82} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{125.50} \text{ ft}^3$$

$$\text{DGM Initial } \underline{78.55} \text{ ft}^3$$

$$\text{Final - Initial} = \underline{46.95} \text{ ft}^3 \text{ (Vmc)}$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \frac{5.82}{(5.82 + 46.95)}$$

$$\text{Moisture} = \underline{0.110} = \underline{11.0\%}$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CertainTeed
 Plant: Rock Dryer
 Location: McAdam, NB
 Test: PM-2
 Date: Oct. 20, 2015
 Operators: JJB/NGM
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.791
 Start : 12:45
 Finish : 14:45

Static Pressure (in.H2O): 0.20
 Port Length (in): 4"
 Stack Dia. (in.): 36"
 Probe Length (ft): 31
 Nozzle ID (in.): 1-8 (0.234)
 Console S/N: 1646

Pre-Test Leak Check: -18
 Vacuum Pressure: 0
 Post-Test Leak Check: 0
 Vacuum Pressure: -18

K': 2.24

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				78.55						
1-1	4	144	0.39	0.75	80.48	251	225	46	56	56	-1
2	8	146	0.37	0.71	82.42	246	228	45	57	56	-1
3	12	150	0.37	0.70	84.31	237	233	45	57	56	-1
4	16	152	0.42	0.80	86.36	236	232	42	59	56	-1
5	20	150	0.42	0.80	88.33	236	232	42	60	57	-1
6	24	148	0.40	0.76	90.37	238	235	42	60	57	-1
7	28	138	0.38	0.74	92.20	235	232	42	62	58	-1
8	32	135	0.38	0.74	94.15	231	229	42	62	58	-1
9	36	135	0.42	0.82	96.16	230	234	41	62	58	-1
10	40	135	0.42	0.82	98.20	233	234	41	62	58	-1
11	44	134	0.40	0.78	100.25	231	236	41	62	58	-1
12	48	134	0.40	0.78	102.24	230	238	41	62	58	-1
2-1	52	135	0.42	0.82	104.24	232	238	41	62	58	-1
2	56	136	0.38	0.73	106.43	231	242	43	63	59	-1
3	60	141	0.35	0.68	108.03	231	240	43	63	59	-1
4	64	146	0.35	0.68	109.89	225	233	43	63	59	-1
5	68	146	0.38	0.73	111.83	230	239	46	65	61	-1
6	72	150	0.38	0.73	113.77	232	234	46	65	61	-1
7	76	150	0.38	0.73	115.83	230	232	49	65	61	-1
8	80	151	0.42	0.81	113.70	232	234	49	65	61	-1
9	84	149	0.42	0.81	119.74	229	238	49	67	63	-1
10	88	145	0.42	0.81	121.75	229	233	49	67	63	-1
11	92	138	0.39	0.69	123.63	227	235	49	67	63	-1
12	96	136	0.35	0.69	125.50	226	237	49	67	63	-1

255/551 116
 265/60/14

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811606

Client: CertainTeed

Plant: Rock Dyer

Location: McAdam, NB

Test No.: 2

Date: Oct 20, 2015

Fuel Type: Natural Gas

Time Start: 11:00

Time Finish: 1:30

Personnel: JJB

MOISTURE FIELD DATA SHEET

Project No.: 121811606
 Client: CertainTeed
 Plant: Rock Dryer
 Location: M. Aclay, NB
 Test: PM-3
 Date: Oct 21, 2015
 Analyst: JJB/NGM



Moisture Data

Impinger No.	Impinger Content	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	765.5	697.9	67.6
2	100 mL H ₂ O	714.6	703.3	11.3
3	Blank	663.6	661.5	2.1
4	200g Silica Gel	1015.2	1005.7	9.5
		Total Weight Gain (g)		90.5
		Moisture Volume (mL)		90.5

$$\text{Volume H}_2\text{O Collected: } \underline{90.5} \text{ ml}$$

$$X 0.048 = \underline{4.34} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{176.20} \text{ ft}^3$$

$$\text{DGM Initial } \underline{125.74} \text{ ft}^3$$

$$\text{Final - Initial} = \underline{50.46} \text{ ft}^3 \text{ (Vmc)}$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \frac{4.34}{(4.34 + 50.46)}$$

$$\text{Moisture} = \underline{0.079} = 7.9\%$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CERTAINTEED
 Plant: mcGOWAN
 Location: Rock DRYER
 Test: PM-3
 Date: OCT. 21 / 2015
 Operators: JJB / NGM
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.791
 Start: 10:30
 Finish: 12:10

Static Pressure (in.H2O): 0.25
 Port Length (in): 4"
 Stack Dia. (in.): 36"
 Probe Length (ft): 3'
 Nozzle ID (in.): 1-8 (0.234)
 Console S/N: 1646

Pre-Test Leak Check: 0
 Vacuum Pressure: -18
 Post-Test Leak Check: 0
 Vacuum Pressure: -18

K': 2.24

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				125.74						
1-1	4	115	0.50	1.00	127.93	264	256	36	56	56	-1
2	8	117	0.46	0.92	130.07	250	254	36	58	56	-1
3	12	118	0.44	0.88	132.18	238	254	36	58	57	-1
4	16	121	0.44	0.88	* 134.32	228	251	36	58	57	-1
5	20	121	0.47	0.94	136.45	232	254	36	59	57	-1
6	24	121	0.47	0.84	138.48	237	251	36	60	57	-1
7	28	121	0.44	0.88	140.56	241	255	36	60	58	-1
8	32	122	0.46	0.92	142.71	237	254	36	61	58	-1
9	36	127	0.44	0.87	144.77	238	254	36	61	58	-1
10	40	134	0.45	0.88	146.88	243	255	36	61	58	-1
11	44	140	0.42	0.81	148.89	241	258	36	63	59	-1
12	48	142	0.43	0.83	150.92	230	255	36	63	59	-1
2-1	52	143	0.43	0.83	152.96	228	258	36	63	60	-1
2	56	141	0.44	0.86	155.63	233	256	36	63	60	-1
3	60	139	0.45	0.88	157.12	238	258	36	63	60	-1
4	64	136	0.45	0.88	159.21	238	260	36	64	60	-1
5	68	134	0.45	0.88	161.31	234	262	36	64	61	-1
6	72	132	0.47	0.92	163.49	238	260	36	64	61	-1
7	76	130	0.43	0.85	165.53	243	262	36	64	61	-1
8	80	128	0.46	0.91	167.67	246	264	36	65	62	-1
9	84	128	0.44	0.87	169.76	248	266	37	65	62	-1
10	88	127	0.46	0.91	171.94	243	268	37	65	62	-1
11	92	126	0.46	0.91	174.09	245	267	38	66	62	-1
12	96	127	0.45	0.89	176.20	247	268	38	66	62	-1

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811606

Client: Certainteed

Plant: Rock River

Location: M. Adams, N.Y.

Test No.: 3

Date: Oct 21, 2015

Fuel Type: Natural Gas

Time Start: 10:30

Time Finish: 16:00

Personnel: JR

MOISTURE FIELD DATA SHEET

0922-02

Project No.: 121811606
 Client: Certainteed
 Plant: Calsine
 Location: McMulan, WI
 Test: PM-1
 Date: 09.22.2015
 Analyst: JJB/MGM



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	959.1	699.0	260.1
2	100 mL H ₂ O	874.8	708.0	166.8
3	Blank	680.0	661.3	18.7
4	200g Silica Gel	1043.5	1015.2	28.3
		Total Weight Gain (g)		473.9
		Moisture Volume (mL)		473.9

$$\text{Volume H}_2\text{O Collected: } \underline{473.9} \text{ ml}$$

$$X 0.048 = \underline{22.75} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{277.73} \text{ ft}^3$$

$$\text{DGM Initial } \underline{176.36} \text{ ft}^3$$

$$\text{Final - Initial} = \underline{101.37} \text{ ft}^3 (\text{Vmc})$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \frac{22.75}{(22.75 + 101.37)}$$

$$\text{Moisture} = \underline{0.183 = 18.3\%}$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CertainTeed
 Plant: Calcine
 Location: McAdam, NB
 Test: PM-1
 Date: Oct 27 2015
 Operators: JJR/NGM
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.783
 Start: 13:20
 Finish: 15:00

Static Pressure (in.H2O):
 Port Length (in): 2"
 Stack Dia. (in.): 36"
 Probe Length (ft): 3
 Nozzle ID (in.): 2-10 (0.305)
 Console S/N: 1646

Pre-Test Leak Check: -18
 Vacuum Pressure: 0
 Post-Test Leak Check: -18
 Vacuum Pressure: 0

K': 5.20

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				176.36						
1-1	4	292	1.10	3.93	180.56	240	257	43	57	57	-3
2	8	287	1.0	3.57	184.69	225	232	43	57	57	-3
3	12	287	0.97	3.50	188.76	225	237	39	58	57	-3
4	16	287	0.99	3.56	192.88	225	234	42	57	57	-3
5	20	293	1.0	3.57	197.00	225	251	45	61	58	-3
6	24	293	1.10	3.95	201.29	225	250	49	63	60	-3
7	28	293	1.10	3.95	205.60	225	251	49	63	60	-3
8	32	293	1.10	3.95	209.88	225	237	53	65	60	-3
9	36	293	1.05	3.76	214.12	226	234	55	66	60	-2
10	40	293	1.05	3.76	218.36	230	266	57	66	61	-3
11	44	292	1.05	3.80	222.60	231	266	55	67	61	-3
12	48	292	1.05	3.80	226.85	231	261	51	67	61	-3
2-1	52	293	1.10	3.98	231.10	232	269	50	68	61	-3
2	56	293	1.00	3.62	235.34	249	266	46	67	62	-3
3	60	293	1.00	3.62	239.50	247	264	43	67	62	-3
4	64	293	1.00	3.62	243.63	242	257	42	67	62	-3
5	68	293	1.10	3.99	248.00	244	260	42	68	65	-3
6	72	293	1.10	3.99	252.37	231	262	42	68	65	-3
7	76	293	1.10	3.99	256.70	231	245	43	68	62	-3
8	80	294	1.10	3.99	261.04	232	247	43	68	63	-3
9	84	294	1.00	3.62	265.24	228	243	44	68	63	-4
10	88	295	1.00	3.63	269.42	225	245	45	69	63	-4
11	92	295	1.00	3.63	273.59	232	257	45	69	63	-4
12	96	295	1.00	3.63	277.73	232	261	46	70	63	-4

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811 606

Client: Certinked

Plant: Mc Adam

Location: Calcine Mill

Test No.: Gas # 1

Date: Oct 22, 2015

Fuel Type: Nat gas

Time Start: 14:00

Time Finish: 24:30

Personnel: N6M

MOISTURE FIELD DATA SHEET

0922-20

Project No.: 121811606
 Client: CertainTeed
 Plant: Calcine
 Location: McAdam, NB
 Test: PM-2
 Date: Oct 27, 2015
 Analyst: NGM



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	961.4	696.0	265.4
2	100 mL H ₂ O	962.5	704.8	257.7
3	Blank	712.0	663.3	48.7
4	200g Silica Gel	1006.4	979.6	26.8
		Total Weight Gain (g)		598.6
		Moisture Volume (mL)		540.6

$$\text{Volume H}_2\text{O Collected: } \underline{848.6} \text{ ml}$$

$$\times 0.048 = \underline{28.73} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{375.67} \text{ ft}^3$$

$$\text{DGM Initial } \underline{278.06} \text{ ft}^3$$

$$\text{Final - Initial} = \underline{97.57} \text{ ft}^3 (\text{Vmc})$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \frac{28.73}{28.73 + 97.57}$$

$$\text{Moisture} = \underline{0.23} \quad 23\%$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CertainTeed
 Plant: Calrina
 Location: McAdoo, PA
 Test: PM-2
 Date: Oct 27, 2015
 Operators: TSB/N6M
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.793
 Start: 10:40
 Finish: 12:35

Static Pressure (in.H2O):
 Port Length (in): 21
 Stack Dia. (in.): 36"
 Probe Length (ft): 3
 Nozzle ID (in.): 2-10 (0.305)
 Console S/N: 16416

Pre-Test Leak Check: -18
 Vacuum Pressure: 0
 Post-Test Leak Check: -18
 Vacuum Pressure: 0

K': \$20

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
0					278.06						
1	4	300	0.96	3.28	281.82	225	225	42	38	38	-4
2	8	300	0.98	3.31	285.73	226	230	44	45	39	-4
3	12	301	1.0	3.45	289.65	225	228	34	49	41	-4
7	16	302	1.0	3.45	293.62	228	230	34	49	41	-4
5	20	301	1.1	3.84	297.76	230	228	34	52	42	-4
6	24	300	1.1	3.84	302.03	226	233	33	54	43	-4
7	28	300	1.1	3.84	306.22	227	228	32	54	43	-4
8	32	301	0.95	3.33	310.16	228	230	38	56	45	-4
9	36	302	0.95	3.33	314.12	230	228	38	56	45	-4
10	40	302	0.95	3.35	318.08	228	226	42	60	50	-4
11	44	302	1.0	3.53	322.29	228	225	42	60	50	-4
12	48	302	1.0	3.53	326.49	229	226	42	60	50	-4
1	52	302	1.0	3.54	330.38	225	230	43	62	53	-4
2	56	299	1.0	3.94	334.41	226	230	41	62	54	-4
3	60	200	1.1	3.90	338.70	228	230	41	62	54	-4
4	64	300	1.1	3.90	343.97	225	228	41	62	54	-4
5	68	300	1.1	3.90	347.25	228	230	41	62	54	-4
6	72	301	0.95	3.38	351.25	225	228	43	64	56	-4
7	76	301	0.95	3.38	355.26	230	232	43	64	56	-4
8	80	302	0.95	3.39	359.29	227	230	45	65	58	-4
9	84	302	0.98	3.50	364.32 *	227	228	45	66	58	-4
10	88	303	0.98	3.50	367.47	225	229	45	66	58	-4
11	92	300	0.96	3.50	371.60	228	233	45	66	58	-4
12	96	300	0.98	3.50	375.63	228	233	45	66	58	-4

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.:	121811606
Client:	Certainteed
Plant:	McAdam
Location:	Calcare
Test No.:	Ces # 2
Date:	Oct 22, 2000

Fuel Type: No. 2 fuel oil

Personnel: TBH IN 6M

MOISTURE FIELD DATA SHEET

Project No.: 121411606

Client: CERTAINTEED

Plant: *Malva*

Location: CALCIWER

Test: Page 3

Date: Oct 23

Analyst: ✓



Stantec

0922-19

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	953.1	692.9	260.2
2	100 mL H ₂ O	971.8	712.7	259.1
3	Blank	738.3	664.1	74.2
4	200g Silica Gel	881.1	877.3	3.8
		Total Weight Gain (g)		597.3
		Moisture Volume (mL)		

Volume H₂O Collected: 579.3 ml
X 0.048 = ft³ H₂O (Vwc)

DGM Final

DGM Initial _____ ft³

Final - Initial = ft³ (Yards)

$$\text{Moisture} = \frac{V_{wc}}{(V_{wc} + V_{mc})}$$

Moisture =

Moisture =

SOURCE TESTING FIELD DATA SHEET

Job No.: 121311006
 Client: CertainTeed
 Plant: N. Adam
 Location: Calcare
 Test: PM-3
 Date: Oct 27, 2015
 Operators: TB H/MGM
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 2.1783
 Start : 14:03
 Finish : 15:45

Static Pressure (in.H2O):
 Port Length (in): 211
 Stack Dia. (in.): 341
 Probe Length (ft): 3
 Nozzle ID (in.): 2-10 (A305)
 Console S/N: 1646

Pre-Test Leak Check: ✓
 Vacuum Pressure: -10
 Post-Test Leak Check: ✓
 Vacuum Pressure: -18

K': 5.20

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
0					375.86						
1	4	303	1.10	3.91	380.04	225	230	43	61	61	-1
2	8	306	1.70	3.91	384.30	225	231	33	61	61	-3
3	12	306	1.20	4.24	389.06	228	228	33	60	61	-3
4	16	306	1.25	4.42	393.29	231	229	36	61	61	-5
5	20	306	1.20	4.24	397.76	232	226	36	61	61	-4
6	24	306	1.15	4.06	402.13	231	225	30	63	61	-4
7	28	306	1.30	4.61	406.62	228	238	40	63	61	-4
8	32	307	1.20	4.26	411.08	231	237	43	60	62	-4
9	36	307	1.15	4.03	415.47	239	236	43	66	62	-4
10	40	307	1.10	3.90	420.11 *	227	237	43	66	62	-4
11	44	307	1.10	3.70	424.10	229	233	42	60	63	-4
12	48	307	1.00	3.55	428.21	230	236	45	68	63	-4
1	52	307	0.99	3.52	432.60 *	230	236	43	68	63	-4
2	56	306	0.98	3.49	436.00 *	237	230	46	68	63	-4
3	60	306	1.00	3.56	440.50	231	230	48	67	64	-4
4	64	306	1.10	3.92	444.79	230	230	48	67	64	-4
5	68	306	1.10	4.09	449.22	231	230	43	67	64	-4
6	72	306	1.20	4.27	453.75	225	239	48	67	64	-4
7	76	306	1.20	4.27	458.25	230	243	50	67	64	-4
8	80	306	1.20	4.30	462.75	230	243	52	68	64	-4
9	84	307	1.15	4.11	467.20	238	240	55	70	65	-5
10	88	307	1.10	3.93	471.40	230	230	55	70	65	-5
11	92	307	1.00	3.80	475.75	228	235	56	70	65	-5
12	96	308	0.98	3.50	479.79	244	232	56	70	65	-5

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811606

Client: Certain Tech

Plant: Mr Adams

Location: Calcium Mill

Test No.: 695# 3

Date: Oct 27, 2015

Fuel Type: No. 2 Fuel/oil

Time Start: 2:30

Time Finish: 3:00

Personnel: TSH/NGM

MOISTURE FIELD DATA SHEET

Project No.: 121811606
 Client: CURRENT-TED
 Plant: MCAODAM
 Location: ZONAL 1 DRYER
 Test: PM-1
 Date: OCT 25/2015
 Analyst: NLM



0922-24

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	974.8	735.6	239.2
2	100 mL H ₂ O	979.6	726.4	253.2
3	Blank	735.6	569.5	166.1
4	200g Silica Gel	984.0	959.5	24.5
		Total Weight Gain (g)		683.0
		Moisture Volume (mL)		683.0

Volume H₂O Collected: 683.0 ml
 $X 0.048 =$ 32.784 ft³ H₂O (Vwc)

DGM Final 164.79 ft³
 DGM Initial 95.45 ft³
 Final - Initial = 69.34 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = 0.321021503

Moisture = 32%

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CertainTeed
 Plant: McAdam
 Location: Zone 1 Dryer
 Test: PM-1
 Date: Oct 28, 2015
 Operators: N.C.M
 Gamma: 0.974
 Delta H@: 1.585
 Pitot Coeff.: 0.756
 Start: 13:52
 Finish:

Static Pressure (in.H2O): 0.2
 Port Length (in): 4"
 Stack Dia. (in.): 48"
 Probe Length (ft): 41
 Nozzle ID (in.): 2-10 (0.305)
 Console S/N: 1848

Pre-Test Leak Check: 0
 Vacuum Pressure: -20
 Post-Test Leak Check: 0
 Vacuum Pressure: -20

K': 5.31

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				95.45						
1	4	285	0.45	1.65	98.39	242	244	47	51	51	-1
2	8	284	0.45	1.65	101.39	240	247	47	51	51	-1
3	12	332	0.35	1.20	103.94	237	249	43	51	51	-1
4	16	341	0.35	1.19	106.51	237	245	44	53	51	-1
5	20	346	0.30	1.01	108.87	241	250	46	54	52	-1
6	24	339	0.47	1.60	111.78	245	249	47	56	52	-1
7	28	217	0.45	1.58	114.68	245	253	48	57	52	-1
8	32	295	0.44	1.60	117.66	248	255	50	59	53	-1
9	36	288	0.44	1.60	120.59	248	257	50	59	53	-2
10	40	283	0.39	1.43	123.40	240	254	60	61	54	-2
11	44	250	0.39	1.43	126.18	240	252	60	61	54	-2
12	48	278	0.39	1.43	128.99	240	257	63	61	54	-2
1	52	279	0.45	1.68	132.01	239	256	62	63	55	-2
2	56	280	0.45	1.68	135.04	240	256	65	63	55	-2
3	60	276	0.49	1.83	138.22	233	258	67	64	56	-2
4	64	276	0.49	1.83	141.49	232	256	68	63	56	-2
5	68	275	0.35	1.31	144.14 *	237	255	69	64	57	-2
6	72	274	0.35	1.31	146.90	237	255	60	64	57	-2
7	76	276	0.35	1.31	149.63	232	250	56	64	58	-2
8	80	276	0.35	1.31	152.32	230	253	55	64	56	-2
9	84	276	2.40	1.49	155.39	232	256	55	64	58	-2
10	88	276	0.43	1.49	158.15	232	256	55	64	59	-2
11	92	275	0.52	1.94	161.47	238	254	55	64	59	-3
12	96	276	0.52	1.94	164.79	238	256	55	64	59	-3

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 12-1811606

Client: CERTAINTECH

Plant: meadow

Location: On yr zone 1

Test No.: /

Date: Oct. 28 / 2015

Fuel Type: L

Time Start: 14:30

Time Finish: 15:00

Personnel: ✓G, ✓

MOISTURE FIELD DATA SHEET

Project No.: 121811606
 Client: GRANITE
 Plant: McADAM
 Location: DRYER ZONE 1
 Test: Pn-2
 Date: OCT 29 / 15
 Analyst: NM



0922-27

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1020.2	731.2	289
2	100 mL H ₂ O	1030.3	723.1	307.2
3	Blank	663.6	570.3	93.3
4	200g Silica Gel	1010.1	972.6	37.5
		Total Weight Gain (g)		727
		Moisture Volume (mL)		727

$$\text{Volume H}_2\text{O Collected: } \underline{727} \text{ ml}$$

$$X 0.048 = \underline{34.896} \text{ ft}^3 \text{ H}_2\text{O (Vwc)}$$

$$\text{DGM Final } \underline{216.18} \text{ ft}^3$$

$$\text{DGM Initial } \underline{164.96} \text{ ft}^3$$

$$\text{Final - Initial} = \underline{51.22} \text{ ft}^3 \text{ (Vmc)}$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \underline{0.405220864}$$

$$\text{Moisture} = \underline{40.5\%}$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CERTAINTED
 Plant: NAOM
 Location: DRYER 1 ZONE 1
 Test: PM 2
 Date: OCT 28/2015
 Operators: NL, M
 Gamma: 2.947
 Delta H@: 1.545
 Pitot Coeff.: 0.756
 Start: 9:55
 Finish: 11:45

Static Pressure (in.H2O): 0.3
 Port Length (in): 4
 Stack Dia. (in.): 44
 Probe Length (ft): 4
 Nozzle ID (in.): 2-10 (0.305)
 Console S/N: 1845

Pre-Test Leak Check: 0
 Vacuum Pressure: -20
 Post-Test Leak Check: 0
 Vacuum Pressure: -20

K': 3.48

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
0					164.96						
1	4	340	0.35	0.80	167.01	225	225	53	65	65	-1
2	8	256	0.35	0.78	169.08	225	228	42	66	65	-1
3	12	350	0.35	0.78	170.94	225	225	42	66	65	-1
4	16	344	0.35	0.80	172.93	225	228	42	67	65	-1
5	20	308	0.35	0.83	174.92	225	230	41	67	66	-1
6	24	304	0.35	0.83	176.93	226	228	41	67	66	-1
7	28	297	0.40	0.96	179.12	225	229	43	67	66	-1
8	32	296	0.40	0.94	181.30	225	230	43	67	66	-1
9	36	296	0.35	0.85	183.38	225	228	46	68	66	-1
10	40	295	0.35	0.85	185.45	230	232	46	69	66	-1
11	44	295	0.35	0.85	187.50	228	230	46	69	66	-1
12	48	294	0.35	0.85	189.55	225	225	48	70	67	-1
1	52	297	0.35	0.85	191.62	225	220	50	70	67	-1
2	56	296	0.35	0.85	193.66	228	230	50	71	67	-1
3	60	296	0.40	0.98	195.90	225	228	50	71	67	-1
4	64	295	0.40	0.98	198.15	225	228	50	71	68	-1
5	68	295	0.42	1.03	200.43	225	227	51	72	68	-1
6	72	293	0.42	1.03	202.76	228	230	52	72	68	-1
7	76	291	0.35	0.86	205.97	228	220	52	72	68	-1
8	80	292	0.35	0.86	207.05	225	225	56	72	69	-1
9	84	293	0.35	0.86	209.13	225	228	56	72	69	-1
10	88	294	0.40	0.98	211.38	225	230	56	72	69	-2
11	92	294	0.40	0.98	213.66	225	229	56	72	69	-2
12	96	294	0.40	0.98	216.18	228	230	56	72	69	-2

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121411606

Client: CERTAINTED

Plant: McAdam

Location: DRYER ZONE I

Test No.: 2

Date: Oct 29 / 2015

Fuel Type: #2

Time Start: 10:00

Time Finish: 10:30

Personnel: ~4~

MOISTURE FIELD DATA SHEET

0922-25

Project No.: 121811606
 Client: CERTAIN TEZCO
 Plant: M. ADAM
 Location: ZONE 1 DRYER
 Test: PM-3
 Date: OCT 29
 Analyst: NGM



Stantec

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1029.7	724.0	
2	100 mL H ₂ O	1028.5	715.5	
3	Blank	595.4	572.2	
4	200g Silica Gel	987.1	974.5	
		Total Weight Gain (g)		
		Moisture Volume (mL)		

Volume H₂O Collected: _____ ml

X 0.048 = _____ ft³ H₂O (V_{wc})

DGM Final _____ ft³

DGM Initial _____ ft³

Final - Initial = _____ ft³ (V_{mc})

Moisture = $\frac{V_{wc}}{(V_{wc} + V_{mc})}$

Moisture = _____

Moisture = _____

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CERTAINTEED
 Plant: MCADAM
 Location: DRY ZONE #1
 Test: PM 3
 Date: OCT 29 / 15
 Operators: NHM
 Gamma: 0.947
 Delta H@: 1.585
 Pitot Coeff.: 0.756
 Start: 13:20
 Finish:

Static Pressure (in.H2O): 0.25
 Port Length (in): 4
 Stack Dia. (in.): .78
 Probe Length (ft): 4
 Nozzle ID (in.): 2-10 (0.305)
 Console S/N: 1844

Pre-Test Leak Check: 0
 Vacuum Pressure: -20
 Post-Test Leak Check: 0
 Vacuum Pressure: -20

K': 2.81

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (In.Hg)
									In	Out	
0					217.00						
1	4	290	0.2	0.40	218.44	225	225	55	68	68	-1
2	8	290	0.2	0.40	219.90	235	229	50	68	68	-1
3	12	288	0.25	0.49	221.53	240	239	43	68	68	-1
4	16	289	0.25	0.49	223.15	243	242	43	68	68	-1
5	20	290	0.25	0.50	224.77	246	244	43	69	68	-1
6	24	288	0.25	0.50	226.42	244	246	43	69	68	-1
7	28	288	0.25	0.50	228.06	246	247	45	69	68	-1
8	32	291	0.30	0.59	229.91	250	249	45	69	68	-1
9	36	291	0.30	0.59	231.74	252	254	46	69	68	-1
10	40	290	0.30	0.59	233.51	252	252	48	69	68	-1
11	44	291	0.30	0.59	235.30	249	252	48	69	68	-1
12	48	289	0.30	0.59	237.12	247	254	49	69	68	-1
1	52	288	0.30	0.59	238.93	250	260	51	70	68	-1
2	56	290	0.30	0.59	240.75	254	258	52	70	68	-1
3	60	290	0.35	0.69	242.76	252	259	52	69	67	-1
4	64	289	0.35	0.69	244.89	252	258	52	69	67	-1
5	68	289	0.35	0.69	246.75	253	259	52	69	67	-1
6	72	288	0.35	0.69	248.68	256	260	52	69	67	-1
7	76	288	0.35	0.69	250.76	256	258	52	69	67	-1
8	80	289	0.35	0.69	252.80	257	247	49		67	-1
9	84	288	0.35	0.69	254.84	236	247	48	7	67	-1
10	88	288	0.35	0.69	256.91	226	243	48	70	67	-2
11	92	288	0.35	0.69	258.87	227	245	48	70	67	-2
12	96	288	0.30	0.60	260.73	231	243	48	70	67	-2

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 121811606

Client: CONSTRAINT FCB

Plant: McAdam

Location: Dry or Zone 1

Test No.: 3

Date: OCT. 29/2015

Fuel Type: L

Time Start: 13:30

Time Finish: 14:00

Personnel: None

MOISTURE FIELD DATA SHEET

Project No.: 121811606
 Client: Certainteed
 Plant: Mc Adam
 Location: Zone 2 Dryer
 Test: PM-1
 Date: Oct 28 2015
 Analyst: TB14



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1029.8	680.4	349.4
2	100 mL H ₂ O	1035.6	691.8	343.8
3	Blank	849.2	664.2	185.0
4	200g Silica Gel	1058.2	1033.7	24.5
		Total Weight Gain (g)		902.7
		Moisture Volume (mL)		902.7

$$\begin{aligned} \text{Volume H}_2\text{O Collected: } & 902.7 \text{ ml} \\ \times 0.048 = & 43.33 \text{ ft}^3 \text{ H}_2\text{O (Vwc)} \end{aligned}$$

$$\begin{aligned} \text{DGM Final } & 524.41 \text{ ft}^3 \\ \text{DGM Initial } & 524.41 \text{ ft}^3 \\ \text{Final - Initial } = & \text{ ft}^3 (\text{Vmc}) \end{aligned}$$

$$\text{Moisture} = \frac{\text{Vwc}}{(\text{Vwc} + \text{Vmc})}$$

$$\text{Moisture} = \underline{\hspace{2cm}}$$

$$\text{Moisture} = \underline{\hspace{2cm}}$$

SOURCE TESTING FIELD DATA SHEET

Job No.: 121811606
 Client: CertainTeed
 Plant: ~~AA~~ Zone 2 Dryer
 Location: McAdam, NB
 Test: PM-1
 Date: August 28, 2015
 Operators: TBH / AW
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.788
 Start :
 Finish :

Static Pressure (in.H2O): 0.20
 Port Length (in): 4"
 Stack Dia. (in.): 48"
 Probe Length (ft): 6'
 Nozzle ID (in.): 1-10 (0.506)
 Console S/N: 1046

Pre-Test Leak Check: ✓
 Vacuum Pressure: -18
 Post-Test Leak Check: ✓
 Vacuum Pressure: -18

K': 3.74

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (In.Hg)
									In	Out	
	0				493.94						
1	4	241	0.26	0.71	495.80	225	241	50	55	54	
2	8	242	0.31	0.84	497.72	226	242	50	55	54	
3	12	247	0.55	1.50	500.22	227	243	50	55	54	
4	16	238	0.60	1.105	503.02	228	246	51	56	54	
5	20	242	0.65	1.73	505.93	228	250	51	56	54	
6	24	242	0.74	2.03	509.08	230	248	51	56	55	
7	28	238	0.77	2.12	512.28	232	256	51	56	55	
8	32	241	0.64	1.76	515.32	233	249	52	56	55	
9	36	241	0.50	1.37	517.67	239	248	52	56	55	
10	40	247	0.54	1.49	520.52	239	250	52	57	55	
11	44	242	0.48	1.31	523.07	238	249	52	57	55	
12	48	248	0.32	0.87	525.12	239	251	53	57	56	
1	51	240	0.34	0.93	527.30	241	251	53	58	56	
2	56	246	0.47	1.29	529.84	242	260	50	58	56	
3	60	240	0.50	1.34	521.95	242	257	48	58	56	
4	64	241	0.100	1.65	534.59	241	258	47	58	56	
5	68	242	0.65	1.79	537.28	242	258	47	58	56	
6	72	242	0.65	1.79	540.31	242	251	47	58	56	
7	76	242	0.72	1.98	543.23	242	249	47	58	56	
8	80	242	0.74	2.03	546.38	242	250	48	58	56	
9	84	247	0.64	1.76	549.37	238	248	48	59	56	
10	88	241	0.52	1.73	552.02	239	247	43	59	57	
11	92	241	0.40	1.13	554.27	239	240	43	59	58	
12	96	243	0.35	0.96	556.43	235	239	42	59	58	

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Stantec

Project No.: 1218116.06

Client: Certainfield

Plant: Mc Adam

Location: Zone 2 Dryer

Test No.: Gas #1

Date: Oct 23, 2015

Fuel Type: #2 Fuel Oil

Time Start: 3:00

Time Finish: 3:30

Personnel: TB/H

MOISTURE FIELD DATA SHEET

0922-23

Project No.: 121811606
 Client: Certain teal
 Plant: Mc Adams
 Location: Zone 2 Dryer
 Test: PM - 2
 Date: Oct 28, 2015
 Analyst: TB14



Stantec

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1038.4	695.3	343.1
2	100 mL H ₂ O	1011.6	719.0	291.8
3	Blank	913.3	663.8	249.5
4	200g Silica Gel	1033.6	1009.0	24.6
		Total Weight Gain (g)		909.0
		Moisture Volume (mL)		909

Volume H₂O Collected: 909 ml
 $X 0.048 = \underline{43.632}$ ft³ H₂O (V_{wc})

DGM Final 619.18 ft³
 DGM Initial 556.67 ft³
 Final - Initial = 62.56 ft³ (V_{mc})

Moisture = $\frac{V_{wc}}{(V_{wc} + V_{mc})}$ 0.06192

Moisture = 0.41087841

Moisture = 41%

SOURCE TESTING FIELD DATA SHEET

Job No.: 1218116006
 Client: CertainTeed
 Plant: McAdam
 Location: Bone 2 Dryer
 Test: PM-2
 Date: Oct 28, 2005
 Operators: TBH
 Gamma: 1.033
 Delta H@: 1.712
 Pitot Coeff.: 0.788
 Start : 11:05
 Finish :

Static Pressure (in.H2O): 0.20
 Port Length (in): 4'
 Stack Dia. (in.): 4.5"
 Probe Length (ft): 6'
 Nozzle ID (in.): 1-10 (0.306)
 Console S/N: 6646

Pre-Test Leak Check: ✓
 Vacuum Pressure: -13
 Post-Test Leak Check:
 Vacuum Pressure: -13

K': 3.74

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft) 55	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
0					5 550.662 215	215	215	215			
1	4	251	0.25	0.68	558.48	225	225	52	56	56	-1
2	9	248	0.30	0.82	559.39	225	226	45	57	56	-1
3	12	247	0.55	1.49	561.90	237	235	47	57	56	-2
4	16	241	0.59	1.63	564.70	238	233	51	58	57	-2
5	20	239	0.68	1.98	567.61	237	231	41	58	56	-2
6	24	238	0.75	2.08	570.77	239	227	41	58	56	-2
7	29	241	0.76	2.10	573.96	240	227	42	58	57	-2
8	32	241	0.65	1.79	577.00	240	228	44	61	57	-3
9	36	241	0.50	1.38	580.34 *	240	233	44	61	57	-3
10	40	241	0.53	1.46	582.20	238	232	49	62	57	-3
11	44	241	0.45	1.24	584.72	234	235	50	62	58	-3
12	48	241	0.30	0.83	587.00 *	234	231	51	62	58	-3
1	52	241	0.35	0.97	588.94	236	232	51 51	62	58	-3
2	56	241	0.44	1.27	591.35	236	235	52	61	58	-3
3	60	242	0.51	1.41	593.99	237	236	52	62	58	-3
4	64	241	0.58	1.61	596.68	241	242	51	62	58	-3
5	68	241	0.67	1.86	599.73	240	238	52	63	58	-3
6	72	241	0.65	1.80	602.64	240	241	52	63	58	-3
7	76	241	0.71	1.97	605.78	240	240	52	63	58	-3
8	80	241	0.76	2.11	609.00	242	246	57	63	58	-3
9	84	242	0.64	1.78	611.99	243	240	57	63	58	-3
10	88	242	0.74	1.50	614.90 *	243	238	53	64	59	-3
11	92	243	0.41	1.13	617.05	246	237	53	64	59	-4
12	96	242	0.33	0.91	619.10	248	247	54	64	59	-4

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Project No.: 121811606
Client: Certainteed
Plant: Zinc Flak Dryer
Location: McAdam

Test No.: Gas #2
Date: Nov 29, 2015

Fuel Type: #2 Fuel Oil

Time Start: 11:30

Personnel: TBH

MOISTURE FIELD DATA SHEET

0922-21

Project No.: 121811606
 Client: CERTAIN TEED
 Plant: McADAM
 Location: ZONE 2 DRYER
 Test: PM-03
 Date: OCT 29/2015
 Analyst: TBH



Stantec

Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1038.7	685.0	353.7
2	100 mL H ₂ O	1020.5	692.2	328.3
3	Blank	851.7	664.1	186.6
4	200g Silica Gel	1060.2	1033.2	27.0
		Total Weight Gain (g)		895.6
		Moisture Volume (mL)		895.6

Volume H₂O Collected: 895.6 ml
 $X 0.048 = \underline{42.9888}$ ft³ H₂O (V_{wc})

DGM Final 681.78 ft³
 DGM Initial 619.38 ft³
 Final - Initial = 62.4 ft³ (V_{mc})

Moisture = $\frac{V_{wc}}{(V_{wc} + V_{mc})}$

Moisture = 0.407906722

Moisture = 40.7%

SOURCE TESTING FIELD DATA SHEET

Job No.: 14811606
 Client: Carteret
 Plant: M. Adams
 Location: Zone 2 Dryer
 Test: PM-3
 Date: Oct 29, 2015
 Operators: TGH
 Gamma: 1.073
 Delta H@: 1.717
 Pitot Coeff.: 0.792
 Start : 19:15
 Finish :

Static Pressure (in.H2O): 0.2
 Port Length (in): 4"
 Stack Dia. (in.): 48"
 Probe Length (ft): 16'
 Nozzle ID (in.): 1-10 (0.306")
 Console S/N: 1646

Pre-Test Leak Check: ✓
 Vacuum Pressure: -13
 Post-Test Leak Check: ✓
 Vacuum Pressure: -18

K: 3.25

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (In.Hg)
									In	Out	
0					619.38						
1	4	243	0.30	0.72	621.31	225	226	55	58	58	-1
2	8	243	0.48	1.15	623.68	231	234	52	60	59	-1
3	12	243	0.51	1.22	626.14	227	235	55	60	59	-1
4	16	242	0.58	1.39	628.75	228	240	54	61	59	-1
5	20	243	0.63	1.51	631.50	228	225	54	62	59	-1
6	24	243	0.68	1.63	634.34	229	236	57	63	59	-2
7	28	242	0.71	1.71	637.24	227	236	57	64	59	-2
8	32	242	0.80	1.93	640.13	228	239	57	64	60	-2
9	36	243	0.82	1.98	643.29	232	241	57	64	61	-3
10	40	242	0.68	1.64	646.15	228	242	57	64	61	-3
11	44	242	0.50	1.21	648.61	227	242	57	66	60	-3
12	48	241	0.38	0.92	650.77	227	239	57	65	60	-3
					779	240	58	65	60		
1	52	242	0.38	0.92	652.97	229	240	58	65	60	-2
2	56	241	0.45	1.08	655.24	231	245	56	65	60	-2
3	60	241	0.56	1.36	657.95*	235	244	55	65	60	-2
4	64	242	0.63	1.52	660.40	231	241	56	66	61	-2
5	68	242	0.70	1.69	663.27	227	244	56	66	61	-2
6	72	241	0.75	1.81	666.210	227	243	56	65	60	-3
7	76	242	0.80	1.93	669.601*	226	242	55	67	61	-3
8	80	243	0.69	1.67	672.28	227	248	55	68	63	-3
9	84	245	0.58	1.40	674.95	228	245	56	69	64	-3
10	88	246	0.52	1.26	677.24*	227	240	56	69	64	-4
11	92	246	0.48	1.15	679.75	229	242	55	68	63	-3
12	96	03246	0.33	0.79	681.78	228	243	55	68	63	-2

COMBUSTION GAS ANALYSIS CONCENTRATION FIELD SHEET

Sampling Methodology: Environment Canada EPS 1/RM/15



Project No.: 121911606
Client: Certainteed
Plant: Zone 2 Dryer
Location: McAdam

Test No.: Gas # 3
Date: Nov 29 2015

Fuel Type: # 2 Fuel Oil

Time Start: 2:30

Time Finish: 3:00

**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

APPENDIX F
Field Data Sheets



**Source Emissions Testing 2015 – CertainTeed Gypsum Wallboard Plant, McAdam,
New Brunswick**

December 16, 2015

Raw Data for: CertainTeed Rock Dryer PM data

Test #1

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-1
Date: 20-Oct-15
Personnel: JJB/NGM

Test Start: 10:30 AM
Test Finish: 12:15 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg): 0.1
Particulate Collected from Probe Wash (mg): 1.7
Particulate Collected from Impinger Wash (mg): 0.1
Total Particulate Collected (mg): 2.0

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	789.2	704.4	84.8
2	100 mL H2O	726.5	702.1	24.4
3	Blank	667.0	660.9	6.1
4	200g Silica Gel	995.5	986.1	9.4
			Total Weight Gain (g)	124.7
			Moisture Volume (mL)	124.7

29.90
0.20
48
124.7
24
4
4
NBDELG

O2, (%) 19.7
CO2, (%) 0.7
N2, (%) 79.6
CO(ppm) 9.7
NOx (ppm) 10.0
SO2 (ppm) 0.7

Stack Diameter, (in.) 36.00
Stack Area, (sq. ft.) 7.07
Probe Length, (ft.) 3
Nozzle Diameter, (in.) 0.234
Pitot Coefficient, (Cp) 0.791
Gamma, meter constant 1.033
Port length (in.) 4.000

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	151	0.47	0.89	28.130	56 55
	2	8	151	0.53	1.00	30.370	56 56
	3	12	153	0.45	0.85	32.580	57 55
	4	16	155	0.44	0.83	34.640	57 55
	5	20	152	0.46	0.87	36.670	58 55
	6	24	148	0.46	0.87	38.800	58 55
	7	28	146	0.48	0.91	40.920	59 55
	8	32	146	0.49	0.93	43.090	58 56
	9	36	144	0.48	0.91	45.250	60 56
	10	40	134	0.50	0.97	47.445	60 57
	11	44	130	0.48	0.94	49.650	60 57
	12	48	130	0.48	0.94	51.800	59 57
Traverse 2	1	52	130	0.48	0.94	53.990	59 56
	2	56	131	0.50	0.98	56.190	60 57
	3	60	133	0.50	0.98	58.400	59 56
	4	64	134	0.48	0.94	60.587	59 56
	5	68	138	0.51	0.99	62.780	59 56
	6	72	141	0.49	0.95	64.980	59 56
	7	76	143	0.49	0.95	67.140	59 56
	8	80	143	0.49	0.95	69.310	60 56
	9	84	141	0.46	0.89	71.410	60 57
	10	88	143	0.50	0.97	73.610	60 57
	11	92	148	0.50	0.95	75.760	60 57
	12	96	151	0.46	0.88	77.870	60 57

Calculations for: CertainTeed Rock Dryer PM data
Test #1

Client: CertainTeed
 Job Number: 121811606

Plant: Rock Dryer Stack
 Location: McAdam, NB
 Test: PM-1
 Date: 20-Oct-15
 Personnel: JJB/NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)
 Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
 Volume of Water Vapour Collected, Vvc (cu.ft)
 Stack Gas Moisture Content (% as decimal)
 Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)

29.91
 28.90
 5.986
 0.097
 27.84

Isokineticity Checks

Check range
 Check average
 Within Criteria
 Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	611	0.47	0.89	39.63	29.97	516	2.100	2.263
	2	8	611	0.53	1.00	42.09	29.97	516	2.240	2.412
	3	12	613	0.45	0.85	38.85	29.96	516	2.210	2.379
	4	16	615	0.44	0.83	38.47	29.96	516	2.060	2.218
	5	20	612	0.46	0.87	39.24	29.96	517	2.030	2.183
	6	24	608	0.46	0.87	39.11	29.96	517	2.130	2.291
	7	28	606	0.48	0.91	39.89	29.97	517	2.120	2.278
	8	32	606	0.49	0.93	40.30	29.97	517	2.170	2.332
	9	36	604	0.48	0.91	39.82	29.97	518	2.160	2.317
	10	40	594	0.50	0.97	40.31	29.97	519	2.195	2.352
	11	44	590	0.48	0.94	39.36	29.97	519	2.205	2.363
	12	48	590	0.48	0.94	39.36	29.97	518	2.150	2.306
Traverse 2	1	52	590	0.48	0.94	39.36	29.97	518	2.190	2.351
	2	56	591	0.50	0.98	40.21	29.97	519	2.200	2.358
	3	60	593	0.50	0.98	40.27	29.97	518	2.210	2.373
	4	64	594	0.48	0.94	39.49	29.97	518	2.187	2.348
	5	68	598	0.51	0.99	40.85	29.97	518	2.193	2.355
	6	72	601	0.49	0.95	40.14	29.97	518	2.200	2.362
	7	76	603	0.49	0.95	40.20	29.97	518	2.160	2.319
	8	80	603	0.49	0.95	40.20	29.97	518	2.170	2.328
	9	84	601	0.46	0.89	38.89	29.97	519	2.100	2.250
	10	88	603	0.50	0.97	40.61	29.97	519	2.200	2.358
	11	92	608	0.50	0.95	40.78	29.97	519	2.150	2.304
	12	96	611	0.46	0.88	39.21	29.96	519	2.110	2.261
Total		Average 96	Average 602	Average 0.48	Average 0.93	Average 39.86	Average 29.97	Total 51.840	Total 55.662	Average 100.88

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-1
Date: 20-Oct-15
Personnel: JJB/NGM

Test Start: 10:15 AM
Test Finish: 10:45 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	19.9	0.6	16.0	1.0	13.0	0.0	13
5	19.9	0.6	11.0	1.0	14.0	0.0	14
10	19.8	0.7	7.0	1.0	16.0	0.0	16
15	19.8	0.6	9.0	1.0	15.0	0.0	15
20	19.6	0.8	11.0	0.0	4.0	0.0	4
25	19.6	0.8	7.0	1.0	4.0	0.0	4
30	19.6	0.7	7.0	0.0	4.0	0.0	4
Average:		19.7	0.7	9.7	0.7	10.0	0.0
							10

Raw Data for: CertainTeed Rock Dryer PM data

Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-2
Date: 20-Oct-15
Personnel: JJB/NGM

Test Start: 12:45 PM
Test Finish: 2:45 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg): 0.0
Particulate Collected from Probe Wash (mg): 0.0
Particulate Collected from Impinger Wash (mg): 1.0
Total Particulate Collected (mg): 1.0

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	784.6	692.2	92.4
2	100 mL H2O	716.8	701.5	15.3
3	Blank	665.4	662.1	3.3
4	200g Silica Gel	1005.7	995.5	10.2
			Total Weight Gain (g)	121.2
			Moisture Volume (mL)	121.2

29.80
0.20
53
121.2
24
4
4
NBDELG

O2, (%) 19.6
CO2, (%) 0.9
N2, (%) 79.5
CO(ppm) 13.9
NOx (ppm) 3.1
SO2 (ppm) 0.0

Stack Diameter, (in.) 36.00
Stack Area, (sq. ft.) 7.07
Probe Length, (ft.) 3
Nozzle Diameter, (in.) 0.234
Pitot Coefficient, (Cp) 0.791
Gamma, meter constant 1.033
Port length (in.) 4

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	144	0.39	0.75	80.480	56
	2	8	146	0.38	0.71	82.420	57
	3	12	158	0.38	0.70	84.310	57
	4	16	152	0.42	0.80	86.360	59
	5	20	150	0.42	0.80	88.330	60
	6	24	148	0.40	0.76	90.370	60
	7	28	138	0.38	0.74	92.200	62
	8	32	135	0.38	0.74	94.150	62
	9	36	135	0.42	0.82	96.160	62
	10	40	135	0.42	0.82	98.200	62
	11	44	134	0.40	0.78	100.250	62
	12	48	134	0.40	0.78	102.240	58
Traverse 2	1	52	135	0.42	0.82	104.240	62
	2	56	136	0.37	0.73	106.430	63
	3	60	141	0.35	0.68	108.030	63
	4	64	146	0.35	0.68	109.890	63
	5	68	148	0.38	0.73	111.830	65
	6	72	150	0.38	0.73	113.590	65
	7	76	150	0.64	0.73	115.830	65
	8	80	151	0.42	0.81	117.700	65
	9	84	149	0.42	0.81	119.740	67
	10	88	145	0.42	0.81	121.750	67
	11	92	138	0.35	0.69	123.630	67
	12	96	136	0.35	0.69	125.500	67

Calculations for: CertainTeed Rock Dryer PM data
Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-2
Date: 20-Oct-15
Personnel: JJB/NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	29.81
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	28.92
Volume of Water Vapour Collected, Vvc (cu.ft)	5.818
Stack Gas Moisture Content (% as decimal)	0.104
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	27.78

Isokineticity Checks

Check range
Check average
Within Criteria
Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	604	0.39	0.75	35.99	29.86	516	1.930	2.070
	2	8	606	0.38	0.71	35.59	29.85	517	1.940	2.079
	3	12	618	0.38	0.70	35.94	29.85	517	1.890	2.025
	4	16	612	0.42	0.80	37.60	29.86	518	2.050	2.193
	5	20	610	0.42	0.80	37.54	29.86	519	1.970	2.103
	6	24	608	0.40	0.76	36.57	29.86	519	2.040	2.178
	7	28	598	0.38	0.74	35.35	29.85	520	1.830	1.948
	8	32	595	0.38	0.74	35.26	29.85	520	1.950	2.076
	9	36	595	0.42	0.82	37.07	29.86	520	2.010	2.140
	10	40	595	0.42	0.82	37.07	29.86	520	2.040	2.172
	11	44	594	0.40	0.78	36.15	29.86	520	2.050	2.182
	12	48	594	0.40	0.78	36.15	29.86	520	1.990	2.118
Traverse 2	1	52	595	0.42	0.82	37.07	29.86	520	2.000	2.129
	2	56	596	0.37	0.73	34.83	29.85	521	2.190	2.327
	3	60	601	0.35	0.68	34.01	29.85	521	1.600	1.700
	4	64	606	0.35	0.68	34.16	29.85	521	1.860	1.976
	5	68	608	0.38	0.73	35.65	29.85	523	1.940	2.053
	6	72	610	0.38	0.73	35.71	29.85	523	1.760	1.863
	7	76	610	0.64	0.73	46.27	29.85	523	2.240	2.371
	8	80	611	0.42	0.81	37.57	29.86	523	1.870	1.979
	9	84	609	0.42	0.81	37.51	29.86	525	2.040	2.151
	10	88	605	0.42	0.81	37.38	29.86	525	2.010	2.119
	11	92	598	0.35	0.69	33.93	29.85	525	1.880	1.982
	12	96	596	0.35	0.69	33.87	29.85	525	1.870	1.971
Total	96	Average 603	Average 0.40	Average 0.75	Average 36.43	Average 29.86	Average 521	Total 46.950	Total 49.905	Average 100.34

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB

Test: PM-2

Date: 20-Oct-15

Personnel: JJB/NGM

Test Start: 1:00 PM

Test Finish: 1:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)	
0	19.7	0.7	11.0	0.0	3.0	0.0	3	
5	19.6	0.8	15.0	0.0	3.0	0.0	3	
10	19.5	1.0	23.0	0.0	4.0	0.0	4	
15	19.7	0.7	10.0	0.0	3.0	0.0	3	
20	19.6	0.8	9.0	0.0	2.0	0.0	2	
25	19.6	1.0	13.0	0.0	4.0	0.0	4	
30	19.5	1.0	16.0	0.0	3.0	0.0	3	
Average:		19.6	0.9	13.9	0.0	3.1	0.0	3

Raw Data for: CertainTeed Rock Dryer PM data

Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-3
Date: 21-Oct-15
Personnel: JJB/NGM

Test Start: 10:30 AM
Test Finish: 12:10 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg):	0.0
Particulate Collected from Probe Wash (mg):	1.2
Particulate Collected from Impinger Wash (mg):	1.5
Total Particulate Collected (mg):	2.7

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	765.5	697.9	67.6
2	100 mL H2O	714.6	703.3	11.3
3	Blank	663.6	661.5	2.1
4	200g Silica Gel	1015.2	1005.7	9.5

Total Weight Gain (g)
Moisture Volume (mL)

30.20	O2, (%)	19.7
0.20	CO2, (%)	0.7
45.60	N2, (%)	79.6
90.50	CO(ppm)	10.3
24	NOx (ppm)	7.6
4	SO2 (ppm)	0.0

Stack Diameter, (in.)	36.00
Stack Area, (sq. ft.)	7.07
Probe Length, (ft.)	3
Nozzle Diameter, (in.)	0.234
Pitot Coefficient, (Cp)	0.791
Gamma, meter constant	1.033
Port length (in.)	4

NBDELG

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	115	0.50	1.00	125.740	
	2	8	117	0.46	0.92	127.930	56
	3	12	118	0.44	0.88	130.070	58
	4	16	121	0.44	0.88	132.180	58
	5	20	121	0.47	0.94	134.320	58
	6	24	121	0.42	0.84	136.450	59
	7	28	121	0.44	0.88	138.480	57
	8	32	122	0.46	0.92	140.560	60
	9	36	127	0.44	0.87	142.710	61
	10	40	134	0.45	0.88	144.770	58
	11	44	140	0.42	0.81	146.880	61
	12	48	142	0.43	0.83	148.890	59
Traverse 2	1	52	143	0.43	0.83	150.920	
	2	56	141	0.44	0.86	152.960	63
	3	60	139	0.45	0.88	155.030	63
	4	64	136	0.45	0.86	157.120	63
	5	68	134	0.45	0.88	159.210	64
	6	72	132	0.47	0.92	161.320	64
	7	76	130	0.43	0.85	163.490	64
	8	80	128	0.46	0.91	165.530	64
	9	84	128	0.44	0.87	167.670	65
	10	88	127	0.46	0.91	169.760	62
	11	92	126	0.46	0.91	171.940	65
	12	96	127	0.45	0.89	174.090	66
					176.200	66	62

Calculations for: CertainTeed Rock Dryer PM data

Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-3
Date: 21-Oct-15
Personnel: JJB/NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	30.21
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	28.90
Volume of Water Vapour Collected, Vwc (cu.ft)	4.344
Stack Gas Moisture Content (% as decimal)	0.074
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	28.09

Isokineticity Checks

Check range	Within Criteria
Check average	Within Criteria

	Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	575	0.50	1.00	39.28	30.27	516	2.190	2.382	96.89
	2	8	577	0.46	0.92	37.75	30.27	517	2.140	2.323	98.67
	3	12	578	0.44	0.88	36.95	30.26	518	2.110	2.288	99.45
	4	16	581	0.44	0.88	37.04	30.26	518	2.140	2.320	101.13
	5	20	581	0.47	0.94	38.29	30.27	518	2.130	2.308	97.31
	6	24	581	0.42	0.84	36.19	30.26	519	2.030	2.197	97.99
	7	28	581	0.44	0.88	37.04	30.26	519	2.080	2.249	98.01
	8	32	582	0.46	0.92	37.91	30.27	520	2.150	2.322	99.08
	9	36	587	0.44	0.87	37.23	30.26	520	2.060	2.225	97.47
	10	40	594	0.45	0.88	37.88	30.26	520	2.110	2.279	99.31
	11	44	600	0.42	0.81	36.78	30.26	521	2.010	2.164	98.11
	12	48	602	0.43	0.83	37.28	30.26	521	2.030	2.186	98.10
Traverse 2	1	52	603	0.43	0.83	37.31	30.20	522	2.040	2.190	98.37
	2	56	601	0.44	0.86	37.68	30.26	522	2.070	2.227	98.71
	3	60	599	0.45	0.88	38.04	30.26	522	2.090	2.249	98.40
	4	64	596	0.45	0.86	37.94	30.26	522	2.090	2.247	98.06
	5	68	594	0.45	0.88	37.88	30.26	523	2.110	2.266	98.73
	6	72	592	0.47	0.92	38.65	30.26	523	2.170	2.330	99.19
	7	76	590	0.43	0.85	36.90	30.27	523	2.040	2.191	97.34
	8	80	588	0.46	0.91	38.10	30.26	524	2.140	2.294	98.35
	9	84	588	0.44	0.87	37.27	30.27	524	2.090	2.240	98.22
	10	88	587	0.46	0.91	38.07	30.26	524	2.180	2.337	100.11
	11	92	586	0.46	0.91	38.04	30.27	524	2.150	2.302	98.56
	12	96	587	0.45	0.89	37.65	30.27	524	2.110	2.260	97.88
	Total	96	Average 589	Average 0.45	Average 0.88	Average 37.63	Average 30.26	Average 521	Total 50.460	Total 54.375	Average 98.48

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Rock Dryer Stack
Location: McAdam, NB
Test: PM-3
Date: 21-Oct-15
Personnel: JJB/NGM

Test Start: 10:30 AM
Test Finish: 11:00 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	19.8	0.6	11.0	0.0	9.0	0.0	9
5	19.9	0.6	11.0	0.0	9.0	0.0	9
10	19.7	0.7	12.0	0.0	8.0	0.0	8
15	19.7	0.7	8.0	0.0	9.0	0.0	9
20	19.6	0.7	8.0	0.0	7.0	0.0	7
25	19.6	0.7	10.0	0.0	7.0	0.0	7
30	19.6	0.7	12.0	0.0	4.0	0.0	4
Average:		19.7	0.7	10.3	0.0	7.6	0.0
							8

DATA ENTRY

CertainTeed

McAdam, NB

Fuel: # 2 Fuel oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 7 m

Stack Diameter: 0.9 m

Reference Temperature, Tref (F): 77
(K): 298
Reference Pressure, Pref (in.Hg): 29.92
(Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	20-Oct-15	20-Oct-15	21-Oct-15	n/a
Start Time	-	-	10:30 AM	12:45 PM	10:30 AM	n/a
End Time	-	-	12:15 PM	2:45 PM	12:10 PM	n/a
Total Sampling Time	-	min	96	96	96	96
Stack Diameter	D	in.	36	36	36	36
Average Stack Gas Temperature	Ts	F	142	143	129	138
Average Dry Gas Meter Temperature	Tm	F	57	61	61	60
Barometric Pressure	Pbar	in.Hg	29.90	29.80	30.20	29.97
Stack Static Pressure	Pstatic	in.H2O	0.20	0.20	0.20	0.20
Average Pressure Drop (Head)	dP	in.H2O	0.48	0.40	0.45	0.44
Average deltaH Orifice	dH	in.H2O	0.93	0.75	0.88	0.86
Average Meter Temperature	Tm	F	57	61	61	60
Gas Sample Volume	Vm	cu.ft	51.84	46.95	50.46	49.75
Average Isokinetics	I	%	100.88	100.34	98.48	99.90
Nozzle Diameter	Dn	in.	0.234	0.234	0.234	0.234
Pitot Coefficient	Cp	-	0.791	0.791	0.791	0.791
Gamma, meter constant	y	-	1.033	1.033	1.033	1.033
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	19.7	19.6	19.7	19.7
Stack Gas Carbon Dioxide Content	Cco2	%	0.7	0.9	0.7	0.7
Stack Gas Nitrogen Content	Cn2	%	79.6	79.5	79.6	79.6
Stack Gas Sulphur Dioxide Content	Cso2	ppm	0.7	0.0	0.0	0.2
Stack Gas Nitrogen Oxides Content	Cnox	ppm	10.0	3.1	7.6	6.9
Stack Gas Carbon Monoxide Content	Cco	ppm	9.7	13.9	10.3	11.3
Volume of Water Collected	Vw	mL	124.7	121.2	90.5	112.1
Particulate Collected from Filter	-	mg	0.1	0.0	0.0	0.0
Particulate Collected from Probe Wash	-	mg	1.7	0.0	1.2	1.0
Particulate Collected from Impinger Wash	-	mg	0.11	1.02	1.47	0.87
Total Particulate Collected (excl. impingers)	Mp	mg	1.85	0.00	1.20	1.02

Legend: F - degrees Fahrenheit
K - degrees Kelvin
Bar - bars
in.Hg - inches of mercury
in. - inches

in.H2O - inches of water
cu.ft - cubic feet
R - degrees Rankin
NOx - as NO2

CALCULATIONS

CertainTeed

McAdam, NB

Fuel: # 2 Fuel oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 7 m

Stack Diameter: 0.9 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	As	sq.ft sq.m	As = $\pi \times ((D/12)^2) / 4$ As (sq.m) = As (sq.ft) x 0.0929	7.07 0.66	7.07 0.66	7.07 0.66	7.07 0.66
Barometric Pressure Stack Static Pressure Avg. Stack Temperature Avg. Meter Temperature Nozzle Diameter	Pbar Pstatic Ts Tm Dn	kPa kPa R R mm	Pbar (kPa) = Pbar (in.Hg) x 3.386 Pstatic (kPa) = Pstatic (in.H2O) x 0.249 Ts (R) = Ts (F) + 460 Tm (R) = Tm (F) + 460 Dn (mm) = Dn (in.) x 25.4	101.2 0.05 602 517 6	100.9 0.05 603 521 6	102.3 0.05 589 521 6	101.5 0.05 598.1 519.6 5.9
Gas Meter Pressure Sample Volume at Ref Cond Volume of Water Vapour Water Fraction	Pm Vm Vwc Bwo	in.Hg cu.ft cu.m cu.ft -	Pm = Pbar + (dH / 13.6) Vm = Tref/Pref x (Vm x Pm x y) / Tm Vm (cu.m) = 0.02832 x Vmc (cu.ft) Vwc = 0.0480 x Vw Bwo = Vwc / (Vwc + Vmc)	29.97 55.66 1.58 5.99 0.097	29.86 49.90 1.41 5.82 0.104	30.27 54.38 1.54 4.34 0.074	30.0 53.3 1.51 5.4 0.1
Molecular Weight, Dry Molecular Weight, Wet	Md Ms	lb/lb-mol lb/lb-mol	Md = 0.44 (Cco2) + 0.32 (Co2) + 0.28 (Cn2) Ms = Md (1 - Bwo) + (18 x Bwo)	28.90 27.84	28.92 27.78	28.90 28.09	28.9 27.9
Stack Pressure Stack Gas Velocity	Ps Us	in.Hg ft/s	Ps = Pbar + (Pstatic / 13.6) Us = 85.33 x Cp x ((dP x Ts)/(Ps x Ms))^0.5	29.91 39.86 12.15	29.81 36.43 11.10	30.21 37.63 11.47	30.0 38.0 11.6
Actual Stack Gas Flow Rate	Q	m/s acfpm	Q = 60 x Us x As	16,906	15,449	15,960	16,105
Dry Stack Gas Flow Rate	Qs	acfm Rcfm Rcms	Q(acfm) = Q(acfm) x 0.02831685 Qs = Q x (1-Bwo) x (Tref/Ts) x (Ps/Pref) Qs (Rcms) = 0.000472 x Qs (Rcfm)	479 13,606 6.42	437 12,277 5.79	452 13,613 6.43	456 13,165 6.2
Sulphur Dioxide - SO2 SO2 Measured Concentration Uncorrected @ Ref Cond SO2 Emission Rate	Cso2 Cso2 ERso2	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cso2 (mg/Rem) = Cso2 (ppm) x 2.62 ERso2 = Cso2/1000 x Qs ERso2 (kg/hr) = 3.6 x ERso2 (g/s)	0.71 1.87 0.01 0.04	0.00 0.00 0.00 0.00	0.00 0.00 0.00 0.00	0.24 0.62 0.00 0.01
SO2 Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cso2 Cso2 Cso2	mg/Rem mg/Rem mg/Rem	Cso2 (11% O2) = Cso2 (mg/Rem) x (20.9-11) / (20.9-Co2) Cso2 (3% O2) = Cso2 (mg/Rem) x (20.9-3) / (20.9-Co2) Cso2 (12% CO2) = Cso2 (mg/Rem) x (12/Cco2)	15.85 28.67 33.23	0.00 0.00 0.00	0.00 0.00 0.00	5.28 9.56 11.08
Nitrogen Oxides - NOx NOx Measured Concentration Uncorrected @ Ref Cond NOx Emission Rate	Cnox Cnox ERnox	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cnox (mg/Rem) = Cnox (ppm) x 1.882 ERnox = Cnox/1000 x Qs ERnox (kg/hr) = 3.6 x ERnox (g/s)	10.00 18.82 0.12 0.44	3.14 5.91 0.03 0.12	7.57 14.25 0.09 0.33	6.90 12.99 0.08 0.30
NOx Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cnox Cnox Cnox	mg/Rem mg/Rem mg/Rem	Cnox (11% O2) = Cnox (mg/Rem) x (20.9-11) / (20.9-Co2) Cnox (3% O2) = Cnox (mg/Rem) x (20.9-3) / (20.9-Co2) Cnox (12% CO2) = Cnox (mg/Rem) x (12/Cco2)	159.44 288.28 334.22	44.90 81.18 82.81	117.56 212.55 254.13	107.30 194.00 223.72
Carbon Monoxide - CO CO Measured Concentration Uncorrected @ Ref Cond CO Emission Rate	Cco Cco ERco	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cco (mg/Rem) = Cco (ppm) x 1.145 ERco = Cco/1000 x Qs ERco (kg/hr) = 3.6 x ERco (g/s)	9.71 11.12 0.07 0.26	13.86 15.87 0.09 0.33	10.29 11.78 0.08 0.27	11.29 12.92 0.08 0.29
CO Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cco Cco Cco	mg/Rem mg/Rem mg/Rem	Cco (11% O2) = Cco (mg/Rem) x (20.9-11) / (20.9-Co2) Cco (3% O2) = Cco (mg/Rem) x (20.9-3) / (20.9-Co2) Cco (12% CO2) = Cco (mg/Rem) x (12/Cco2)	94.23 170.38 197.53	120.43 217.75 222.13	97.16 175.68 210.04	103.94 187.93 209.90
Particulate Concentration Particulate Emission Rate	Cs ERp	mg/Rem g/s kg/hr	Cs = Mp / Vmc ERp = Cs/1000 x Qs ERp (kg/hr) = 3.6 x ERp (g/s)	1.17 0.01 0.03	0.00 0.00 0.00	0.78 0.01 0.02	0.65 0.00 0.02
Particulate Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cs Cs Cs	mg/Rem mg/Rem mg/Rem	Cs (11% O2) = Cs x (20.9-11) / (20.9-Co2) Cs (3% O2) = Cs x (20.9-3) / (20.9-Co2) Cs (12% CO2) = Cs x (12/Cco2)	9.94 17.98 20.84	0.00 0.00 0.00	6.43 11.62 13.90	5.46 9.87 11.58

Legend:
 sq.ft - square feet
 sq.m - square metres
 Pi - 3.142
 R - degrees Rankin
 ppm - parts per million

in.Hg - inches of mercury
 cu.ft - cubic feet
 cu.m - cubic metres
 Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)
 Rcfm - dry Reference cubic feet per minute

mg/Rcm - milligrams per dry Reference cubic metre
 g/s - grams per second
 NOx - as NO2
 acfm - actual cubic feet per minute
 Rcms - dry Reference cubic metres per second

OFFICIAL STACK TESTING RESULTS

CertainTeed

McAdam, NB

Fuel: # 2 Fuel oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 7 m

Stack Diameter: 0.9 m

Parameter	Test 1	Test 2	Test 3	Average	NBDELG Limits
Test ID Test Date	PM-1 20-Oct-15	PM-2 20-Oct-15	PM-3 21-Oct-15	- -	- -
Stack Gas Temperature (C) Moisture Content (%) Velocity (m/s) Volumetric Flow (Rcms)	61.3 9.7 12.1 6.42	61.7 10.4 11.1 5.79	53.8 7.4 11.5 6.43	58.9 9.2 11.6 6.21	- - - -
Oxygen - O2 (%) Carbon Dioxide - CO2 (%)	19.7 0.68	19.6 0.86	19.7 0.67	19.7 0.74	- -
Sulphur Dioxide - SO2 SO2 Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	0.71 1.87 0.04	0.00 0.00 0.00	0.00 0.00 0.00	0.24 0.62 0.01	- - -
Nitrogen Oxides - NOx NOx Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	10.0 18.8 0.44	3.14 5.91 0.12	7.57 14.2 0.33	6.90 13.0 0.30	- - -
Carbon Monoxide - CO CO Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	9.71 11.1 0.26	13.9 15.9 0.33	10.3 11.8 0.27	11.3 12.9 0.29	- - -
Particulate Matter - PM Particulate Concentration (mg/Rcm) Particulate Emission Rate (kg/hr)	1.17 0.03	0.00 0.00	0.78 0.02	0.65 0.02	- -

Legend: C - degrees Celsius

m/s - metres per second

Rcms - dry Reference cubic metres per second

ppm - parts per million

Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)

mg/Rcm - miligrams per dry Reference cubic metre

NOx - as NO2

ND - non-detectable

Particulate Recoveries: Impinger Catch, Probe Wash, Filter Catch

Client: CertainTeed
Facility: Rock Dryer Stack
Location: McAdam, NB
Job Number: 121811606

IMPIINGER CATCH

Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)								
	Date					Jar + Sample + Rinse (g)	Jar Tare (g)	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date													
	Analysed by										Analysed by													
	Trial 1	Trial 2	Trial 3	Average							Trial 1	Trial 2	Trial 3	Average										
M2	110.8394	110.8394		110.8394	PM-1	616.2	389.5	124.7	7.7	109.7	110.8406	110.8406		110.8406	0.0012	0.0001								
C4	112.6437	112.6440		112.6439	PM-2	601.0	390.0	121.2	8.3	98.1	112.6461	112.6456		112.6459	0.0020	0.0010								
I6	107.9291	107.9290		107.9291	PM-3	579.3	390.6	90.5	10.3	108.5	107.9318	107.9314		107.9316	0.0025	0.0015								
D6	110.4609	110.4610		110.4610	WB	455.3	390.0	65.3		65.3	110.4617	110.4615		110.4616	0.0007	0.000010								
Conc. (g/mL)																								

PROBE WASH

Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)								
	Date					Jar + Sample + Rinse (g)	Jar Tare (g)	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date													
	Analysed by										Analysed by													
	Trial 1	Trial 2	Trial 3	Average							Trial 1	Trial 2	Trial 3	Average										
C3	113.2742	113.2741		113.2742	PM-1	421.9	321.0	100.9	3.9	104.8	113.2759	113.2758		113.2759	0.0017	0.0017								
W4	110.3543	110.3545		110.3544	PM-2	384.1	323.7	60.4	5.0	65.4	110.3526	110.3531		110.3529	-0.0016	0.0000								
Q1	116.8836	116.8835		116.8836	PM-3	362.4	324.3	38.1	4.7	42.8	116.8845	116.8850		116.8848	0.0012	0.0012								
G1	117.3946	117.3947		117.3947	AB	355.6	326.2	29.4		29.4	117.3931	117.3926		117.3929	-0.0018	0.000000								
Conc. (g/mL)																								


Density of Acetone: 0.7850 g/ml

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID *	Post Weights (g)				Particulate Weight from Filter (g)		
	Date:					Analysed by						
	Analysed by					Analysed by						
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average			
0922-04	0.3759	0.3761		0.3760	PM-1	0.3762	0.3761		0.3762	0.0001		
0922-03	0.3726	0.3728		0.3727	PM-2	0.3725	0.3723		0.3724	0.0000		
0922-05	0.3726	0.3727		0.3727	PM-3	0.3720	0.3719		0.3720	0.0000		


Stack Gas Velocity Profiles
McAdam, NB

Test #1




Traverse Point

Test #2



Traverse Point

Test #3



Traverse Point

Raw Data for: CertainTeed McAdam Calcine Mill PM data

Test #1

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-1
Date: 22-Oct-15
Personnel: NGM/JJB

Test Start: 1:20 PM
Test Finish: 3:00 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg): 5.2
Particulate Collected from Probe Wash (mg): 5.0
Particulate Collected from Impinger Wash (mg): 5.9
Total Particulate Collected (mg): 16.1

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	959.1	699.0	260.1
2	100 mL H2O	874.8	708.0	166.8
3	Blank	680.0	661.3	18.7
4	200g Silica Gel	1043.5	1015.2	28.3
			Total Weight Gain (g)	473.9
			Moisture Volume (mL)	473.9

30.00	O2, (%)	17.4	Stack Diameter, (in.)	36.00
0.10	CO2, (%)	2.4	Stack Area, (sq. ft.)	7.07
52	N2, (%)	80.1	Probe Length, (ft.)	3
473.9	CO(ppm)	9.7	Nozzle Diameter, (in.)	0.305
24	NOx (ppm)	86.9	Pitot Coefficient, (Cp)	0.783
4	SO2 (ppm)	3.3	Gamma, meter constant	1.033
NBDELG			Port length (in.)	2.000

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)
----------------	------------	-------------------------	--------------------------------	---------------------------	----------------------------	---------------------------	----------------------------

Traverse 1	1	4	292	1.10	3.93	176.360	180.560	57	57
	2	8	287	1.00	3.57		184.690	57	57
	3	12	287	0.97	3.50		188.760	58	57
	4	16	287	0.99	3.56		192.880	59	57
	5	20	293	1.00	3.57		197.000	61	58
	6	24	293	1.10	3.95		201.290	63	60
	7	28	293	1.10	3.95		205.600	63	60
	8	32	293	1.10	3.95		209.880	65	60
	9	36	293	1.05	3.76		214.120	66	60
	10	40	293	1.05	3.76		218.360	66	61
	11	44	292	1.05	3.80		222.600	67	61
	12	48	292	1.05	3.80		226.850	67	61

Traverse 2	1	52	293	1.10	3.98	226.850	231.100	68	61
	2	56	293	1.00	3.62		235.340	67	62
	3	60	293	1.00	3.62		239.500	67	62
	4	64	293	1.00	3.62		243.630	67	62
	5	68	293	1.10	3.99		248.000	68	65
	6	72	293	1.10	3.99		252.370	68	65
	7	76	293	1.10	3.99		256.700	68	62
	8	80	294	1.10	3.99		261.040	68	63
	9	84	294	1.00	3.62		265.240	68	63
	10	88	295	1.00	3.63		269.420	69	63
	11	92	295	1.00	3.63		273.590	69	63
	12	96	295	1.00	3.63		277.730	70	63

Calculations for: CertainTeed McAdam Calcine Mill PM data
Test #1

Client: CertainTeed
 Job Number: 121811606

Plant: Calcine Mill
 Location: McAdam, NB
 Test: PM-1
 Date: 22-Oct-15
 Personnel: NGM/JJB

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)
 Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
 Volume of Water Vapour Collected, Vwc (cu.ft)
 Stack Gas Moisture Content (% as decimal)
 Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)

30.01
 29.09
 22.747
 0.173
 27.17

Isokineticity Checks

Check range
 Check average
 Within Criteria
 Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	752	1.10	3.93	67.30	30.29	517	4.200	4.562
	2	8	747	1.00	3.57	63.95	30.26	517	4.130	4.482
	3	12	747	0.97	3.50	62.99	30.26	518	4.070	4.412
	4	16	747	0.99	3.56	63.63	30.26	518	4.120	4.462
	5	20	753	1.00	3.57	64.21	30.26	520	4.120	4.450
	6	24	753	1.10	3.95	67.34	30.29	522	4.290	4.620
	7	28	753	1.10	3.95	67.34	30.29	522	4.310	4.641
	8	32	753	1.10	3.95	67.34	30.29	523	4.280	4.600
	9	36	753	1.05	3.76	65.79	30.28	523	4.240	4.551
	10	40	753	1.05	3.76	65.79	30.28	524	4.240	4.546
	11	44	752	1.05	3.80	65.75	30.28	524	4.240	4.543
	12	48	752	1.05	3.80	65.75	30.28	524	4.250	4.553
Traverse 2	1	52	753	1.10	3.98	67.34	30.29	525	4.250	4.551
	2	56	753	1.00	3.62	64.21	30.27	525	4.240	4.536
	3	60	753	1.00	3.62	64.21	30.27	525	4.160	4.451
	4	64	753	1.00	3.62	64.21	30.27	525	4.130	4.419
	5	68	753	1.10	3.99	67.34	30.29	527	4.370	4.662
	6	72	753	1.10	3.99	67.34	30.29	527	4.370	4.662
	7	76	753	1.10	3.99	67.34	30.29	525	4.330	4.632
	8	80	754	1.10	3.99	67.39	30.29	526	4.340	4.639
	9	84	754	1.00	3.62	64.25	30.27	526	4.200	4.485
	10	88	755	1.00	3.63	64.29	30.27	526	4.180	4.459
	11	92	755	1.00	3.63	64.29	30.27	526	4.170	4.449
	12	96	755	1.00	3.63	64.29	30.27	527	4.140	4.412
Total		Average	Average	Average	Average	Average	Average	Total	Total	Average
96		752	1.04	3.77	65.57	30.28	523	101.370	108.778	95.92

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-1
Date: 22-Oct-15
Personnel: NGM/JJB

Test Start: 2:00 PM
Test Finish: 2:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	17.5	2.0	9.0	0.0	18.0
5	17.4	2.0	12.0	0.0	16.0
10	17.4	2.7	11.0	3.0	95.0
15	17.4	2.6	10.0	3.0	81.0
20	17.4	2.7	9.0	5.0	130.0
25	17.4	2.6	9.0	8.0	153.0
30	17.5	2.6	8.0	4.0	115.0
Average:		17.4	2.4	9.7	3.3
					86.9

Raw Data for: CertainTeed McAdam Calcine Mill PM data

Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-2
Date: 27-Oct-15
Personnel: NGM

Test Start: 10:40 AM
Test Finish: 12:35 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg): 9.9
Particulate Collected from Probe Wash (mg): 5.9
Particulate Collected from Impinger Wash (mg): 5.8
Total Particulate Collected (mg): 21.6

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	961.4	696.0	265.4
2	100 mL H2O	962.5	704.8	257.7
3	Blank	712.0	663.3	48.7
4	200g Silica Gel	1006.4	979.6	26.8
			Total Weight Gain (g)	598.6
			Moisture Volume (mL)	598.6

30.50
0.10
43
598.6
24
4
4
NBDELG

O2, (%) 17.5
CO2, (%) 2.6
N2, (%) 79.9
CO(ppm) 8.1
NOx (ppm) 81.4
SO2 (ppm) 2.7

Stack Diameter, (in.) 36.00
Stack Area, (sq. ft.) 7.07
Probe Length, (ft.) 3
Nozzle Diameter, (in.) 0.305
Pitot Coefficient, (Cp) 0.783
Gamma, meter constant 1.033
Port length (in.) 2

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	300	0.96	3.28	281.820	38 38
	2	8	300	0.96	3.31	285.730	45 39
	3	12	301	1.00	3.45	289.650	49 41
	4	16	302	1.00	3.45	293.620	49 41
	5	20	301	1.10	3.84	297.760	52 42
	6	24	300	1.10	3.84	302.030	54 43
	7	28	300	1.10	3.84	306.220	54 43
	8	32	301	0.95	3.33	310.160	56 45
	9	36	302	0.95	3.33	314.120	56 45
	10	40	302	0.95	3.35	318.080	60 50
	11	44	302	1.00	3.53	322.290	60 50
	12	48	302	1.00	3.53	326.490	60 50
Traverse 2	1	52	302	1.00	3.54	330.380	62 53
	2	56	299	1.10	3.54	334.410	62 54
	3	60	300	1.10	3.90	338.700	62 54
	4	64	300	1.10	3.90	342.970	62 54
	5	68	300	1.10	3.90	347.250	62 54
	6	72	301	0.95	3.38	351.250	64 56
	7	76	301	0.95	3.38	355.260	64 56
	8	80	302	0.95	3.39	359.290	65 58
	9	84	302	0.98	3.50	363.320	65 58
	10	88	303	0.98	3.50	367.470	66 58
	11	92	300	0.98	3.50	371.600	66 58
	12	96	300	0.98	3.50	375.630	66 58

Calculations for: CertainTeed McAdam Calcine Mill PM data
Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-2
Date: 27-Oct-15
Personnel: NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	30.51
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.11
Volume of Water Vapour Collected, Vvc (cu.ft)	28.733
Stack Gas Moisture Content (% as decimal)	0.210
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	26.78

Isokineticity Checks

Check range
Check average
Within Criteria
Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	760	0.96	3.28	63.14	30.74	498	3.760	4.303
	2	8	760	0.96	3.31	63.14	30.74	502	3.910	4.440
	3	12	761	1.00	3.45	64.48	30.75	505	3.920	4.426
	4	16	762	1.00	3.45	64.52	30.75	505	3.970	4.482
	5	20	761	1.10	3.84	67.63	30.78	507	4.140	4.660
	6	24	760	1.10	3.84	67.58	30.78	509	4.270	4.792
	7	28	760	1.10	3.84	67.58	30.78	509	4.190	4.703
	8	32	761	0.95	3.33	62.85	30.74	511	3.940	4.399
	9	36	762	0.95	3.33	62.89	30.74	511	3.960	4.422
	10	40	762	0.95	3.35	62.89	30.75	515	3.960	4.383
	11	44	762	1.00	3.53	64.52	30.76	515	4.210	4.662
	12	48	762	1.00	3.53	64.52	30.76	515	4.200	4.651
Traverse 2	1	52	762	1.00	3.54	64.52	30.76	518	3.890	4.287
	2	56	759	1.10	3.54	67.54	30.76	518	4.030	4.437
	3	60	760	1.10	3.90	67.58	30.79	518	4.290	4.727
	4	64	760	1.10	3.90	67.58	30.79	518	4.270	4.705
	5	68	760	1.10	3.90	67.58	30.79	518	4.280	4.716
	6	72	761	0.95	3.38	62.85	30.75	520	4.000	4.385
	7	76	761	0.95	3.38	62.85	30.75	520	4.010	4.396
	8	80	762	0.95	3.39	62.89	30.75	522	4.030	4.406
	9	84	762	0.98	3.50	63.88	30.76	522	4.030	4.407
	10	88	763	0.98	3.50	63.92	30.76	522	4.150	4.534
	11	92	760	0.98	3.50	63.79	30.76	522	4.130	4.512
	12	96	760	0.98	3.50	63.79	30.76	522	4.030	4.402
Total	96	Average 761	Average 1.01	Average 3.54	Average 64.77	Average 30.76	Average 514	Total 97.570	Total 108.237	Average 100.59

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-2
Date: 27-Oct-15
Personnel: NGM

Test Start: 10:40 AM
Test Finish: 11:10 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	17.4	2.7	9.0	4.0	110.0
5	17.5	2.6	9.0	6.0	145.0
10	17.5	2.6	9.0	4.0	119.0
15	17.5	2.6	8.0	2.0	84.0
20	17.5	2.6	8.0	1.0	61.0
25	17.5	2.6	7.0	0.0	27.0
30	17.6	2.5	7.0	2.0	24.0
Average:		17.5	2.6	8.1	2.7
					81.4

Raw Data for: CertainTeed McAdam Calcine Mill PM data

Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-3
Date: 27-Oct-15
Personnel: NGM

Test Start: 2:03 PM
Test Finish: 3:45 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
 Stack Static Pressure, Pstatic (in. H2O)
 Ambient Temp, (°F)
 H2O Volume Collected, Vw (mL)
 Total # Sampling Points,
 Sampling Time per Point, (min)
 Readings Taken Every __ mins
 Regulatory Agency

Particulate Collected from Filter (mg):	10.7
Particulate Collected from Probe Wash (mg):	7.4
Particulate Collected from Impinger Wash (mg):	5.8
Total Particulate Collected (mg):	24.0

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	953.1	692.9	260.2
2	100 mL H2O	971.8	712.7	259.1
3	Blank	738.3	664.1	74.2
4	200g Silica Gel	881.1	877.3	3.8
		Total Weight Gain (g)		597.3
		Moisture Volume (mL)		597.3

30.40	O2, (%)	17.4
0.10	CO2, (%)	2.7
47.70	N2, (%)	79.9
597.30	CO(ppm)	9.3
24	NOx (ppm)	102.3
4	SO2 (ppm)	2.6

NBDELG

Stack Diameter, (in.)	36.00
Stack Area, (sq. ft.)	7.07
Probe Length, (ft.)	3
Nozzle Diameter, (in.)	0.305
Pitot Coefficient, (Cp)	0.783
Gamma, meter constant	1.033
Port length (in.)	2

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)
----------------	------------	-------------------------	--------------------------------	---------------------------	----------------------------	---------------------------	----------------------------

Traverse 1	1	4	303	1.10	3.91	375.860	380.040	61	61
	2	8	306	1.10	3.91	384.300	384.300	61	61
	3	12	306	1.20	4.24	389.060	389.060	60	61
	4	16	306	1.25	4.42	393.270	393.270	61	61
	5	20	306	1.20	4.24	397.760	397.760	61	61
	6	24	306	1.15	4.06	402.130	402.130	63	61
	7	28	306	1.30	4.61	406.620	406.620	63	61
	8	32	307	1.20	4.26	411.080	411.080	66	62
	9	36	307	1.15	4.08	415.470	415.470	66	62
	10	40	307	1.10	3.90	420.110	420.110	66	62
	11	44	307	1.10	3.90	424.100	424.100	66	63
	12	48	307	1.00	3.55	428.210	428.210	68	63

Traverse 2	1	52	307	0.99	3.52	428.210	432.600	68	63
	2	56	306	0.98	3.49	436.000	436.000	68	63
	3	60	306	1.00	3.56	440.500	440.500	67	64
	4	64	306	1.10	3.92	444.790	444.790	67	64
	5	68	306	1.15	4.09	449.220	449.220	67	64
	6	72	306	1.20	4.27	453.750	453.750	67	64
	7	76	306	1.20	4.27	458.250	458.250	67	64
	8	80	306	1.20	4.30	462.750	462.750	68	64
	9	84	307	1.15	4.11	467.200	467.200	70	65
	10	88	307	1.10	3.93	471.630	471.630	70	65
	11	92	307	1.00	3.56	475.750	475.750	70	65
	12	96	308	0.98	3.50	479.769	479.769	70	65

Calculations for: Certainteed McAdam Calcine Mill PM data

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-3
Date: 27-Oct-15
Personnel: NGM

Calculated Parameters

Isokineticity Checks

Stack Gas Pressure, Ps (in.Hg)	30.41	Check range	Within Criteria
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.12	Check average	Within Criteria
Volume of Water Vapour Collected, Vwc (cu.ft)	28.670		
Stack Gas Moisture Content (% as decimal)	0.203		
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	26.87		

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Gas Meter			Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
							Avg. Temp, Tm (R)	Volume, Vm (cu. ft.)	Total		
Traverse 1	1	4	763	1.10	3.91	67.72	30.69	521	4.180	4.565	97.09
	2	8	766	1.10	3.91	67.85	30.69	521	4.260	4.652	99.14
	3	12	766	1.20	4.24	70.87	30.71	521	4.760	5.207	106.25
	4	16	766	1.25	4.42	72.33	30.73	521	4.210	4.603	92.02
	5	20	766	1.20	4.24	70.87	30.71	521	4.490	4.907	100.12
	6	24	766	1.15	4.06	69.38	30.70	522	4.370	4.785	99.31
	7	28	766	1.30	4.61	73.76	30.74	522	4.490	4.902	96.10
	8	32	767	1.20	4.26	70.92	30.71	524	4.460	4.847	98.95
	9	36	767	1.15	4.08	69.42	30.70	524	4.390	4.769	99.45
	10	40	767	1.10	3.90	67.90	30.69	524	4.640	5.038	107.43
	11	44	767	1.10	3.90	67.90	30.69	525	3.990	4.328	92.30
	12	48	767	1.00	3.55	64.74	30.66	526	4.110	4.446	99.44
Traverse 2	1	52	767	0.99	3.52	64.41	30.40	526	4.390	4.708	105.84
	2	56	766	0.98	3.49	64.04	30.66	526	3.400	3.678	83.04
	3	60	766	1.00	3.56	64.69	30.66	526	4.500	4.867	108.79
	4	64	766	1.10	3.92	67.85	30.66	526	4.290	4.641	98.90
	5	68	766	1.15	4.09	69.38	30.69	526	4.430	4.796	99.97
	6	72	766	1.20	4.27	70.87	30.70	526	4.530	4.907	100.12
	7	76	766	1.20	4.27	70.87	30.71	526	4.500	4.876	99.49
	8	80	766	1.20	4.30	70.87	30.71	526	4.500	4.872	99.40
	9	84	767	1.15	4.11	69.42	30.72	528	4.450	4.804	100.20
	10	88	767	1.10	3.93	67.90	30.70	528	4.430	4.780	101.94
	11	92	767	1.00	3.56	64.74	30.69	528	4.120	4.444	99.39
	12	96	768	0.98	3.50	64.13	30.66	528	4.019	4.331	97.92
Total		Average	Average	Average	Average	Average	Average	Total	Total	Average	
96		766	1.12	3.98	68.45	30.68	524	103.909	112.733	99.28	

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Calcine Mill
Location: McAdam, NB
Test: PM-3
Date: 27-Oct-15
Personnel: NGM

Test Start: 2:30 PM
Test Finish: 3:00 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	17.4	2.8	11.0	2.0	81.0
5	17.4	2.7	10.0	2.0	82.0
10	17.4	2.6	10.0	3.0	85.0
15	17.4	2.6	9.0	2.0	156.0
20	17.5	2.7	9.0	6.0	146.0
25	17.5	2.6	8.0	2.0	91.0
30	17.5	2.7	8.0	1.0	75.0
Average:		17.4	2.7	9.3	102.3

DATA ENTRY

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.5 m

Stack Diameter: 0.9 m

Reference Temperature, Tref (F): 77
(K): 298
Reference Pressure, Pref (in.Hg): 29.92
(Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	22-Oct-15	27-Oct-15	27-Oct-15	n/a
Start Time	-	-	1:20 PM	10:40 AM	2:03 PM	n/a
End Time	-	-	3:00 PM	12:35 PM	3:45 PM	n/a
Total Sampling Time	-	min	96	96	96	96
Stack Diameter	D	in.	36	36	36	36
Average Stack Gas Temperature	Ts	F	292	301	306	300
Average Dry Gas Meter Temperature	Tm	F	63	54	64	61
Barometric Pressure	Pbar	in.Hg	30.00	30.50	30.40	30.30
Stack Static Pressure	Pstatic	in.H2O	0.10	0.10	0.10	0.10
Average Pressure Drop (Head)	dP	in.H2O	1.04	1.01	1.12	1.06
Average deltaH Orifice	dH	in.H2O	3.77	3.54	3.98	3.76
Average Meter Temperature	Tm	F	63	54	64	61
Gas Sample Volume	Vm	cu.ft	101.37	97.57	103.91	100.95
Average Isokinetics	I	%	95.92	100.59	99.28	98.59
Nozzle Diameter	Dn	in.	0.305	0.305	0.305	0.305
Pitot Coefficient	Cp	-	0.783	0.783	0.783	0.783
Gamma, meter constant	y	-	1.033	1.033	1.033	1.033
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	17.4	17.5	17.4	17.5
Stack Gas Carbon Dioxide Content	Cco2	%	2.4	2.6	2.7	2.6
Stack Gas Nitrogen Content	Cn2	%	80.1	79.9	79.9	80.0
Stack Gas Sulphur Dioxide Content	Cso2	ppm	3.3	2.7	2.6	2.9
Stack Gas Nitrogen Oxides Content	Cnox	ppm	86.9	81.4	102.3	90.2
Stack Gas Carbon Monoxide Content	Cco	ppm	9.7	8.1	9.3	9.0
Volume of Water Collected	Vw	mL	473.9	598.6	597.3	556.6
Particulate Collected from Filter	-	mg	5.2	9.9	10.7	8.6
Particulate Collected from Probe Wash	-	mg	5.0	5.9	7.4	6.1
Particulate Collected from Impinger Wash	-	mg	5.91	5.79	5.81	5.83
Total Particulate Collected (excl. impingers)	Mp	mg	10.1	15.9	18.1	14.7

Legend: F - degrees Fahrenheit
K - degrees Kelvin
Bar - bars
in.Hg - inches of mercury
in. - inches

in.H2O - inches of water
cu.ft - cubic feet
R - degrees Rankin
NOx - as NO2

CALCULATIONS

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.5 m

Stack Diameter: 0.9 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	As	sq.ft sq.m	As = $\pi \times ((D/12)^2) / 4$ As (sq.m) = As (sq.ft) x 0.0929	7.07 0.66	7.07 0.66	7.07 0.66	7.07 0.66
Barometric Pressure Stack Static Pressure Avg. Stack Temperature Avg. Meter Temperature Nozzle Diameter	Pbar Pstatic Ts Tm Dn	kPa kPa R R mm	Pbar (kPa) = Pbar (in.Hg) x 3.386 Pstatic (kPa) = Pstatic (in.H2O) x 0.249 Ts (R) = Ts (F) + 460 Tm (R) = Tm (F) + 460 Dn (mm) = Dn (in.) x 25.4	101.6 0.02 752 523 8	103.3 0.02 761 514 8	102.9 0.02 766 524 8	102.6 0.02 759.9 520.5 7.7
Gas Meter Pressure Sample Volume at Ref Cond Volume of Water Vapour Water Fraction	Pm Vm Vwc Bwo	in.Hg cu.ft cu.m cu.ft -	Pm = Pbar + (dH / 13.6) Vm = Tref/Pref x (Vm x Pm x y) / Tm Vm (cu.m) = 0.02832 x Vmc (cu.ft) Vwc = 0.0480 x Vw Bwo = Vwc / (Vwc + Vmc)	30.28 108.78 3.08 22.75 0.173	30.76 108.24 3.07 28.73 0.210	30.69 112.76 3.19 28.67 0.203	30.6 109.9 3.11 26.7 0.2
Molecular Weight, Dry Molecular Weight, Wet	Md Ms	lb/lb-mol lb/lb-mol	Md = 0.44 (Cco2) + 0.32 (Co2) + 0.28 (Cn2) Ms = Md (1 - Bwo) + (18 x Bwo)	29.09 27.17	29.11 26.78	29.12 26.87	29.1 26.9
Stack Pressure Stack Gas Velocity Actual Stack Gas Flow Rate Dry Stack Gas Flow Rate	Ps Us Q Qs	in.Hg ft/s m/s acfmin acfm Rcfm Rcms	Ps = Pbar + (Pstatic / 13.6) Us = 85.33 x Cp x ((dP x Ts)/(Ps x Ms))^0.5 Us (m/s) = 0.3048 x Us (ft/s) Q = 60 x Us x As Q(acfm) = Q(acfm) x 0.02831685 Qs = Q x (1-Bwo) x (Tref/Ts) x (Ps/Pref) Qs (Rcms) = 0.000472 x Qs (Rcfm)	30.01 65.57 19.99 27,810 787 16,462 7.77	30.51 64.77 19.74 27,471 778 15,620 7.37	30.41 68.45 20.86 29,031 822 16,484 7.78	30.3 66.3 20.2 28,104 796 16,189 7.6
Sulphur Dioxide - SO2 SO2 Measured Concentration Uncorrected @ Ref Cond SO2 Emission Rate SO2 Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cso2 Cso2 ERso2 Cso2 Cso2 Cso2	ppm mg/Rcm g/s kg/hr mg/Rcm mg/Rcm mg/Rcm	Measurement from Flue Gas Analyzer Cso2 (mg/Rcm) = Cso2 (ppm) x 2.62 ERso2 = Cso2/1000 x Qs ERso2 (kg/hr) = 3.6 x ERso2 (g/s) Cso2 (11% O2) = Cso2 (mg/Rcm) x (20.9-11) / (20.9-Co2) Cso2 (3% O2) = Cso2 (mg/Rcm) x (20.9-3) / (20.9-Co2) Cso2 (12% CO2) = Cso2 (mg/Rcm) x (12/Cco2)	3.29 8.61 0.07 0.24	2.71 7.11 0.05 0.19	2.57 6.74 0.05 0.19	2.86 7.49 0.06 0.21
Nitrogen Oxides - NOx NOx Measured Concentration Uncorrected @ Ref Cond NOx Emission Rate NOx Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cnox Cnox ERnox Cnox Cnox Cnox	ppm mg/Rcm g/s kg/hr mg/Rcm mg/Rcm mg/Rcm	Measurement from Flue Gas Analyzer Cnox (mg/Rcm) = Cnox (ppm) x 1.882 ERnox = Cnox/1000 x Qs ERnox (kg/hr) = 3.6 x ERnox (g/s) Cnox (11% O2) = Cnox (mg/Rcm) x (20.9-11) / (20.9-Co2) Cnox (3% O2) = Cnox (mg/Rcm) x (20.9-3) / (20.9-Co2) Cnox (12% CO2) = Cnox (mg/Rcm) x (12/Cco2)	86.86 163.47 1.27 4.57	81.43 153.25 1.13 4.07	102.29 192.50 1.50 5.39	90.19 169.74 1.30 4.68
Carbon Monoxide - CO CO Measured Concentration Uncorrected @ Ref Cond CO Emission Rate CO Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cco Cco ERco Cco Cco Cco	ppm mg/Rcm g/s kg/hr mg/Rcm mg/Rcm mg/Rcm	Measurement from Flue Gas Analyzer Cco (mg/Rcm) = Cco (ppm) x 1.145 ERco = Cco/1000 x Qs ERco (kg/hr) = 3.6 x ERco (g/s) Cco (11% O2) = Cco (mg/Rcm) x (20.9-11) / (20.9-Co2) Cco (3% O2) = Cco (mg/Rcm) x (20.9-3) / (20.9-Co2) Cco (12% CO2) = Cco (mg/Rcm) x (12/Cco2)	9.71 11.12 0.09 0.31	8.14 9.32 0.07 0.25	9.29 10.63 0.08 0.30	9.05 10.36 0.08 0.29
Particulate Concentration Particulate Emission Rate Particulate Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cs ERP Cs Cs Cs	mg/Rcm g/s kg/hr mg/Rcm mg/Rcm mg/Rcm	Cs = Mp / Vmc ERP = Cs/1000 x Qs ERP (kg/hr) = 3.6 x ERP (g/s) Cs (11% O2) = Cs x (20.9-11) / (20.9-Co2) Cs (3% O2) = Cs x (20.9-3) / (20.9-Co2) Cs (12% CO2) = Cs x (12/Cco2)	3.29 0.03 0.09	5.17 0.04 0.14	5.68 0.04 0.16	4.72 0.04 0.13
Legend: sq.ft - square feet sq.m - square metres Pi - 3.142 R - degrees Rankin ppm - parts per million				in.Hg - inches of mercury cu.ft - cubic feet cu.m - cubic metres Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa) Rcfm - dry Reference cubic feet per minute			
				mg/Rcm - milligrams per dry Reference cubic metre g/s - grams per second NOx - as NO2 acfmin - actual cubic feet per minute Rcms - dry Reference cubic metres per second			

OFFICIAL STACK TESTING RESULTS

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.5 m

Stack Diameter: 0.9 m

Parameter	Test 1	Test 2	Test 3	Average	NBDELG Limits
Test ID Test Date	PM-1 22-Oct-15	PM-2 27-Oct-15	PM-3 27-Oct-15	- -	- -
Stack Gas Temperature (C) Moisture Content (%) Velocity (m/s) Volumetric Flow (Rcms)	145 17.3 19.99 7.77	149 21.0 19.74 7.37	152 20.3 20.86 7.78	149 19.5 20.20 7.64	- - - -
Oxygen - O2 (%) Carbon Dioxide - CO2 (%)	17.4 2.45	17.5 2.58	17.4 2.66	17.5 2.56	- -
Sulphur Dioxide - SO2 SO2 Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	3.29 8.61 0.24	2.71 7.11 0.19	2.57 6.74 0.19	2.86 7.49 0.21	- - -
Nitrogen Oxides - NOx NOx Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	86.9 163 4.57	81.4 153 4.07	102.3 193 5.39	90.2 170 4.68	- - -
Carbon Monoxide - CO CO Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	9.71 11.1 0.31	8.14 9.32 0.25	9.29 10.6 0.30	9.05 10.4 0.29	- - -
Particulate Matter - PM Particulate Concentration (mg/Rcm) Particulate Emission Rate (kg/hr)	3.29 0.09	5.17 0.14	5.68 0.16	4.72 0.13	- -

Legend: C - degrees Celsius

m/s - metres per second

Rcms - dry Reference cubic metres per second

ppm - parts per million

Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)

mg/Rcm - miligrams per dry Reference cubic metre

NOx - as NO2

ND - non-detectable

Particulate Recoveries: Impinger Catch, Probe Wash, Filter Catch

Client: CertainTeed
Facility: Calcine Mill
Location: McAdam, NB
Job Number: 121811606

IMPIINGER CATCH

Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)		
	Date			Analysed by			Jar + Sample + Rinse (g)	Jar Tare (g)	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date						
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average			Trial 1	Trial 2	Trial 3	Average			
V2	109.1720	109.1721		109.1721	PM-1	944.9	389.2	473.9	7.8	89.6	109.1791	109.1786		109.1789	0.0068	0.0059		
H6	109.4407	109.4410		109.4409	PM-2	1150.8	389.2	598.6	8.9	171.9	109.4486	109.4481		109.4484	0.0075	0.0058		
G2	107.7214	107.7216		107.7215	PM-3	1134.5	391.5	597.3	9.4	155.1	107.7291	107.7286		107.7289	0.0074	0.0058		
D6	110.4609	110.4610		110.4610	WB	455.3	390.0	65.3		65.3	110.4617	110.4615		110.4616	0.0007	0.000010		
																	Conc. (g/mL)	

PROBE WASH




Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)		
	Date			Analysed by			Jar + Acetone (g)	Jar Tare (g)	Recovered Acetone (g)	Rinse Acetone (g)	Total Acetone (g)	Date						
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average			Trial 1	Trial 2	Trial 3	Average			
E5	107.0972	107.0977		107.0975	PM-1	385.9	324.2	61.7	3.1	64.8	107.1027	107.1022		107.1025	0.0050	0.0050		
K6	112.1856	112.1861		112.1859	PM-2	351.8	301.8	50.0	2.8	52.8	112.1920	112.1915		112.1918	0.0059	0.0059		
C1	113.6647	113.6647		113.6647	PM-3	388.2	323.7	64.5	2.9	67.4	113.6724	113.6719		113.6722	0.0074	0.0074		
G1	117.3946	117.3947		117.3947	AB	355.6	326.2	29.4		29.4	117.3931	117.3926		117.3929	-0.0018	0.000000		
																	Conc. (g/mL)	

Density of Acetone: 0.7850 g/ml

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID *	Post Weights (g)				Particulate Weight from Filter (g)
	Analysed by			Date:		Analysed by			Date:	
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average	
0922-02	0.3725	0.3725		0.3725	PM-1	0.3775	0.3778		0.3777	0.0052
0922-20	0.3739	0.3734		0.3737	PM-2	0.3836	0.3836		0.3836	0.0099
0922-19	0.3717	0.3713		0.3715	PM-3	0.3822	0.3822		0.3822	0.0107

Stack Gas Velocity Profiles
McAdam, NB



Raw Data for: CetainTeed Zone 1 Dryer PM

Test #1

Client: CertainTeed	Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
Job Number: 121811606	1	100 mL H ₂ O	974.8	735.6	239.2
Plant: Zone 1 Dryer	2	100 mL H ₂ O	979.6	726.4	253.2
Location: McAdam, NB	3	Blank	735.6	569.5	166.1
Test: PM-1	4	200g Silica Gel	984.0	959.5	24.5
Date: 28-Oct-15					
Personnel: TBH					
Test Start: 1:52 PM					Total Weight Gain (g) 683.0
Test Finish: 3:30 PM					Moisture Volume (mL) 683.0

Parameters

Barometric Pressure, Pbar (in. Hg)
 Stack Static Pressure, Pstatic (in. H₂O)
 Ambient Temp, (°F)
 H₂O Volume Collected, Vw (mL)
 Total # Sampling Points,
 Sampling Time per Point, (min)
 Readings Taken Every __ mins
 Regulatory Agency

30.02	O ₂ , (%)	14.5	Stack Diameter, (in.)	48.00
0.20	CO ₂ , (%)	4.8	Stack Area, (sq. ft.)	12.57
75	N ₂ , (%)	80.7	Probe Length, (ft.)	4
683.0	CO(ppm)	14.4	Nozzle Diameter, (in.)	0.305
24	NO _x (ppm)	140.1	Pitot Coefficient, (Cp)	0.756
4	SO ₂ (ppm)	0.0	Gamma, meter constant	0.974
4			Port length (in.)	4.000
NBDELG				

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	285	0.45	1.65	98.390	51
	2	8	284	0.45	1.65	101.390	51
	3	12	332	0.35	1.20	103.940	51
	4	16	341	0.35	1.19	106.510	53
	5	20	346	0.30	1.01	108.870	54
	6	24	339	0.47	1.60	111.780	56
	7	28	317	0.45	1.58	114.680	57
	8	32	295	0.44	1.60	117.660	59
	9	36	288	0.44	1.60	120.590	59
	10	40	283	0.39	1.43	123.400	61
	11	44	280	0.39	1.43	126.180	61
	12	48	278	0.39	1.46	128.990	61
Traverse 2	1	52	279	0.45	1.68	132.010	63
	2	56	280	0.45	1.68	135.040	63
	3	60	276	0.49	1.83	138.220	64
	4	64	276	0.49	1.83	141.490	63
	5	68	275	0.35	1.31	144.180	64
	6	72	275	0.35	1.31	146.900	64
	7	76	276	0.64	1.31	149.630	64
	8	80	276	0.35	1.31	152.320	64
	9	84	276	0.40	1.49	155.390	64
	10	88	276	0.40	1.49	158.150	64
	11	92	275	0.52	1.94	161.470	64
	12	96	276	0.52	1.94	164.790	64

Calculations for: CertainTeed Zone 1 Dryer PM
Test #1

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-1
Date: 28-Oct-15
Personnel: TBH

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
Volume of Water Vapour Collected, Vvc (cu.ft)
Stack Gas Moisture Content (% as decimal)
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)

30.03
29.35
32.784
0.317
25.75

Isokineticity Checks

Check range
Check average Outside of Criteria
Outside of Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Gas Meter			Isokinetics I (%)	
							Avg. Temp, Tm (R)	Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)		
Traverse 1	1	4	745	0.45	1.65	42.47	30.14	511	2.945	3.037	118.85
	2	8	744	0.45	1.65	42.44	30.14	511	3.000	3.093	120.99
	3	12	792	0.35	1.20	38.62	30.11	511	2.550	2.626	120.18
	4	16	801	0.35	1.19	38.84	30.11	512	2.570	2.642	121.57
	5	20	806	0.30	1.01	36.07	30.09	513	2.360	2.420	120.67
	6	24	799	0.47	1.60	44.95	30.14	514	2.910	2.983	118.30
	7	28	777	0.45	1.58	43.37	30.14	515	2.900	2.969	118.69
	8	32	755	0.44	1.60	42.28	30.14	516	2.980	3.043	121.24
	9	36	748	0.44	1.60	42.08	30.14	516	2.930	2.992	118.65
	10	40	743	0.39	1.43	39.49	30.13	518	2.810	2.860	120.06
	11	44	740	0.39	1.43	39.41	30.13	518	2.780	2.829	118.54
	12	48	738	0.39	1.46	39.35	30.13	518	2.810	2.860	119.66
Traverse 2	1	52	739	0.45	1.68	42.30	30.14	519	3.020	3.066	119.53
	2	56	740	0.45	1.68	42.33	30.14	519	3.030	3.076	120.00
	3	60	736	0.49	1.83	44.05	30.15	520	3.180	3.224	120.18
	4	64	736	0.49	1.83	44.05	30.15	520	3.270	3.318	123.70
	5	68	735	0.35	1.31	37.20	30.12	521	2.690	2.721	119.94
	6	72	735	0.35	1.31	37.20	30.12	521	2.720	2.751	121.28
	7	76	736	0.64	1.31	50.15	30.12	521	2.730	2.759	90.34
	8	80	736	0.35	1.31	37.23	30.12	521	2.690	2.718	119.90
	9	84	736	0.40	1.49	39.80	30.13	521	3.070	3.104	128.06
	10	88	736	0.40	1.49	39.80	30.13	522	2.760	2.788	115.02
	11	92	735	0.52	1.94	45.35	30.16	522	3.320	3.357	121.40
	12	96	736	0.52	1.94	45.38	30.16	522	3.320	3.357	121.48
Total		Average	Average	Average	Average	Average	Average	Total	Total	Average	
96		751	0.43	1.52	41.43	30.13	517	69.345	70.591	119.09	

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-1
Date: 28-Oct-15
Personnel: TBH

Test Start: 2:30 PM
Test Finish: 3:00 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)	
0	14.6	4.8	12.0	0.0	138.0	2.0	136	
5	14.6	4.8	13.0	0.0	140.0	3.0	137	
10	14.5	4.9	12.0	0.0	141.0	1.0	140	
15	14.5	4.9	13.0	0.0	140.0	0.0	140	
20	14.5	4.8	13.0	0.0	142.0	2.0	140	
25	14.6	4.8	20.0	0.0	140.0	0.0	140	
30	14.6	4.8	18.0	0.0	140.0	3.0	137	
Average:		14.5	4.8	14.4	0.0	140.1	1.6	139

Raw Data for: CetainTeed Zone 1 Dryer PM

Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-2
Date: 29-Oct-15
Personnel: NGM

Test Start: 9:55 AM
Test Finish: 11:45 AM

Parameters
Barometric Pressure, Pbar (in.
Stack Static Pressure, Pstatic (
Ambient Temp, (°F)
H₂O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg):	17.8
Particulate Collected from Probe Wash (mg):	3.3
Particulate Collected from Impinger Wash (mg):	49.6
Total Particulate Collected (mol):	70.7

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	1020.2	731.2	289.0
2	100 mL H ₂ O	1030.3	723.1	307.2
3	Blank	663.6	570.3	93.3
4	200g Silica Gel	1010.1	972.6	37.5
Total Weight Gain (g)				727.0
Moisture Volume (mL)				727.0

Barometric Pressure, Pbar (in. Hg)	29.98
Stack Static Pressure, Psstatic (in. H2O)	0.20
Ambient Temp, (°F)	70
20 Volume Collected, Vw (mL)	727.0
Total # Sampling Points,	24
Sampling Time per Point, (min)	4
Readings Taken Every __ mins	4
Regulatory Agency	NBDELG

14.7	Stack Diameter, (in.)
4.7	Stack Area, (sq. ft.)
80.6	Probe Length, (ft.)
13.9	Nozzle Diameter, (in.)
132.9	Pitot Coefficient, (C_p)
0.0	Gamma, meter constant
	Port length (in.)

Stack Diameter, (in.)	48.00
Stack Area, (sq. ft.)	12.5
Probe Length, (ft.)	4
Nozzle Diameter, (in.)	0.30
Pitot Coefficient, (C_p)	0.75
Gamma, meter constant	0.97
Port length (in.)	4

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Inlet (°F)	Gas Meter Temp Outlet (°F)
Traverse 1	1	4	340	0.35	0.80	164.960	
	2	8	250	0.35	0.78	167.010	65
	3	12	250	0.35	0.78	169.080	66
	4	16	344	0.35	0.80	170.940	66
	5	20	308	0.35	0.83	174.920	67
	6	24	304	0.35	0.83	176.930	66
	7	28	297	0.40	0.96	179.120	67
	8	32	296	0.40	0.97	181.300	68
	9	36	296	0.35	0.85	183.380	69
	10	40	295	0.35	0.85	185.450	69
	11	44	295	0.35	0.85	187.500	66
	12	48	294	0.35	0.85	189.550	67
Traverse 2	1	52	297	0.35	0.85	189.550	
	2	56	296	0.35	0.85	191.620	70
	3	60	296	0.40	0.98	193.660	71
	4	64	295	0.40	0.98	195.900	71
	5	68	295	0.42	1.03	198.150	72
	6	72	293	0.42	1.03	200.430	72
	7	76	291	0.35	0.86	202.760	72
	8	80	292	0.35	0.86	204.870	72
	9	84	293	0.35	0.86	207.050	72
	10	88	294	0.40	0.98	209.130	69
	11	92	294	0.40	0.98	211.380	72
	12	96	294	0.40	0.98	213.660	69

Calculations for: CertainTeed Zone 1 Dryer PM
Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-2
Date: 29-Oct-15
Personnel: NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	29.99
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.34
Volume of Water Vapour Collected, Vvc (cu.ft)	34.896
Stack Gas Moisture Content (% as decimal)	0.408
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	24.71

Isokineticity Checks

Check range	Within Criteria
Check average	Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	800	0.35	0.80	39.65	30.04	525	2.050	2.050
	2	8	710	0.35	0.78	37.35	30.04	526	2.070	2.068
	3	12	710	0.35	0.78	37.35	30.04	526	1.860	91.11
	4	16	804	0.35	0.80	39.75	30.04	526	1.990	1.987
	5	20	768	0.35	0.83	38.85	30.04	527	1.990	1.985
	6	24	764	0.35	0.83	38.75	30.04	527	2.010	2.005
	7	28	757	0.40	0.96	41.23	30.05	527	2.190	2.185
	8	32	756	0.40	0.97	41.21	30.05	527	2.180	2.173
	9	36	756	0.35	0.85	38.55	30.04	528	2.080	2.071
	10	40	755	0.35	0.85	38.52	30.04	528	2.070	2.061
	11	44	755	0.35	0.85	38.52	30.04	528	2.050	2.041
	12	48	754	0.35	0.85	38.49	30.04	529	2.050	2.037
Traverse 2	1	52	757	0.35	0.85	38.57	30.04	529	2.070	2.057
	2	56	756	0.35	0.85	38.55	30.04	530	2.040	2.021
	3	60	756	0.40	0.98	41.21	30.05	529	2.240	2.225
	4	64	755	0.40	0.98	41.18	30.05	530	2.250	2.230
	5	68	755	0.42	1.03	42.20	30.06	530	2.280	2.260
	6	72	753	0.42	1.03	42.14	30.06	530	2.330	2.310
	7	76	751	0.35	0.86	38.42	30.04	530	2.110	2.091
	8	80	752	0.35	0.86	38.44	30.04	531	2.180	2.158
	9	84	753	0.35	0.86	38.47	30.04	531	2.080	2.059
	10	88	754	0.40	0.98	41.15	30.05	531	2.250	2.228
	11	92	754	0.40	0.98	41.15	30.05	531	2.280	2.258
	12	96	754	0.40	0.98	41.15	30.05	531	2.140	2.119
Total	96	Average 756	Average 0.37	Average 0.89	Average 39.62	Average 30.05	Average 528	Total 50.840	Total 50.539	Average 103.57

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-2
Date: 29-Oct-15
Personnel: NGM

Test Start: 10:00 AM
Test Finish: 10:30 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	14.7	4.6	13.0	0.0	129.0	3.0	126
5	14.7	4.7	12.0	0.0	131.0	2.0	129
10	14.7	4.7	13.0	0.0	132.0	2.0	130
15	14.7	4.7	11.0	0.0	133.0	0.0	133
20	14.7	4.7	15.0	0.0	134.0	4.0	130
25	14.6	4.8	21.0	0.0	135.0	1.0	134
30	14.6	4.8	12.0	0.0	136.0	3.0	133
Average:		14.7	4.7	13.9	0.0	132.9	2.1
							131

Raw Data for: CetainTeed Zone 1 Dryer PM

Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: NGM

Test Start: 1:20 PM
Test Finish: 3:00 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg):	11.6
Particulate Collected from Probe Wash (mg):	0.7
Particulate Collected from Impinger Wash (mg):	42.7
Total Particulate Collected (mg):	55.0

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	1029.7	724.0	305.7
2	100 mL H2O	1028.5	715.5	313.0
3	Blank	595.4	572.2	23.2
4	200g Silica Gel	987.1	974.5	12.6

Total Weight Gain (g) 654.5
Moisture Volume (mL) 654.5

29.90	O2, (%)	14.6
0.20	CO2, (%)	4.7
77.40	N2, (%)	80.6
654.50	CO(ppm)	14.3
24	NOx (ppm)	144.0
4	SO2 (ppm)	0.0

Stack Diameter, (in.)	48.00
Stack Area, (sq. ft.)	12.57
Probe Length, (ft.)	4
Nozzle Diameter, (in.)	0.305
Pitot Coefficient, (Cp)	0.756
Gamma, meter constant	0.974
Port length (in.)	4

NBDELG

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	290	0.20	0.40	217.000	
	2	8	290	0.20	0.40	218.440	68
	3	12	288	0.25	0.49	219.900	68
	4	16	289	0.25	0.49	221.530	68
	5	20	290	0.25	0.50	223.150	68
	6	24	288	0.25	0.50	224.770	69
	7	28	288	0.25	0.50	226.420	68
	8	32	291	0.30	0.59	228.060	69
	9	36	291	0.30	0.59	229.910	69
	10	40	290	0.30	0.59	231.770	69
	11	44	291	0.30	0.59	233.510	68
	12	48	289	0.30	0.59	235.300	69
Traverse 2	1	52	288	0.30	0.59	237.120	
	2	56	290	0.30	0.59	238.930	70
	3	60	290	0.35	0.69	240.750	69
	4	64	289	0.35	0.69	242.760	69
	5	68	289	0.35	0.69	244.890	69
	6	72	288	0.35	0.69	246.750	69
	7	76	288	0.35	0.69	248.680	69
	8	80	289	0.35	0.69	250.760	69
	9	84	288	0.35	0.69	252.800	70
	10	88	288	0.35	0.69	254.840	70
	11	92	288	0.30	0.60	256.910	70
	12	96	288	0.30	0.60	258.820	70
					260.730	70	67

Calculations for: CertainTeed Zone 1 Dryer PM
Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: NGM

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	29.91	Check range	Within Criteria
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.34	Check average	
Volume of Water Vapour Collected, Vwc (cu.ft)	31.416	Within Criteria	
Stack Gas Moisture Content (% as decimal)	0.420		
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	24.58		

Isokineticity Checks

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	750	0.20	0.40	29.14	29.93	528	1.440	1.427
	2	8	750	0.20	0.40	29.14	29.93	528	1.460	1.447
	3	12	748	0.25	0.49	32.54	29.94	528	1.630	1.616
	4	16	749	0.25	0.49	32.56	29.94	528	1.620	1.606
	5	20	750	0.25	0.50	32.58	29.94	529	1.620	1.604
	6	24	748	0.25	0.50	32.54	29.94	529	1.650	1.634
	7	28	748	0.25	0.50	32.54	29.94	529	1.640	1.624
	8	32	751	0.30	0.59	35.71	29.94	529	1.850	1.832
	9	36	751	0.30	0.59	35.71	29.94	529	1.860	1.842
	10	40	750	0.30	0.59	35.69	29.94	529	1.740	1.723
	11	44	751	0.30	0.59	35.71	29.94	529	1.790	1.773
	12	48	749	0.30	0.59	35.66	29.94	529	1.820	1.803
Traverse 2	1	52	748	0.30	0.59	35.64	29.90	530	1.810	1.787
	2	56	750	0.30	0.59	35.69	29.94	530	1.820	1.799
	3	60	750	0.35	0.69	38.55	29.94	528	2.010	1.993
	4	64	749	0.35	0.69	38.52	29.95	528	2.130	2.112
	5	68	749	0.35	0.69	38.52	29.95	528	1.860	1.844
	6	72	748	0.35	0.69	38.50	29.95	528	1.930	1.914
	7	76	748	0.35	0.69	38.50	29.95	528	2.080	2.063
	8	80	749	0.35	0.69	38.52	29.95	529	2.040	2.021
	9	84	748	0.35	0.69	38.50	29.95	529	2.040	2.021
	10	88	748	0.35	0.69	38.50	29.95	529	2.070	2.051
	11	92	748	0.30	0.60	35.64	29.95	529	1.910	1.892
	12	96	748	0.30	0.60	35.64	29.94	529	1.910	1.892
Total	96	Average 749	Average 0.30	Average 0.59	Average 35.43	Average 29.94	Average 528	Total 43.730	Total 43.318	Average 100.58

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 1 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: NGM

Test Start: 1:30 PM
Test Finish: 2:00 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	14.6	4.8	12.0	0.0	144.0	4.0	140
5	14.7	4.7	13.0	0.0	143.0	2.0	141
10	14.6	4.7	12.0	0.0	143.0	3.0	140
15	14.6	4.8	13.0	0.0	144.0	1.0	143
20	14.7	4.7	18.0	0.0	143.0	0.0	143
25	14.6	4.8	13.0	0.0	146.0	2.0	144
30	14.6	4.7	19.0	0.0	145.0	0.0	145
Average:	14.6	4.7	14.3	0.0	144.0	1.7	142

DATA ENTRY

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.7 m

Stack Diameter: 1.22 m

Reference Temperature, Tref (F): 77
(K): 298
Reference Pressure, Pref (in.Hg): 29.92
(Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	28-Oct-15	29-Oct-15	29-Oct-15	n/a
Start Time	-	-	1:52 PM	9:55 AM	1:20 PM	n/a
End Time	-	-	3:30 PM	11:45 AM	3:00 PM	n/a
Total Sampling Time	-	min	96	96	96	96
Stack Diameter	D	in.	48	48	48	48
Average Stack Gas Temperature	Ts	F	291	296	289	292
Average Dry Gas Meter Temperature	Tm	F	57	68	68	65
Barometric Pressure	Pbar	in.Hg	30.02	29.98	29.90	29.97
Stack Static Pressure	Pstatic	in.H2O	0.20	0.20	0.20	0.20
Average Pressure Drop (Head)	dP	in.H2O	0.43	0.37	0.30	0.37
Average deltaH Orifice	dH	in.H2O	1.52	0.89	0.59	1.00
Average Meter Temperature	Tm	F	57	68	68	65
Gas Sample Volume	Vm	cu.ft	69.35	50.84	43.73	54.64
Average Isokinetics	I	%	119.09	103.57	100.58	107.75
Nozzle Diameter	Dn	in.	0.305	0.305	0.305	0.305
Pitot Coefficient	Cp	-	0.756	0.756	0.756	0.756
Gamma, meter constant	y	-	0.974	0.974	0.974	0.974
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	14.5	14.7	14.6	14.6
Stack Gas Carbon Dioxide Content	Cco2	%	4.8	4.7	4.7	4.8
Stack Gas Nitrogen Content	Cn2	%	80.7	80.6	80.6	80.6
Stack Gas Sulphur Dioxide Content	Cso2	ppm	0.0	0.0	0.0	0.0
Stack Gas Nitrogen Oxides Content	Cnox	ppm	140.1	132.9	144.0	139.0
Stack Gas Carbon Monoxide Content	Cco	ppm	14.4	13.9	14.3	14.2
Volume of Water Collected	Vw	mL	683.0	727.0	654.5	688.2
Particulate Collected from Filter	-	mg	17.0	17.8	11.6	15.4
Particulate Collected from Probe Wash	-	mg	2.8	3.3	0.7	2.3
Particulate Collected from Impinger Wash	-	mg	44.5	49.6	42.7	45.6
Total Particulate Collected (excl. impingers)	Mp	mg	19.7	21.1	12.3	17.7

Legend: F - degrees Fahrenheit
K - degrees Kelvin
Bar - bars
in.Hg - inches of mercury
in. - inches

in.H2O - inches of water
cu.ft - cubic feet
R - degrees Rankin
NOx - as NO2

CALCULATIONS

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.7 m

Stack Diameter: 1.22 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	As	sq.ft sq.m	As = $\pi \times ((D/12)^2) / 4$ As (sq.m) = As (sq.ft) x 0.0929	12.57 1.17	12.57 1.17	12.57 1.17	12.57 1.17
Barometric Pressure Stack Static Pressure Avg. Stack Temperature Avg. Meter Temperature Nozzle Diameter	Pbar Pstatic Ts Tm Dn	kPa kPa R R mm	Pbar (kPa) = Pbar (in.Hg) x 3.386 Pstatic (kPa) = Pstatic (in.H2O) x 0.249 Ts (R) = Ts (F) + 460 Tm (R) = Tm (F) + 460 Dn (mm) = Dn (in.) x 25.4	101.6 0.05 751 517 8	101.5 0.05 756 528 8	101.2 0.05 749 528 8	101.5 0.05 752.0 524.7 7.7
Gas Meter Pressure Sample Volume at Ref Cond Volume of Water Vapour Water Fraction	Pm Vm Vwc Bwo	in.Hg cu.ft cu.m cu.ft	Pm = Pbar + (dH / 13.6) Vm = Tref/Pref x (Vm x Pm x y) / Tm Vm (cu.m) = 0.02832 x Vmc (cu.ft) Vwc = 0.0480 x Vw Bwo = Vwc / (Vwc + Vmc)	30.13 70.60 2.00 32.78 0.317	30.05 50.54 1.43 34.90 0.408	29.94 43.32 1.23 31.42 0.420	30.0 54.8 1.55 33.0 0.4
Molecular Weight, Dry Molecular Weight, Wet	Md Ms	lb/lb-mol lb/lb-mol	Md = 0.44 (Cco2) + 0.32 (Co2) + 0.28 (Cn2) Ms = Md (1 - Bwo) + (18 x Bwo)	29.35 25.75	29.34 24.71	29.34 24.58	29.3 25.0
Stack Pressure Stack Gas Velocity Actual Stack Gas Flow Rate Dry Stack Gas Flow Rate	Ps Us Q Qs	in.Hg ft/s m/s acfmin acfm Rcfm Rcms	Ps = Pbar + (Pstatic / 13.6) Us = 85.33 x Cp x ((dP x Ts)/(Ps x Ms))^0.5 Us (m/s) = 0.3048 x Us (ft/s) Q = 60 x Us x As Q(acfm) = Q(acfm) x 0.02831685 Qs = Q x (1-Bwo) x (Tref/Ts) x (Ps/Pref) Qs (Rcms) = 0.000472 x Qs (Rcfm)	30.03 41.43 12.63 31,234 884 15,310 7.23	29.99 39.62 12.08 29,872 846 12,587 5.94	29.91 35.43 10.80 26,710 756 11,097 5.24	30.0 38.8 11.8 29,272 829 12,998 6.1
Sulphur Dioxide - SO2 SO2 Measured Concentration Uncorrected @ Ref Cond SO2 Emission Rate	Cso2 Cso2 ERso2	ppm mg/Rcm g/s kg/hr	Measurement from Flue Gas Analyzer Cso2 (mg/Rcm) = Cso2 (ppm) x 2.62 ERso2 = Cso2/1000 x Qs ERso2 (kg/hr) = 3.6 x ERso2 (g/s)	0.00 0.00 0.00 0.00	0.00 0.00 0.00 0.00	0.00 0.00 0.00 0.00	0.00 0.00 0.00 0.00
SO2 Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cso2 Cso2 Cso2	mg/Rcm mg/Rcm mg/Rcm	Cso2 (11% O2) = Cso2 (mg/Rcm) x (20.9-11) / (20.9-Co2) Cso2 (3% O2) = Cso2 (mg/Rcm) x (20.9-3) / (20.9-Co2) Cso2 (12% CO2) = Cso2 (mg/Rcm) x (12/Cco2)	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00
Nitrogen Oxides - NOx NOx Measured Concentration Uncorrected @ Ref Cond NOx Emission Rate	Cnox Cnox ERnox	ppm mg/Rcm g/s kg/hr	Measurement from Flue Gas Analyzer Cnox (mg/Rcm) = Cnox (ppm) x 1.882 ERnox = Cnox/1000 x Qs ERnox (kg/hr) = 3.6 x ERnox (g/s)	140.14 263.75 1.91 6.86	132.86 250.04 1.49 5.35	144.00 271.01 1.42 5.11	139.00 261.60 1.60 5.77
NOx Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cnox Cnox Cnox	mg/Rcm mg/Rcm mg/Rcm	Cnox (11% O2) = Cnox (mg/Rcm) x (20.9-11) / (20.9-Co2) Cnox (3% O2) = Cnox (mg/Rcm) x (20.9-3) / (20.9-Co2) Cnox (12% CO2) = Cnox (mg/Rcm) x (12/Cco2)	410.00 741.31 658.00	396.60 717.09 636.65	427.03 772.11 685.68	411.21 743.50 660.11
Carbon Monoxide - CO CO Measured Concentration Uncorrected @ Ref Cond CO Emission Rate	Cco Cco ERco	ppm mg/Rcm g/s kg/hr	Measurement from Flue Gas Analyzer Cco (mg/Rcm) = Cco (ppm) x 1.145 ERco = Cco/1000 x Qs ERco (kg/hr) = 3.6 x ERco (g/s)	14.43 16.52 0.12 0.43	13.86 15.87 0.09 0.34	14.29 16.36 0.09 0.31	14.19 16.25 0.10 0.36
CO Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cco Cco Cco	mg/Rcm mg/Rcm mg/Rcm	Cco (11% O2) = Cco (mg/Rcm) x (20.9-11) / (20.9-Co2) Cco (3% O2) = Cco (mg/Rcm) x (20.9-3) / (20.9-Co2) Cco (12% CO2) = Cco (mg/Rcm) x (12/Cco2)	25.68 46.43 41.22	25.17 45.50 40.40	25.77 46.60 41.39	25.54 46.18 41.00
Particulate Concentration Particulate Emission Rate	Cs ERp	mg/Rcm g/s kg/hr	Cs = Mp / Vmc ERp = Cs/1000 x Qs ERp (kg/hr) = 3.6 x ERp (g/s)	9.85 0.07 0.26	14.71 0.09 0.31	10.03 0.05 0.19	11.53 0.07 0.25
Particulate Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cs Cs Cs	mg/Rcm mg/Rcm mg/Rcm	Cs (11% O2) = Cs x (20.9-11) / (20.9-Co2) Cs (3% O2) = Cs x (20.9-3) / (20.9-Co2) Cs (12% CO2) = Cs x (12/Cco2)	15.32 27.69 24.58	23.33 42.18 37.44	15.80 28.56 25.37	18.15 32.81 29.13

Legend:
 sq.ft - square feet
 sq.m - square metres
 Pi = 3.142
 R - degrees Rankin
 ppm - parts per million

in.Hg - inches of mercury
 cu.ft - cubic feet
 cu.m - cubic metres
 Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)
 Rcfm - dry Reference cubic feet per minute

mg/Rcm - milligrams per dry Reference cubic metre
 g/s - grams per second
 NOx - as NO2
 acfm - actual cubic feet per minute
 Rcms - dry Reference cubic metres per second

OFFICIAL STACK TESTING RESULTS

CertainTeed

McAdam, NB

Fuel: #2 Fuel Oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.7 m

Stack Diameter: 1.22 m

Parameter	Test 1	Test 2	Test 3	Average	NBDELG Limits
Test ID Test Date	PM-1 28-Oct-15	PM-2 29-Oct-15	PM-3 29-Oct-15	- -	- -
Stack Gas Temperature (C) Moisture Content (%) Velocity (m/s) Volumetric Flow (Rcms)	144 31.7 12.6 7.23	147 40.8 12.1 5.94	143 42.0 10.8 5.24	144 38.2 11.8 6.14	- - - -
Oxygen - O2 (%) Carbon Dioxide - CO2 (%)	14.5 4.81	14.7 4.71	14.6 4.74	14.6 4.76	- -
Sulphur Dioxide - SO2 SO2 Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	0.0 0.0 0.00	0.0 0.0 0.00	0.0 0.0 0.00	0.0 0.0 0.00	- - -
Nitrogen Oxides - NOx NOx Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	140 264 6.86	133 250 5.35	144 271 5.11	139 262 5.77	- - -
Carbon Monoxide - CO CO Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	14.4 16.5 0.43	13.9 15.9 0.34	14.3 16.4 0.31	14.2 16.2 0.36	- - -
Particulate Matter - PM Particulate Concentration (mg/Rcm) Particulate Emission Rate (kg/hr)	9.85 0.26	14.7 0.31	10.0 0.19	11.5 0.25	- -

Legend: C - degrees Celsius

m/s - metres per second

Rcms - dry Reference cubic metres per second

ppm - parts per million

Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)

mg/Rcm - miligrams per dry Reference cubic metre

NOx - as NO2

ND - non-detectable

Particulate Recoveries: Impinger Catch, Probe Wash, Filter Catch

Client: CertainTeed
Facility: Zone 1 Dryer
Location: McAdam, NB
Job Number: 121811606

IMPIINGER CATCH

Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)			
	Date					Jar + Sample + Rinse (g)	Jar Tare (g)	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date								
	Analysed by										Trial 1	Trial 2	Trial 3	Average					
C5	113.1450	113.1452		113.1451	PM-1	1173.9	391.4	683.0	6.9	106.4	113.1904	113.1909		113.1907	0.0456	0.0445			
A1	106.0705	106.0704		106.0705	PM-2	1198.2	389.6	727.0	8.6	90.2	106.1207	106.1212		106.1210	0.0505	0.0496			
T4	109.2395	109.2396		109.2396	PM-3	1141.1	391.2	654.5	6.9	102.3	109.2830	109.2835		109.2833	0.0437	0.0427			
D6	110.4609	110.4610		110.4610	WB	455.3	390.0	65.3		65.3	110.4617	110.4615		110.4616	0.0007	0.000010			
Conc. (g/mL)																			

PROBE WASH




Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)			
	Date					Jar + Acetone (g)	Jar Tare (g)	Recovered Acetone (g)	Rinse Acetone	Total Acetone (g)	Date								
	Analysed by										Trial 1	Trial 2	Trial 3	Average					
Q3	111.5955	111.5955		111.5955	PM-1	398.9	324.6	74.3		74.3	111.5980	111.5985		111.5983	0.0028	0.0028			
T2	112.1702	112.1705		112.1704	PM-2	362.9	300.2	62.7		62.7	112.1734	112.1739		112.1737	0.0033	0.0033			
L3	111.2861	111.2864		111.2863	PM-3	344.2	299.8	44.4		44.4	111.2867	111.2872		111.2870	0.0007	0.0007			
G1	117.3946	117.3947		117.3947	AB	355.6	326.2	29.4		29.4	117.3931	117.3926		117.3929	-0.0018	0.000000			
Conc. (g/mL)																			

Density of Acetone: 0.7850 g/ml

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID *	Post Weights (g)				Particulate Weight from Filter (g)		
	Date:					Analysed by						
	Analysed by					Trial 1	Trial 2	Trial 3	Average			
Trial 1	Trial 2	Trial 3	Average									
1005-21	0.3717	0.3718		0.3718	PM-1	0.3888	0.3886		0.3887	0.0170		
0922-27	0.3691	0.3686		0.3689	PM-2	0.3867	0.3865		0.3866	0.0178		
0922-25	0.3707	0.3703		0.3705	PM-3	0.3820	0.3822		0.3821	0.0116		

Stack Gas Velocity Profiles
McAdam, NB



Raw Data for: Certainteed McAdam Zone 2 Dryer PM

Test #1

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-1
Date: 28-Oct-15
Personnel: TBH

Test Start: 2:45 PM
Test Finish: 4:30 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg): 17.8
Particulate Collected from Probe Wash (mg): 0.9
Particulate Collected from Impinger Wash (mg): 72.4
Total Particulate Collected (mg): 91.1

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	1029.8	680.4	349.4
2	100 mL H2O	1035.6	691.8	343.8
3	Blank	849.2	664.2	185.0
4	200g Silica Gel	1058.2	1033.7	24.5
			Total Weight Gain (g)	902.7
			Moisture Volume (mL)	902.7

30.02	O2, (%)	16.8	Stack Diameter, (in.)	48.00
0.20	CO2, (%)	3.2	Stack Area, (sq. ft.)	12.57
75	N2, (%)	80.0	Probe Length, (ft.)	6
902.7	CO(ppm)	11.7	Nozzle Diameter, (in.)	0.306
24	NOx (ppm)	83.1	Pitot Coefficient, (Cp)	0.788
4	SO2 (ppm)	0.7	Gamma, meter constant	1.033
4			Port length (in.)	4.000

NBDELG

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)
----------------	------------	-------------------------	--------------------------------	---------------------------	----------------------------	---------------------------	----------------------------

Traverse 1	1	4	241	0.26	0.71	493.94	
	2	8	242	0.31	0.84	497.72	55
	3	12	242	0.55	1.50	500.22	55
	4	16	238	0.60	1.65	503.02	56
	5	20	242	0.65	1.78	505.93	56
	6	24	242	0.74	2.03	509.08	56
	7	28	238	0.77	2.12	512.28	56
	8	32	241	0.64	1.76	515.32	56
	9	36	241	0.50	1.37	517.67	56
	10	40	242	0.54	1.48	520.52	57
	11	44	242	0.48	1.31	523.04	57
	12	48	248	0.32	0.87	525.12	57

Traverse 2	1	52	240	0.34	0.93	525.12	
	2	56	240	0.47	1.29	527.30	58
	3	60	240	0.50	1.38	529.54	58
	4	64	241	0.60	1.65	531.95	58
	5	68	242	0.65	1.79	534.59	58
	6	72	242	0.65	1.79	537.28	58
	7	76	242	0.72	1.98	540.31	58
	8	80	242	0.74	2.03	543.23	58
	9	84	242	0.64	1.76	546.38	58
	10	88	241	0.52	1.43	549.37	59
	11	92	241	0.40	1.13	552.02	59
	12	96	240	0.35	0.96	554.27	59

Calculations for: CertainTeed McAdam Zone 2 Dryer PM
Test #1

Client: CertainTeed
 Job Number: 121811606

Plant: Zone 2 Dryer
 Location: McAdam, NB
 Test: PM-1
 Date: 28-Oct-15
 Personnel: TBH

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)
 Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
 Volume of Water Vapour Collected, Vvc (cu.ft)
 Stack Gas Moisture Content (% as decimal)
 Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)

30.03
 29.19
 43.330
 0.390
 24.82

Isokineticity Checks

Check range
 Check average
 Within Criteria
 Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	701	0.26	0.71	33.25	30.07	515	1.860	2.016
	2	8	702	0.31	0.84	36.33	30.08	515	1.920	2.081
	3	12	702	0.55	1.50	48.39	30.13	515	2.500	2.714
	4	16	698	0.60	1.65	50.40	30.14	515	2.800	3.038
	5	20	702	0.65	1.78	52.60	30.15	515	2.910	3.159
	6	24	702	0.74	2.03	56.13	30.17	516	3.150	3.418
	7	28	698	0.77	2.12	57.09	30.18	516	3.200	3.473
	8	32	701	0.64	1.76	52.16	30.15	516	3.040	3.296
	9	36	701	0.50	1.37	46.10	30.12	516	2.350	2.546
	10	40	702	0.54	1.48	47.95	30.13	516	2.850	3.085
	11	44	702	0.48	1.31	45.21	30.12	516	2.520	2.727
	12	48	708	0.32	0.87	37.07	30.08	517	2.080	2.246
Traverse 2	1	52	700	0.34	0.93	37.99	30.09	517	2.180	2.352
	2	56	700	0.47	1.29	44.67	30.11	517	2.240	2.419
	3	60	700	0.50	1.38	46.07	30.12	517	2.410	2.603
	4	64	701	0.60	1.65	50.50	30.14	517	2.640	2.854
	5	68	702	0.65	1.79	52.60	30.15	517	2.690	2.909
	6	72	702	0.65	1.79	52.60	30.15	517	3.030	3.276
	7	76	702	0.72	1.98	55.36	30.17	517	2.920	3.159
	8	80	702	0.74	2.03	56.13	30.17	517	3.150	3.408
	9	84	702	0.64	1.76	52.20	30.15	518	2.990	3.230
	10	88	701	0.52	1.43	47.02	30.13	518	2.650	2.857
	11	92	701	0.40	1.13	41.24	30.10	519	2.250	2.422
	12	96	700	0.35	0.96	38.55	30.09	519	2.210	2.378
Total		Average	Average	Average	Average	Average	Average	Total	Total	Average
96		701	0.54	1.48	47.40	30.13	516	62.540	67.666	103.56

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-1
Date: 28-Oct-15
Personnel: TBH

Test Start: 3:00 PM
Test Finish: 3:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	16.9	3.0	11.0	1.0	74.0	1.0	73
5	17.0	3.0	10.0	1.0	75.0	1.0	74
10	16.9	3.0	10.0	0.0	79.0	1.0	78
15	16.9	3.1	11.0	0.0	81.0	1.3	79
20	16.4	3.4	14.0	0.0	91.0	1.5	89
25	16.6	3.3	14.0	1.0	98.0	2.0	88
30	16.8	3.9	12.0	2.0	84.0	2.3	83
Average:	16.8	3.2	11.7	0.7	83.1	1.4	81

Raw Data for: Certainteed McAdam Zone 2 Dryer PM

Test #2

Client: CertainTeed	Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
Job Number: 121811606	1	100 mL H ₂ O	1038.4	695.3	343.1
Plant: Zone 2 Dryer	2	100 mL H ₂ O	1011.6	719.8	291.8
Location: McAdam, NB	3	Blank	913.3	663.8	249.5
Test: PM-2	4	200g Silica Gel	1033.6	1009.0	24.6
Date: 28-Oct-15					
Personnel: TBH/AW					
Test Start: 11:05 AM			Total Weight Gain (g)	909.0	
Test Finish: 12:45 PM			Moisture Volume (mL)	909.0	

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H₂O)
Ambient Temp, (°F)
H₂O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

29.98	O ₂ , (%)	16.7	Stack Diameter, (in.)	48.00
0.20	CO ₂ , (%)	3.2	Stack Area, (sq. ft.)	12.57
70	N ₂ , (%)	80.1	Probe Length, (ft.)	6
909.0	CO(ppm)	10.3	Nozzle Diameter, (in.)	0.306
24	NOx (ppm)	72.4	Pitot Coefficient, (Cp)	0.788
4	SO ₂ (ppm)	0.9	Gamma, meter constant	1.033
4			Port length (in.)	4

NBDELG

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)
Traverse 1	1	4	251	0.25	0.68	556.500	
	2	8	248	0.25	0.68	558.050	56
	3	12	247	0.55	1.49	559.390	56
	4	16	241	0.59	1.63	561.900	57
	5	20	239	0.68	1.88	564.700	58
	6	24	238	0.75	2.08	567.610	58
	7	28	241	0.76	2.10	570.770	58
	8	32	241	0.65	1.79	573.960	58
	9	36	241	0.50	1.38	577.000	61
	10	40	241	0.53	1.46	579.440	61
	11	44	241	0.46	1.24	582.200	62
	12	48	241	0.30	0.83	584.721	58

Traverse 2	1	52	241	0.35	0.97	588.940	
	2	56	241	0.44	1.22	591.350	62
	3	60	242	0.52	1.41	593.990	63
	4	64	241	0.58	1.61	596.680	63
	5	68	241	0.67	1.86	599.730	63
	6	72	241	0.65	1.80	602.640	63
	7	76	241	0.71	1.97	605.780	63
	8	80	241	0.76	2.11	609.000	63
	9	84	242	0.64	1.78	611.990	63
	10	88	242	0.54	1.50	614.800	64
	11	92	243	0.41	1.13	617.050	64
	12	96	242	0.33	0.91	619.180	64

Calculations for: Certainteed McAdam Zone 2 Dryer PM
Test #2

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-2
Date: 28-Oct-15
Personnel: TBH/AW

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	29.99
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.18
Volume of Water Vapour Collected, Vvc (cu.ft)	43.632
Stack Gas Moisture Content (% as decimal)	0.393
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	24.79

Isokineticity Checks

Check range
Check average
Within Criteria
Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	711	0.25	0.68	32.88	30.03	516	1.550	1.672
	2	8	708	0.25	0.68	32.81	30.03	517	1.340	1.444
	3	12	707	0.55	1.49	48.63	30.09	517	2.510	2.711
	4	16	701	0.59	1.63	50.15	30.10	518	2.800	3.019
	5	20	699	0.68	1.88	53.76	30.12	517	2.910	3.143
	6	24	698	0.75	2.08	56.42	30.13	517	3.160	3.415
	7	28	701	0.76	2.10	56.92	30.13	518	3.190	3.444
	8	32	701	0.65	1.79	52.64	30.11	519	3.040	3.270
	9	36	701	0.50	1.38	46.17	30.08	519	2.440	2.622
	10	40	701	0.53	1.46	47.53	30.09	520	2.760	2.964
	11	44	701	0.46	1.24	44.04	30.07	520	2.521	2.703
	12	48	701	0.30	0.83	35.76	30.04	520	2.279	2.441
Traverse 2	1	52	701	0.35	0.97	38.63	30.05	520	1.940	2.079
	2	56	701	0.44	1.22	43.31	30.07	520	2.410	2.584
	3	60	702	0.52	1.41	47.16	30.08	521	2.640	2.829
	4	64	701	0.58	1.61	49.73	30.10	521	2.690	2.884
	5	68	701	0.67	1.86	53.44	30.12	521	3.050	3.272
	6	72	701	0.65	1.80	52.64	30.11	521	2.910	3.121
	7	76	701	0.71	1.97	55.02	30.12	521	3.140	3.369
	8	80	701	0.76	2.11	56.92	30.14	521	3.220	3.456
	9	84	702	0.64	1.78	52.27	30.11	521	2.990	3.204
	10	88	702	0.54	1.50	48.01	30.09	522	2.810	3.006
	11	92	703	0.41	1.13	41.87	30.06	522	2.250	2.405
	12	96	702	0.33	0.91	37.53	30.05	522	2.130	2.275
Total		Average 96	Average 702	Average 0.54	Average 1.48	Average 47.26	Average 30.09	Average 519	Total 62.680	Average 103.52

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-2
Date: 28-Oct-15
Personnel: TBH/AW

Test Start: 11:30 AM
Test Finish: 12:00 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	17.0	3.3	10.0	0.0	75.0	1.5	73
5	17.0	3.0	9.0	1.0	74.0	1.5	72
10	16.8	3.0	11.0	1.0	75.0	1.5	73
15	16.5	3.4	12.0	0.0	76.0	1.3	74
20	16.4	3.4	11.0	1.0	69.0	1.3	67
25	16.5	3.3	10.0	2.0	68.0	1.3	67
30	17.0	3.0	9.0	1.0	70.0	1.5	68
Average:	16.7	3.2	10.3	0.9	72.4	1.4	71

Raw Data for: CertainTeed McAdam Zone 2 Dryer PM

Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: TBH/AW

Test Start: 2:15 PM
Test Finish: 4:00 PM

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every __ mins
Regulatory Agency

Particulate Collected from Filter (mg):	12.6
Particulate Collected from Probe Wash (mg):	5.2
Particulate Collected from Impinger Wash (mg):	38.1
Total Particulate Collected (mg):	55.9

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	1038.7	685.0	353.7
2	100 mL H2O	1020.5	692.2	328.3
3	Blank	850.7	664.1	186.6
4	200g Silica Gel	1060.2	1033.2	27.0

Total Weight Gain (g) 895.6
Moisture Volume (mL) 895.6

29.90	O2, (%)	16.8
0.20	CO2, (%)	3.2
77.40	N2, (%)	80.0
895.60	CO(ppm)	10.4
24	NOx (ppm)	78.7
4	SO2 (ppm)	0.3

Stack Diameter, (in.)	48.00
Stack Area, (sq. ft.)	12.57
Probe Length, (ft.)	6
Nozzle Diameter, (in.)	0.306
Pitot Coefficient, (Cp)	0.788
Gamma, meter constant	1.033
Port length (in.)	4

NBDELG

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp	
						Inlet (°F)	Outlet (°F)
Traverse 1	1	4	243	0.30	619.380	621.310	58
	2	8	243	0.48	623.680	60	59
	3	12	243	0.51	626.140	60	59
	4	16	243	0.58	628.750	61	59
	5	20	243	0.63	631.500	62	59
	6	24	243	0.68	634.340	63	59
	7	28	242	0.71	637.240	64	59
	8	32	242	0.80	640.130	64	60
	9	36	243	0.82	643.290	64	61
	10	40	242	0.68	646.150	64	61
	11	44	242	0.50	648.610	66	60
	12	48	241	0.38	650.770	65	60
Traverse 2	1	52	242	0.38	650.770	652.970	60
	2	56	241	0.45	655.240	65	60
	3	60	241	0.56	657.950	65	60
	4	64	242	0.63	660.400	66	61
	5	68	242	0.70	663.270	66	61
	6	72	241	0.75	666.260	65	60
	7	76	242	0.80	669.610	67	61
	8	80	243	0.69	672.280	68	63
	9	84	245	0.58	674.950	69	64
	10	88	246	0.52	677.240	69	64
	11	92	246	0.48	679.750	68	63
	12	96	246	0.33	681.780	68	63

Calculations for: CertainTeed McAdam Zone 2 Dryer PM
Test #3

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: TBH/AW

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)	29.91	Check range	Within Criteria
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	29.18	Check average	
Volume of Water Vapour Collected, Vwc (cu.ft)	42.989	Within Criteria	
Stack Gas Moisture Content (% as decimal)	0.393		
Stack Gas Molecular Weight, Wet Basis, Ms (lb/lb-mole)	24.79		

Isokineticity Checks

Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref., Vmc (cu. ft.)	Isokinetics I (%)
Traverse 1	1	4	703	0.30	0.72	35.86	29.95	518	1.930	2.069
	2	8	703	0.48	1.15	45.36	29.98	520	2.370	2.536
	3	12	703	0.51	1.22	46.76	29.99	520	2.460	2.633
	4	16	703	0.58	1.39	49.86	30.00	520	2.610	2.792
	5	20	703	0.63	1.51	51.97	30.01	521	2.750	2.940
	6	24	703	0.68	1.63	53.99	30.02	521	2.840	3.034
	7	28	702	0.71	1.71	55.13	30.03	522	2.900	3.096
	8	32	702	0.80	1.93	58.52	30.04	522	2.890	3.084
	9	36	703	0.82	1.98	59.29	30.05	523	3.160	3.369
	10	40	702	0.68	1.64	53.95	30.02	523	2.860	3.047
	11	44	702	0.50	1.21	46.26	29.99	523	2.460	2.615
	12	48	701	0.38	0.92	40.30	29.97	523	2.160	2.297
Traverse 2	1	52	702	0.38	0.92	40.33	29.90	523	2.200	2.334
	2	56	701	0.45	1.08	43.86	29.97	523	2.270	2.414
	3	60	701	0.56	1.36	48.93	29.98	523	2.710	2.883
	4	64	702	0.63	1.52	51.93	30.00	524	2.450	2.603
	5	68	702	0.70	1.69	54.74	30.01	524	2.870	3.050
	6	72	701	0.75	1.81	56.62	30.02	523	2.990	3.185
	7	76	702	0.80	1.93	58.52	30.03	524	3.350	3.560
	8	80	703	0.69	1.67	54.39	30.04	526	2.670	2.830
	9	84	705	0.58	1.40	49.93	30.02	527	2.670	2.823
	10	88	706	0.52	1.26	47.31	30.00	527	2.290	2.419
	11	92	706	0.48	1.15	45.46	29.99	526	2.510	2.656
	12	96	706	0.33	0.79	37.69	29.98	526	2.030	2.148
Total	96	Average 703	Average 0.58	Average 1.40	Average 49.46	Average 30.00	Average 523	Total 62.400	Total 66.416	Average 98.54

Combustion Gas Data for: CertainTeed

Client: CertainTeed
Job Number: 121811606

Plant: Zone 2 Dryer
Location: McAdam, NB
Test: PM-3
Date: 29-Oct-15
Personnel: TBH/AW

Test Start: 2:30 PM
Test Finish: 3:00 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	16.9	3.1	10.0	0.0	75.0	1.5	72
5	16.8	3.2	10.0	0.0	76.0	1.5	73
10	16.9	3.1	9.0	0.1	81.0	1.5	79
15	16.8	3.2	10.0	0.0	81.0	1.5	80
20	16.8	3.2	12.0	0.0	79.0	1.5	76
25	16.7	3.2	13.0	1.0	79.0	1.5	77
30	17.0	3.1	9.0	1.0	80.0	1.5	78
Average:		16.8	3.2	10.4	0.3	78.7	1.5
							76

DATA ENTRY

CertainTeed

McAdam, NB

Fuel: #2 Fuel oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.7 m

Stack Diameter: 1.22 m

Reference Temperature, Tref (F): 77
(K): 298
Reference Pressure, Pref (in.Hg): 29.92
(Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	28-Oct-15	28-Oct-15	29-Oct-15	n/a
Start Time	-	-	2:45 PM	11:05 AM	2:15 PM	n/a
End Time	-	-	4:30 PM	12:45 PM	4:00 PM	n/a
Total Sampling Time	-	min	96	96	96	96
Stack Diameter	D	in.	48	48	48	48
Average Stack Gas Temperature	Ts	F	241	242	243	242
Average Dry Gas Meter Temperature	Tm	F	56	59	63	59
Barometric Pressure	Pbar	in.Hg	30.02	29.98	29.90	29.97
Stack Static Pressure	Pstatic	in.H2O	0.20	0.20	0.20	0.20
Average Pressure Drop (Head)	dP	in.H2O	0.54	0.54	0.58	0.55
Average deltaH Orifice	dH	in.H2O	1.48	1.48	1.40	1.45
Average Meter Temperature	Tm	F	56	59	63	59
Gas Sample Volume	Vm	cu.ft	62.54	62.68	62.40	62.54
Average Isokinetics	I	%	103.56	103.52	98.54	101.87
Nozzle Diameter	Dn	in.	0.306	0.306	0.306	0.306
Pitot Coefficient	Cp	-	0.788	0.788	0.788	0.788
Gamma, meter constant	y	-	1.033	1.033	1.033	1.033
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	16.8	16.7	16.8	16.8
Stack Gas Carbon Dioxide Content	Cco2	%	3.2	3.2	3.2	3.2
Stack Gas Nitrogen Content	Cn2	%	80.0	80.1	80.0	80.0
Stack Gas Sulphur Dioxide Content	Cso2	ppm	0.7	0.9	0.3	0.6
Stack Gas Nitrogen Oxides Content	Cnox	ppm	83.1	72.4	78.7	78.1
Stack Gas Carbon Monoxide Content	Cco	ppm	11.7	10.3	10.4	10.8
Volume of Water Collected	Vw	mL	902.7	909.0	895.6	902.4
Particulate Collected from Filter	-	mg	17.8	20.0	12.6	16.8
Particulate Collected from Probe Wash	-	mg	0.9	16.0	5.2	7.4
Particulate Collected from Impinger Wash	-	mg	72.4	46.9	38.1	52.5
Total Particulate Collected (excl. impingers)	Mp	mg	18.7	36.0	17.8	24.2

Legend: F - degrees Fahrenheit
K - degrees Kelvin
Bar - bars
in.Hg - inches of mercury
in. - inches

in.H2O - inches of water
cu.ft - cubic feet
R - degrees Rankin
NOx - as NO2

CALCULATIONS

CertainTeed
 McAdam, NB
 Fuel: #2 Fuel oil
 Operating Conditions: Normal
 Emission Control Equipment:
 Stack Height from Grade: 6.7 m
 Stack Diameter: 1.22 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	As	sq.ft sq.m	As = Pi x ((D/12)^2) / 4 As (sq.m) = As (sq.ft) x 0.0929	12.57 1.17	12.57 1.17	12.57 1.17	12.57 1.17
Barometric Pressure Stack Static Pressure Avg. Stack Temperature Avg. Meter Temperature Nozzle Diameter	Pbar Pstatic Ts Tm Dn	kPa kPa R R mm	Pbar (kPa) = Pbar (in.Hg) x 3.386 Pstatic (kPa) = Pstatic (in.H2O) x 0.249 Ts (R) = Ts (F) + 460 Tm (R) = Tm (F) + 460 Dn (mm) = Dn (in.) x 25.4	101.6 0.05 701 516 8	101.5 0.05 702 519 8	101.2 0.05 703 523 8	101.5 0.05 702.0 519.4 7.8
Gas Meter Pressure Sample Volume at Ref Cond Volume of Water Vapour Water Fraction	Pm Vmc Vwc Bwo	in.Hg cu.ft cu.m cu.ft	Pm = Pbar + (dH / 13.6) Vmc = Tref/Pref x (Vm x Pm x y) / Tm Vmc (cu.m) = 0.02832 x Vmc (cu.ft) Vwc = 0.0480 x Vw Bwo = Vwc / (Vwc + Vmc)	30.13 67.66 1.92 43.33 0.390	30.09 67.33 1.91 43.63 0.393	30.00 66.42 1.88 42.99 0.393	30.1 67.1 1.90 43.3 0.4
Molecular Weight, Dry Molecular Weight, Wet	Md Ms	lb/lb-mol lb/lb-mol	Md = 0.44 (Cco2) + 0.32 (Co2) + 0.28 (Cn2) Ms = Md (1 - Bwo) + (18 x Bwo)	29.19 24.82	29.18 24.79	29.18 24.79	29.2 24.8
Stack Pressure Stack Gas Velocity Actual Stack Gas Flow Rate Dry Stack Gas Flow Rate	Ps Us Q Qs	in.Hg ft/s m/s acfmin acfm Rcfm Rcfms	Ps = Pbar + (Pstatic / 13.6) Us = 85.33 x Cp x ((dP x Ts)/(Ps x Ms))^0.5 Us (m/s) = 0.3048 x Us (ft/s) Q = 60 x Us x As Q(acfm) = Q(acfm) x 0.02831685 Qs = Q x (1-Bwo) x (Tref/Ts) x (Ps/Pref) Qs (Rcfms) = 0.000472 x Qs (Rcfm)	30.03 47.40 14.45 35.739 1,012 16,745 7.90	29.99 47.26 14.41 35,634 1,009 16,581 7.83	29.91 49.46 15.07 37,290 1,056 17,294 8.16	30.0 48.0 14.6 36,221 1,026 16,873 8.0
Sulphur Dioxide - SO2 SO2 Measured Concentration Uncorrected @ Ref Cond SO2 Emission Rate	Cso2 Cso2 ERs02	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cso2 (mg/Rem) = Cso2 (ppm) x 2.62 ERs02 = Cso2/1000 x Qs ERs02 (kg/hr) = 3.6 x ERs02 (g/s)	0.71 1.87 0.01 0.05	0.86 2.25 0.02 0.06	0.30 0.79 0.01 0.02	0.62 1.63 0.01 0.05
SO2 Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cso2 Cso2 Cso2	mg/Rem mg/Rem mg/Rem	Cso2 (11% O2) = Cso2 (mg/Rem) x (20.9-11) / (20.9-Co2) Cso2 (3% O2) = Cso2 (mg/Rem) x (20.9-3) / (20.9-Co2) Cso2 (12% CO2) = Cso2 (mg/Rem) x (12/Cco2)	4.50 8.14 6.92	5.32 9.61 8.39	1.92 3.46 2.99	3.91 7.07 6.10
Nitrogen Oxides - NOx NOx Measured Concentration Uncorrected @ Ref Cond NOx Emission Rate	Cnox Cnox ERnox	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cnox (mg/Rem) = Cnox (ppm) x 1.882 ERnox = Cnox/1000 x Qs ERnox (kg/hr) = 3.6 x ERnox (g/s)	83.14 156.47 1.24 4.45	72.43 136.31 1.07 3.84	78.71 148.14 1.21 4.35	78.10 146.98 1.17 4.22
NOx Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cnox Cnox Cnox	mg/Rem mg/Rem mg/Rem	Cnox (11% O2) = Cnox (mg/Rem) x (20.9-11) / (20.9-Co2) Cnox (3% O2) = Cnox (mg/Rem) x (20.9-3) / (20.9-Co2) Cnox (12% CO2) = Cnox (mg/Rem) x (12/Cco2)	376.65 681.01 578.90	322.73 583.52 509.28	361.10 652.90 564.09	353.49 639.14 550.75
Carbon Monoxide - CO CO Measured Concentration Uncorrected @ Ref Cond CO Emission Rate	Cco Cco ERco	ppm mg/Rem g/s kg/hr	Measurement from Flue Gas Analyzer Cco (mg/Rem) = Cco (ppm) x 1.145 ERco = Cco/1000 x Qs ERco (kg/hr) = 3.6 x ERco (g/s)	11.71 13.41 0.11 0.38	10.29 11.78 0.09 0.33	10.43 11.94 0.10 0.35	10.81 12.38 0.10 0.35
CO Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cco Cco Cco	mg/Rem mg/Rem mg/Rem	Cco (11% O2) = Cco (mg/Rem) x (20.9-11) / (20.9-Co2) Cco (3% O2) = Cco (mg/Rem) x (20.9-3) / (20.9-Co2) Cco (12% CO2) = Cco (mg/Rem) x (12/Cco2)	32.29 58.38 49.62	27.88 50.42 44.00	29.11 52.63 45.47	29.76 53.81 46.36
Particulate Concentration Particulate Emission Rate	Cs ERP	mg/Rem g/s kg/hr	Cs = Mp / Vmc ERP = Cs/1000 x Qs ERP (kg/hr) = 3.6 x ERP (g/s)	9.76 0.08 0.28	18.91 0.15 0.53	9.46 0.08 0.28	12.71 0.10 0.36
Particulate Concentration Corrected to 11% O2 Corrected to 3% O2 Corrected to 12% CO2	Cs Cs Cs	mg/Rem mg/Rem mg/Rem	Cs (11% O2) = Cs x (20.9-11) / (20.9-Co2) Cs (3% O2) = Cs x (20.9-3) / (20.9-Co2) Cs (12% CO2) = Cs x (12/Cco2)	23.49 42.48 36.11	44.76 80.94 70.64	23.07 41.71 36.04	30.44 55.04 47.59

Legend:
 sq.ft - square feet
 sq.m - square metres
 Pi - 3.142
 R - degrees Rankin
 ppm - parts per million

in.Hg - inches of mercury
 cu.ft - cubic feet
 cu.m - cubic metres
 Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)
 Rcfm - dry Reference cubic feet per minute

mg/Rcm - milligrams per dry Reference cubic metre
 g/s - grams per second
 NOx - as NO2
 acfm - actual cubic feet per minute
 Rcms - dry Reference cubic metres per second

OFFICIAL STACK TESTING RESULTS

CertainTeed

McAdam, NB

Fuel: #2 Fuel oil

Operating Conditions: Normal

Emission Control Equipment:

Stack Height from Grade: 6.7 m

Stack Diameter: 1.22 m

Parameter	Test 1	Test 2	Test 3	Average	NBDELG Limits
Test ID Test Date	PM-1 28-Oct-15	PM-2 28-Oct-15	PM-3 29-Oct-15	- -	- -
Stack Gas Temperature (C) Moisture Content (%) Velocity (m/s) Volumetric Flow (Rcms)	116 39.0 14.4 7.90	117 39.3 14.4 7.83	117 39.3 15.1 8.16	117 39.2 14.6 7.96	- - - -
Oxygen - O2 (%) Carbon Dioxide - CO2 (%)	16.8 3.24	16.7 3.21	16.8 3.15	16.8 3.20	- -
Sulphur Dioxide - SO2 SO2 Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	0.71 1.87 0.05	0.86 2.25 0.06	0.30 0.79 0.02	0.62 1.63 0.05	- - -
Nitrogen Oxides - NOx NOx Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	83.1 156 4.45	72.4 136 3.84	78.7 148 4.35	78.1 147 4.22	- - -
Carbon Monoxide - CO CO Measured Concentration (ppm) Uncorrected at Ref Cond (mg/Rcm) Emission Rate (kg/hr)	11.7 13.4 0.38	10.3 11.8 0.33	10.4 11.9 0.35	10.8 12.4 0.35	- - -
Particulate Matter - PM Particulate Concentration (mg/Rcm) Particulate Emission Rate (kg/hr)	9.76 0.28	18.9 0.53	9.46 0.28	12.7 0.36	- -

Legend: C - degrees Celsius

m/s - metres per second

Rcms - dry Reference cubic metres per second

ppm - parts per million

Ref Cond - Reference temperature and pressure (25 C and 101.3 kPa)

mg/Rcm - miligrams per dry Reference cubic metre

NOx - as NO2

ND - non-detectable

Particulate Recoveries: Impinger Catch, Probe Wash, Filter Catch

Client: CertainTeed
Facility: Zone 2 Dryer
Location: McAdam, NB
Job Number: 121811606

IMPINGER CATCH

Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)		
	Date			Analysed by			Jar + Sample + Rinse (g)	Jar Tare (g)	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date						
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average			Trial 1	Trial 2	Trial 3	Average			
G5	112.8749	112.8750		112.8750	PM-1	1345.9	376.0	902.7	9.6	76.6	112.9479	112.9484		112.9482	0.0732	0.0724		
D3	107.1630	107.1630		107.1630	PM-2	1390.5	378.1	909.0	20.4	123.8	107.2109	107.2114		107.2112	0.0482	0.0469		
D2	112.1295	112.1296		112.1296	PM-3	1335.7	378.3	895.6	16.9	78.7	112.1682	112.1687		112.1685	0.0389	0.0381		
															Conc. (g/mL)			
D6	110.4609	110.4610		110.4610	WB	455.3	390.0	65.3		65.3	110.4617	110.4615		110.4616	0.0007	0.000010		

PROBE WASH




Container ID	Beaker Pre Weights (g)				Sample ID	Recoveries					Beaker Post Weights (g)				Uncorrected Particulate Weight (g)	Corrected Particulate Weight (g)		
	Date			Analysed by			Jar + Acetone (g)	Jar Tare (g)	Recovered Acetone (g)	Rinse Acetone	Total Acetone (g)	Date						
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average			Trial 1	Trial 2	Trial 3	Average			
N1	112.7058	112.7057		112.7058	PM-1	352.8	302.3	50.5		50.5	112.7064	112.7069		112.7067	0.0009	0.0009		
S5	108.9285	108.9283		108.9284	PM-2	424.3	301.6	122.7		122.7	108.9442	108.9447		108.9445	0.0160	0.0160		
L6	109.8359	109.8359		109.8359	PM-3	386.7	299.1	87.6		87.6	109.8408	109.8413		109.8411	0.0052	0.0052		
															Conc. (g/mL)			
G1	117.3946	117.3947		117.3947	AB	355.6	326.2	29.4		29.4	117.3931	117.3926		117.3929	-0.0018	0.000000		

Density of Acetone: 0.7850 g/ml

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID *	Post Weights (g)				Particulate Weight from Filter (g)
	Analysed by			Date:		Analysed by			Date:	
	Trial 1	Trial 2	Trial 3	Average		Trial 1	Trial 2	Trial 3	Average	
0922-26	0.3698	0.3693		0.3696	PM-1	0.3873	0.3874		0.3874	0.0178
0922-23	0.3704	0.3700		0.3702	PM-2.1	0.3750	0.3751		0.3751	0.0049
0922-30	0.3689	0.3686		0.3688	PM-2.2	0.3835	0.3843		0.3839	0.0152
0922-21	0.3698	0.3694		0.3696	PM-3	0.3820	0.3825		0.3823	0.0126

Stack Gas Velocity Profiles
McAdam, NB



Project: 121311606 Certanteed
Test: Zone 1 Dryer PM-2
Date: Dec 11, 2015
Analyst: TBH

Hand Calculations
Page 1 of 6

Absolute stack gas pressure (Ps) in in.Hg is:

$$Ps = P_{bar} + \frac{P_{static} \text{ in.H}_2\text{O}}{13.6 \text{ in.H}_2\text{O/in.Hg}}$$

$$Ps = \underline{29.98} + \frac{\underline{0.20}}{13.6}$$

$$Ps = \underline{29.99} \text{ in.Hg}$$

The molecular weight of the stack gas on a dry basis (Md) in 1b/1b-mole is:

$$Md = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 [(\%N_2)]$$

$$Md = 0.44 \times \underline{4.71} + 0.32 \times \underline{14.66} + 0.28 (\underline{80.63} + \underline{\quad}) \\ + 0.40 (\underline{\quad} + \underline{\quad})$$

$$Md = \underline{2.07} + \underline{4.69} + \underline{27.58} + \underline{\quad}$$

$$B \quad Md = \underline{29.34} \text{ lb/lb-mole}$$

The volume of water vapour collected at reference conditions (Vwc) in ft³ is:

$$Vwc = 0.0480 \text{ ft}^3/\text{mL} \times \text{volume of moisture collected mL.}$$

$$Vwc = 0.0480 \times \underline{727.0}$$

$$C \quad Vwc = \underline{34.90} \text{ ft}^3$$

The average ΔH orifice in in.H₂O is:

$$\Delta H \text{ orifice}_{\text{avg}} = \frac{\sum \Delta H \text{ orifice}}{\# \text{ points}}$$

$$\Delta H \text{ orifice}_{\text{avg}} = \frac{21.39}{24}$$

D) $\Delta H \text{ orifice}_{\text{avg}} = 0.966 \text{ in.H}_2\text{O}$

The pressure at the gas meter (Pm) in in.Hg is:

$$P_m = P_{\text{bar}} + \frac{\Delta H \text{ orifice}_{\text{avg}} \text{ in.H}_2\text{O}}{13.6 \text{ in.H}_2\text{O/in.Hg}}$$

$$P_m = 29.98 + \frac{0.966}{13.6}$$

$$P_m = 29.98 + 0.071$$

E) $P_m = 30.05 \text{ in.Hg}$

The temperature of the gas meter (Tm) in °R is:

$$T_m = \frac{\sum \text{meter temp. } ^\circ\text{F}}{\# \text{ points}} + 460$$

$$T_m = \frac{327.9}{48} + 460$$

$$T_m = 68.31 + 460$$

F) $T_m = 528.31 \text{ } ^\circ\text{R}$

The total volume of gas metered (V_m) in ft^3 is:

$$V_m = V_f \text{ ft}^3 - V_i \text{ ft}^3$$

$$V_m = \underline{215.80} - \underline{164.96}$$

$$V_m = \underline{50.84} \text{ ft}^3$$

G

The dry gas volume at reference conditions (V_{mc}) in ft^3 is:

$$V_{mc} = \frac{T_{ref} \text{ } ^\circ\text{R}}{P_{ref} \text{ in.Hg}} \times \frac{P_m \text{ in.Hg} \times V_m \text{ ft}^3 \times Y}{T_m \text{ } ^\circ\text{R}}$$

$$V_{mc} = \frac{537}{29.92} \times \frac{30.05}{1} \times \frac{50.84}{528.31} \times 0.974$$

$$V_{mc} = \underline{50.55} \text{ ft}^3 \times 1 \text{ m}^3 / 35.31 \text{ ft}^3 = \underline{1.43} \text{ m}^3$$

H

The stack gas moisture content, i.e. the proportion by volume of water vapour in the gas stream (B_{wo}) is:

$$B_{wo} = \frac{V_{wc} \text{ ft}^3}{V_{wc} \text{ ft}^3 + V_{mc} \text{ ft}^3}$$

$$B_{wo} = \frac{34.90}{34.90 + 50.84}$$

$$B_{wo} = \underline{0.407}$$

$$B_{wo} = \underline{0.407}$$

I

The Molecular weight of the stack gas on a wet basis (Ms) in lb/lb-mole is:

$$Ms = Md \text{ lb/lb-mole} (1 - B_{wo}) + 18 \text{ lb/lb-mole} \times B_{wo}$$

$$Ms = \underline{29.34} \times (1 - \underline{0.407}) + 18 \times \underline{(0.407)}$$

$$Ms = \underline{29.34} \times \underline{0.59} + \underline{7.32}$$

$$Ms = \underline{24.72} \text{ lb/lb-mole}$$

The average temperature of the stack ($T_{s \text{ avg}}$) in °R is:

$$T_{s \text{ avg}} = \frac{\sum T_s \text{ °F}}{\# \text{ points}} + 460$$

$$T_{s \text{ avg}} = \frac{\underline{7099}}{24} + 460$$

$$T_{s \text{ avg}} = \underline{715.75} + 460$$

$$T_{s \text{ avg}} = \underline{755.75} \text{ °R}$$

The average velocity ($U_{s \text{ avg}}$) of the stack in ft/s is:

$$U_{s1} = 85.33 C_p \sqrt{\frac{\Delta P_1 \cdot T_{s1}}{P_s \cdot M_s}} = 85.33(0.756) \frac{\sqrt{(0.35)(759)}}{\sqrt{(0.99)(24.7)}}$$

$$U_{s1} = \underline{38.52} \text{ ft/s}$$

$$U_{s \text{ avg}} = \frac{\sum V}{\# \text{ points}}$$

$$U_{s \text{ avg}} = \frac{\underline{950.86}}{24}$$

$$U_{s \text{ avg}} = \underline{39.62} \text{ ft/s} \times 1 \text{ m} / 3.281 \text{ ft} = \underline{12.07} \text{ m/s}$$

The cross-sectional area of the stack (As) in ft² is:

$$As = \frac{\pi (D \text{ ft})^2}{4}$$

$$As = \frac{\pi}{4} \times (\underline{48/12})^2$$

$$As = 0.7854 \times \underline{16}$$

$$As = \underline{12.57} \text{ ft}^2$$

The volumetric stack gas flowrate on a dry basis at reference conditions (Qs) in ft³/hr is:

$$Qs = 3600 \text{ s/hr} \times Us \text{ ft/s} \times As \text{ ft}^2 \times (1 - Bwo) \times \frac{T_{ref} \text{ }^{\circ}\text{R}}{T_{S_{avg}} \text{ }^{\circ}\text{R}} \times \frac{Ps \text{ in.Hg}}{P_{ref} \text{ in.Hg}}$$

$$Qs = 3600 \times \underline{39.62} \times \underline{12.57} \times (1 - \underline{0.407}) \times \frac{\underline{537}}{\underline{755.75}} \times \frac{\underline{29.99}}{29.92}$$

$$Qs = 3600 \times \underline{39.62} \times \underline{12.57} \times \underline{0.59} \times \underline{0.71} \times \underline{1.002}$$

$$Qs = \underline{757.2205} \text{ ft}^3/\text{hr} \times 1 \text{ hr} / 60 \text{ min} = \underline{12.587} \text{ ft}^3/\text{min}$$

$$Qs = \underline{12.587} \text{ ft}^3/\text{min} \times 1 \text{ m}^3 / 35.31 \text{ ft}^3 \times 1 \text{ min} / 60 \text{ s} = \underline{35.94} \text{ m}^3/\text{s}$$

The total amount of particulate matter collected (Mp) in mg is:

$$Mp = \underline{21.1} \text{ mg}$$

The concentration of the particulate matter in the stack gas on a dry basis at reference conditions (Cp) in lb/ft³ is:

$$Cp = 2.205 \times 10^{-6} \text{ lb/mg} \times \frac{Mp \text{ mg}}{Vmc \text{ ft}^3}$$

$$Cp = 2.205 \times 10^{-6} \text{ lb/mg} \times \frac{\underline{21.1}}{50.55}$$

$$\textcircled{D} \quad Cp = \underline{9.20 \times 10^{-7}} \text{ lb/ft}^3 \times 453,590 \text{ mg/lb} \times 35.31 \text{ ft}^3/\text{m}^3 = \underline{14.7} \text{ mg/m}^3$$

The emission rate of the particulate matter from the stack on a dry basis at reference conditions (ERp) in lb/hr is:

$$Erp = Cp \text{ lb/ft}^3 \times Qs \text{ ft}^3/\text{hr}$$

$$Erp = \underline{9.20 \times 10^{-7}} \times \underline{757 \text{ L} \text{hr}}$$

$$Erp = \underline{0.695} \text{ lb/hr} \times 1 \text{ kg/2.20 lb} = \underline{0.31} \text{ kg/hr} \quad \checkmark$$

Appendix M-2

Greenhouse Gas Emissions, 2017 & 2018

Report Preview

Company Details

Name

CertainTeed Canada, Inc.

Report Details

Report Status:

Ready to Submit -

Reporting Period:

2017

Facility Name:

McAdam Wallboard Plant

Facility Address:

57 Quality Way McAdam (New Brunswick) E6J 1B1Canada

Report Type:

Report ECCC & NB

Report Update Comments:

Verify Facility Information

Please verify the following information.

Company Information

Legal Name *

CertainTeed Canada, Inc.

English Trade Name

CertainTeed Gypsum

French Trade Name

Business Number

808787147

DUNS Number

Facility Details

Facility Name *	McAdam Wallboard Plant
Physical Address *	57 Quality Way McAdam (New Brunswick) E6J 1B1 Canada 45.59360 -67.30960
Primary NAICS Code *	327420
GHGRP ID	0 (GHGRP ID to be assigned by ECCC)
NPRI ID	5095

Reporter

Name *	Stephen Dennis
Position *	Snr Automation Specialist
Mailing Address *	57 Quality Way Mcadam (New Brunswick), E6J 1B1, Canada
Physical Address *	57 Quality Way Mcadam (New Brunswick), E6J 1B1, Canada
Email Address *	steve.dennis@saint-gobain.com
Telephone Number *	5067847008
Ext.	

Authorized Signing Officer (Certifying Official)

Name *	Alexey Avdyushin
Position *	Regional Manager, EHS&S
Mailing Address *	2424 Lakeshore Road West, Mississauga (Ontario), L5J 1K4, Canada
Physical Address *	2424 Lakeshore Road West, Mississauga (Ontario), L5J 1K4, Canada
Email Address *	alexey.avdyushin@saint-gobain.com
Telephone Number *	9054032797
Ext.	

Parent Company Information

SAINT-GOBAIN CORPORATION

Legal Name *	SAINT-GOBAIN CORPORATION
Percentage of ownership of the reporting company *	100.00
Physical Address *	750 E Swedesford Road Valley Forge (Pennsylvania), 19482, United States
Business Number **	121891469
DUNS Number	

Facility Activities

Activities

You must select at least one activity

None of the above

Section A

Report the direct greenhouse gas emissions for this facility for the period identified above.

Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

N/A = Not Applicable MDM = Monitoring or Direct Measurement MB = Mass Balance EF = Emission Factors EE = Engineering Estimates

Stationary Fuel Combustion Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	12898.4	12898.4
<input type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.336	8.400
<input type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.225	67.050
Sub-total		12973.850					

Industrial Process Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Sub-total							

Venting Emissions (including vented Formation CO2)

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Sub-total							

Flaring Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					
-------------------------------------	----------------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

Sub-total

Leakage Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

On-site Transportation Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
<input type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	88.2 <input type="checkbox"/>
<input type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	0.03728 <input type="checkbox"/> 0.93200 <input type="checkbox"/>
<input type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	0.05203 <input type="checkbox"/> 15.50494 <input type="checkbox"/>

Sub-total

 104.63694

Waste Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
-----	----------------	--------	-------	-------	-------	------------------	---------------------------------

<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

Wastewater Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

Section B

Report the direct greenhouse gas emissions for this facility for the period identified above. Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

Note: CO₂ emissions from biomass combustion are not included in the total reported to Environment and Climate Change Canada.

N/A = Not Applicable
MDM = Monitoring or Direct Measurement
MB = Mass Balance
EF = Emission Factors
EE = Engineering Estimates

Biomass Combustion Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
-----	----------------	--------	-------	-------	-------	------------------	---------------------------------

<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
-------------------------------------	-----------------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

Section C

Report the direct emissions of HFCs, PFCs and SF6 from industrial processes and industrial product use only for this facility for the period identified above.

Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

N/A = Not Applicable
MDM = Monitoring or Direct Measurement
MB = Mass Balance
EF = Emission Factors
EE = Engineering Estimates

Hydrofluorocarbon (HFC) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
<input checked="" type="checkbox"/>	HFC-23 (CHF ₃)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-32 (CH ₂ F ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-41 (CH ₃ F)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-43-10mee (C ₅ H ₂ F ₁₀)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-125 (C ₂ HF ₅)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-134 (C ₂ H ₂ F ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-134a (C ₂ H ₂ F ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-143 (C ₂ H ₃ F ₃)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-143a	<input type="checkbox"/>					

(C2H3F3)

<input checked="" type="checkbox"/>	HFC-152a (C2H4F2)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-227ea (C3HF7)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-236fa (C3H2F6)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-245ca (C3H3F5)	<input type="checkbox"/>					
Total		<input type="checkbox"/>					

Perfluorocarbon (PFC) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO2e)
<input checked="" type="checkbox"/>	Perfluoro methane (CF4)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluoroe thane (C2F6)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluorop ropane (C3F8)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluorob utane (C4F10)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluoroc yclobutane (c-C4F8)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Perfluoropentane (C5F12)		
-----------------------------	--	--

<input checked="" type="checkbox"/> Perfluorohexane (C6F14)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--	--------------------------	--------------------------	--------------------------	--------------------------

Total

Sulphur Hexafluoride (SF6) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input checked="" type="checkbox"/>	Sulphur hexafluoride (SF6)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	 	

Summary

No input required - GHG totals are calculated automatically.

Total GHG Emissions for the Facility

	Emissions (t)	Emissions (t CO2e)
Carbon Dioxide (CO2)	12986.6	12986.6
Methane (CH4)	0.37328	9.33200
Nitrous Oxide (N2O)	0.27703	82.55494
Hydrofluorocarbons (HFCs)		
Perfluorocarbons (PFCs)		
Sulphur hexafluoride (SF6)		
Facility Total reported to Environment and Climate Change Canada:		13078.48694
Carbon dioxide (CO2) from biomass combustion:		

Facility Total reported to New Brunswick:

13078.48694

Comments

This section is optional.

Enter any comments you wish to include related to the information you have reported.

General Comments will not be published.

General Comments

Comments: (max 4000 characters)

Reasons for Changes in GHG Emissions from Previous Year

Select the applicable reason or reasons

Additional Information: **

File Name

Date

Confidentiality Request

Environment and Climate Change Canada Confidentiality Request

The Canada Gazette Notice indicated that the Minister of the Environment intends to publish GHG emission totals by gas, by facility. Under the Canadian Environmental Protection Act, 1999 (CEPA 1999), you can request that part or all of the information that you have provided in this report be treated as confidential. You must provide appropriate justification to support this request (see Help for more information).

Are you requesting confidentiality of this report under CEPA 1999? *

No

If yes, you must upload a document containing your written request to Environment and Climate Change Canada with your report submission that includes:

- Identification of the specific information that you wish to keep confidential

- Appropriate justification and supporting documentation

An Environment and Climate Change Canada representative will be in contact with you regarding your request.

Click on the icon located to the right of your screen to upload your Environment and Climate Change Canada Confidentiality Request.

File Name	Date

Report Preview

Company Details

Name

CertainTeed Canada, Inc.

Report Details

Report Status:

Ready to Submit -

Reporting Period:

2018

Facility Name:

McAdam Wallboard Plant

Facility Address:

57 Quality Way McAdam (New Brunswick) E6J 1B1Canada

Report Type:

Report ECCC & NB

Report Update Comments:

[Empty text area for Report Update Comments]

Verify Facility Information

Please verify the following information.

Company Information

Legal Name *

CertainTeed Canada, Inc.

English Trade Name

CertainTeed Gypsum

French Trade Name

[Empty text area for French Trade Name]

Business Number

808787147

DUNS Number

[Empty text area for DUNS Number]

Facility Details

Facility Name *	McAdam Wallboard Plant
Physical Address *	57 Quality Way McAdam (New Brunswick) E6J 1B1 Canada 45.59360 -67.30960
Primary NAICS Code *	327420
GHGRP ID	0 (GHGRP ID to be assigned by ECCC)
NPRI ID	5095

Reporter

Name *	Stephen Dennis
Position *	Snr Automation Specialist
Mailing Address *	57 Quality Way Mcadam (New Brunswick), E6J 1B1, Canada
Physical Address *	57 Quality Way Mcadam (New Brunswick), E6J 1B1, Canada
Email Address *	steve.dennis@saint-gobain.com
Telephone Number *	5067847008
Ext.	

Authorized Signing Officer (Certifying Official)

Name *	Alexey Avdyushin
Position *	Regional Manager, EHS&S
Mailing Address *	2424 Lakeshore Road West, Mississauga (Ontario), L5J 1K4, Canada
Physical Address *	2424 Lakeshore Road West, Mississauga (Ontario), L5J 1K4, Canada
Email Address *	alexey.avdyushin@saint-gobain.com
Telephone Number *	9054032797
Ext.	

Parent Company Information

SAINT-GOBAIN CORPORATION

Legal Name *	SAINT-GOBAIN CORPORATION
Percentage of ownership of the reporting company *	100.00
Physical Address *	750 E Swedesford Road Valley Forge (Pennsylvania), 19482, United States
Business Number **	121891469
DUNS Number	

Facility Activities

Activities

You must select at least one activity

None of the above

Section A

Report the direct greenhouse gas emissions for this facility for the period identified above.

Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

N/A = Not Applicable MDM = Monitoring or Direct Measurement MB = Mass Balance EF = Emission Factors EE = Engineering Estimates

Stationary Fuel Combustion Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	15669.3	15669.3
<input type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.4	10.0
<input type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.2695	80.3110
Sub-total		15759.6110					

Industrial Process Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Sub-total							

Venting Emissions (including vented Formation CO2)

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Nitrous Oxide (N2O)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Sub-total							

Flaring Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO2e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<input checked="" type="checkbox"/>	Methane (CH4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					
-------------------------------------	----------------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

Sub-total

Leakage Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

On-site Transportation Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
<input type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	109.2	109.2
<input type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.04612	1.15300
<input type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	0.00627	1.86846

Sub-total

 112.22146

Waste Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO ₂ e)
-----	----------------	--------	-------	-------	-------	------------------	---------------------------------

<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

Wastewater Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Methane (CH ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Nitrous Oxide (N ₂ O)	<input type="checkbox"/>					

Sub-total

Section B

Report the direct greenhouse gas emissions for this facility for the period identified above. Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

Note: CO₂ emissions from biomass combustion are not included in the total reported to Environment and Climate Change Canada.

N/A = Not Applicable
 MDM = Monitoring or Direct Measurement
 MB = Mass Balance
 EF = Emission Factors
 EE = Engineering Estimates

Biomass Combustion Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
-----	----------------	--------	-------	-------	-------	------------------	---------------------------------

<input checked="" type="checkbox"/>	Carbon Dioxide (CO ₂)	<input type="checkbox"/>					
-------------------------------------	-----------------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

Section C

Report the direct emissions of HFCs, PFCs and SF6 from industrial processes and industrial product use only for this facility for the period identified above.

Click Validate to check for errors and Save/Continue to save the information. If there are any errors, they will be flagged. If there are no errors, the page will be Complete.

N/A = Not Applicable MDM = Monitoring or Direct Measurement MB = Mass Balance EF = Emission Factors EE = Engineering Estimates

Hydrofluorocarbon (HFC) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO ₂ e)
<input checked="" type="checkbox"/>	HFC-23 (CHF ₃)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-32 (CH ₂ F ₂)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-41 (CH ₃ F)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-43-10mee (C ₅ H ₂ F ₁₀)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-125 (C ₂ HF ₅)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-134 (C ₂ H ₂ F ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-134a (C ₂ H ₂ F ₄)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-143 (C ₂ H ₃ F ₃)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-143a	<input type="checkbox"/>					

(C2H3F3)

<input checked="" type="checkbox"/>	HFC-152a (C2H4F2)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-227ea (C3HF7)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-236fa (C3H2F6)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	HFC-245ca (C3H3F5)	<input type="checkbox"/>					
Total		<input type="checkbox"/>					

Perfluorocarbon (PFC) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions(t CO2e)
<input checked="" type="checkbox"/>	Perfluoro methane (CF4)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluoroe thane (C2F6)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluorop ropane (C3F8)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluorob utane (C4F10)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>	Perfluoroc yclobutane (c-C4F8)	<input type="checkbox"/>					
<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Perfluoropentane (C5F12)		
-----------------------------	--	--

<input checked="" type="checkbox"/>	Perfluorohexane (C6F14)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
-------------------------------------	----------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--	--

Total

--

Sulphur Hexafluoride (SF6) Emissions

N/A	Substance Name	MDM **	MB **	EF **	EE **	Emissions (t) **	Emissions (t CO2e)
<input checked="" type="checkbox"/>	Sulphur hexafluoride (SF6)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Summary

No input required - GHG totals are calculated automatically.

Total GHG Emissions for the Facility

	Emissions (t)	Emissions (t CO2e)
Carbon Dioxide (CO2)	15778.5	15778.5
Methane (CH4)	0.44612	11.15300
Nitrous Oxide (N2O)	0.27577	82.17946
Hydrofluorocarbons (HFCs)		
Perfluorocarbons (PFCs)		
Sulphur hexafluoride (SF6)		
Facility Total reported to Environment and Climate Change Canada:		15871.83246
Carbon dioxide (CO2) from biomass combustion:		

Facility Total reported to New Brunswick:

15871.83246

Comments

This section is optional.

Enter any comments you wish to include related to the information you have reported.

General Comments will not be published.

General Comments

Comments: (max 4000 characters)

Reasons for Changes in GHG Emissions from Previous Year

Select the applicable reason or reasons

Additional Information: **

File Name

Date

Confidentiality Request

Environment and Climate Change Canada Confidentiality Request

The Canada Gazette Notice indicated that the Minister of the Environment intends to publish GHG emission totals by gas, by facility. Under the Canadian Environmental Protection Act, 1999 (CEPA 1999), you can request that part or all of the information that you have provided in this report be treated as confidential. You must provide appropriate justification to support this request (see Help for more information).

Are you requesting confidentiality of this report under CEPA 1999? *

No

If yes, you must upload a document containing your written request to Environment and Climate Change Canada with your report submission that includes:

- Identification of the specific information that you wish to keep confidential

- Appropriate justification and supporting documentation

An Environment and Climate Change Canada representative will be in contact with you regarding your request.

Click on the icon located to the right of your screen to upload your Environment and Climate Change Canada Confidentiality Request.

File Name	Date