

2008 - 04

FIRE TECHNOTE

NOTE TECHNIQUES DES INCENDIE

From: Technical Inspection Services

Date: July 2008

Subject: **Water supply reservoirs for
sprinkler systems**

Any private water reservoir supplying a sprinkler system shall be acceptable to the Office of the Fire Marshal.

Method and description of water reservoir shall be submitted for review along with sprinkler system shop drawings.

Origine : Services d'inspection technique

Date : Juillet 2008

Objet : **Réservoir d'eau d'alimentation pour
systèmes de gicleurs**

Tout réservoir d'eau privé utilisé pour alimenter un système de gicleurs doit être approuvé par le Bureau du prévôt des incendies.

La méthode d'alimentation et la description du réservoir d'eau, de même que les dessins d'atelier du système de gicleurs, doivent être soumis à des fins d'examen.